




SYNC 3.0 CONSORTIUM
systems yielding new consciousnesses

PROJECT OBSIDIAN

Technical & Commercial Feasibility Audit

50 MW Critical-IT AI Data Center Retrofit · NVIDIA GB200 NVL72 · ZLD Architecture

DOCUMENT REF.	OBSIDIAN-2026
CLASSIFICATION	CONFIDENTIAL // INTERNAL
STATUS	DRAFT
DATE	15 July 2026
PREPARED FOR	Investment Committee & Syndicated LPs
PREPARED BY	Lead Technical Due Diligence Auditor / Project EPC Directorate



This document contains proprietary technical and commercial analysis and is intended solely for the use of the addressee(s). Any unauthorized reproduction, distribution, or disclosure of its contents — in whole or in part — is strictly prohibited.



CONFIDENTIAL // INTERNAL MEMORANDUM

DATE: 15 July 2026

TO: Investment Committee & Syndicated LPs

FROM: Lead Technical Due Diligence Auditor / Project EPC Directorate

SUBJECT: Technical & Commercial Feasibility Audit: Project “Obsidian” — 50 MW Critical AI Retrofit (NVIDIA GB200 NVL72), ZLD Architecture

EXECUTIVE SUMMARY

This memorandum evaluates the structural, thermodynamic, and commercial feasibility of a 50 MW critical-IT-load data center retrofit configured exclusively for NVIDIA GB200 NVL72 clusters. The design targets an aspirational Power Usage Effectiveness (PUE) of < 1.15 utilizing a closed-loop Zero-Liquid-Discharge (ZLD) heat-rejection topology. This assessment strips away vendor optimism to present the raw electromechanical realities of integrating ~416 discrete 120+ kW racks.

TASK 1: THERMODYNAMIC & POWER LEDGER

1.1 Power Allocation Breakdown (The Math)

To sustain a 50.00 MW critical IT load at a PUE of < 1.15 , the total facility power draw must not exceed 57.50 MW. This leaves an incredibly narrow 7.50 MW overhead buffer for all thermal management, power step-down, distribution losses, and ancillary operations.

Power Component	Sub-System Allocation	MW Draw	% of Total	Notes
Critical IT Load	Compute (GPUs, CPUs, NVSwitches)	50.00	87.1%	Hardware baseline (100% utilization)
Cooling Load	Primary Dry Coolers / Fans	2.65	4.6%	VFD-driven EC fans (varies by ambient T)
	Liquid Pumps (FWS Primary Loop)	1.10	1.9%	Major delta-P compensation across plant
	CDUs (Coolant Distribution Units)	0.85	1.5%	Secondary loop (TCS) pumping to cold plates
	Residual Air Handling (CRAHs)	0.80	1.4%	Handles ambient radiation (10-15% of rack load)
Subtotal Cooling		5.40	9.4%	Cooling overhead (partial pPUE: 1.108)
Facility / Power Losses	UPS/BESS Conversion Inefficiencies	1.40	2.4%	Assuming 97% eco-mode double-conversion



Power Component	Sub-System Allocation	MW Draw	% of Total	Notes
	Switchgear & Transformer Losses	0.50	0.9%	Baseline thermal losses in distribution network
	Ancillary/Lighting/Security	0.10	0.2%	Standard DC physical plant overhead
Subtotal Facility		2.00	3.5%	Power chain overhead
TOTAL FACILITY		57.40	100.0%	Calculated PUE: 1.148

PUE Math: \$Total Facility Power (57.40 MW) / IT Equipment Power (50.00 MW) = 1.148 PUE.*

1.2 GB200 Cooling Architecture Reality Check

The GB200 NVL72 pulls an aggregate 120–132 kW/rack. Vendor marketing frequently conflates cooling topologies. We are rejecting two-phase dielectric immersion entirely; it is technically deprecated at this density due to severe PFAS/GWP compliance phase-outs, extreme fluid cost (\$200+/liter), and complex pressure/vapor-loss containment at scale.

We are strictly implementing NVIDIA's reference **Direct-to-Chip (D2C) closed-loop water-based architecture**.

- **Secondary Loop (TCS - Technology Cooling System):** Operates via manifold blindly routed into the rack utilizing PG25 (25% propylene glycol/water) or ultra-low conductivity treated water. Captures ~85% of total rack heat (GPUs, Grace CPUs, NVSwitches via copper micro-skived cold plates).
- **Primary Loop (FWS - Facility Water System):** The inter-loop CDUs transfer heat to a closed pipe network supplying external heat rejection.
- **Caveat:** D2C captures 85%. The remaining ~15% (18-20 kW per rack) radiates to air and mandates high-density sensible cooling modules (rear-door heat exchangers or advanced in-row coolers); ignoring this residual heat leads to structural thermal runaway.

1.3 Water Math & ZLD Engineering Honesty

Traditional vs. ZLD Performance Metrics:

- Traditional Evaporative Towers: ~1.8 - 2.2 L/kWh.
- Pure Dry Coolers (ZLD Target): ~0.0 L/kWh.

The Compromise: Reaching a strict 1.15 PUE with pure 0 L/kWh dry coolers is largely an aspirational fiction if ambient dry bulb temperatures exceed 35°C (95°F) for any sustained duration. A closed-loop D2C architecture rejects heat at higher temperatures (~45°C primary return), which extends the economization hours of dry coolers. However, during high-ambient seasonal peaks, to maintain thermal setpoints without using mechanical chiller trim (which ruins the 1.15 PUE target), **adiabatic-assist cooling** is mandatory.

Adiabatic systems atomize a fine water mist to pre-cool intake air. This consumes water (~0.10 to 0.20 L/kWh dynamically) but yields no blowdown water. Thus, we achieve the regulatory definition of **Zero Liquid Discharge (0 L/kWh discharged to sewer system)**, but not *zero consumption*. Project underwriting must reflect an annualized WUE (Water Usage Effectiveness) of ~0.05 L/kWh.



TASK 2: CAPEX BREAKDOWN (~\$550M Pre-GPU)

Extrapolating 50 MW critical IT at ~550M equates to **\$11 million per MW**. This is undeniably at the highest end of the CapEx spectrum (industry standard is typically 8M–\$10M/MW). The premium is strictly governed by three factors:

1. Retrofitting multi-story load-bearing limits for 3,000+ kg hardware nodes.
2. Exotic fluid distribution/manifold tiering and heavy redundancy.
3. Enhanced Backup & BESS logic for AI transient di/dt drops (step-load changes).

EPC Category	Cost Estimate (USD)	\$/MW Equivalency	Technical Scope & Justification
Land & Civil	\$15,000,000	\$0.3M / MW	Site acquisition assumed inherited. Covers major zoning adjustments, civil groundwork for localized switchyards, and containment vaults.
Core & Shell Retrofit	\$95,000,000	\$1.9M / MW	Heavy structural reinforcement. NVL72 floor loadings hit >2,000 kg/sqm. Demolition of existing airplenums; installation of heavy steel framing for elevated liquid manifolds and robust ceiling rigging.
ZLD / D2C Thermal Loop	\$145,000,000	\$2.9M / MW	Significant premium over air cooling. High-capacity VFD pumps, stainless steel primary piping, liquid redundancy (N+1 CDUs), and adiabatic dry coolers. Includes advanced leak telemetry.
Substation & Switchgear	\$135,000,000	\$2.7M / MW	Utility-scale primary substation build, high-amp busway duct routing, heavy switchgear, fault-current limiters. Oversized to handle 60 MW gross demand.
Backup Generation (Gensets + BESS)	\$160,000,000	\$3.2M / MW	Tier III compliant N+1 generation. <i>Critically:</i> integration of Battery Energy Storage Systems (BESS) alongside advanced UPS to instantaneously buffer massive AI "step-load" training drops (di/dt) without dropping grid sync.
TOTAL (Pre-Server Box)	\$550,000,000	\$11.00M / MW	Exclusive of \$1.5B+ CapEx value of the NVIDIA clusters.

Note to Underwriters: Supply chain constraints on high-amperage switchgear and liquid CDUs add ~12-18 months of schedule risk unrepresented in this direct dollar cost.



TASK 3: PHASE 0 CONSORTIUM PARTNER PROFILES

To mitigate schedule and operational risk, the retrofit depends on three principal consortium actors tightly aligned under Phase 0 Front End Engineering Design (FEED).

1. Tier-1 EPC Firm

- **Profile:** Must have >500 MW completed portfolio with verified liquid-to-chip deployment history (e.g., Mortenson, DPR, Holder).
- **Responsibilities:**
- **Structural Auditing:** Validation of dynamic and static structural tolerances. The shift from air displacement to centralized fluid masses necessitates profound slab load re-engineering.
- **Fluid Integrity & SCADA:** Executing high-pressure welding standards (no ProPress bypasses) and integrating a bespoke BMS/SCADA regime configured for micro-second thermal anomaly tracking and zonal shutdown triggers to counter leak risks.

2. Municipal Water Authority (Host City)

- **Profile:** Regulating body controlling industrial water tapped from municipal supplies (often highly politicized in key data hub markets e.g., Northern Virginia, Phoenix, Querétaro).
- **Responsibilities / Synergy:**
- **Permitting Fast-Track:** Standard 50 MW data centers face lethal community opposition over tower evaporation. The ZLD and low-WUE design acts as the core wedge for rapid CEQA/municipal approval.
- **Telemetry Auditing:** Real-time volumetric meter integration tied to municipal portals to maintain specialized tiered non-evaporative industrial rate structures and secure the Certificate of Occupancy.

3. Compute Operator / Hyperscaler Tenant

- **Profile:** The anchor tenant (e.g., Microsoft, CoreWeave, Meta).
- **Responsibilities:**
- **Equipment Provisioning:** Delivery of the ~416 NVL72 racks and internal NVSwitch network topology (Infiniband networking fabrics represent ~150 miles of inter-rack copper and fiber cabling).
- **SLA Compliance & Modulating Load:** Tenant must program their cluster orchestrators to interface with the facility BMS. Since PUE spikes under pure dry cooling in >35°C peak summer days, the Tenant must enable software-based power capping (thermal throttling) natively across the GB200 nodes locally, preventing catastrophic secondary-loop overheating while honoring SLA limits.

CONCLUSION:

The 1.15 PUE target strictly using standard dry cooling in an NVL72 architecture is highly vulnerable to seasonal ambient peak realities. The retrofit's ~\$11M/MW price is defensively correct due to unprecedented structural and electrical stability demanded by the 120kW density. Execution fundamentally rests on the joint telemetry integration between the EPC's liquid manifold design and the Tenant's compute orchestration.

~anthropic/claude-opus-latest



I'll produce this memo. Let me first verify a few current technical parameters that materially affect the numbers — GB200 NVL72 rack power, WUE benchmarks, and current EPC /MW figures — *since these have shifted recently and precision matters for institutional DD. I have strong data on rack power and WUE. Let me verify current EPC /MW CapEx figures for AI data centers to ground Task 2. I have sufficient grounding across all three tasks. Let me run the thermodynamic and CapEx math precisely, then write the memo. All figures reconcile. Producing the memo.*

TECHNICAL DUE DILIGENCE MEMORANDUM

Project: 50 MW Critical-IT AI Data Center Retrofit — GB200 NVL72 Deployment

Prepared for: PE Investment Committee / Lead Arranger

Classification: Confidential — Institutional TDD | Rev. A | 15 Jul 2026

Prepared under joint authority: Lead Hyperscale DC Architecture · Tier-1 EPC Delivery · PE Technical DD Audit

Reviewer's standing note: This memo is written to institutional underwriting standards. Every material figure is flagged as [STD] industry-standard, [ASP] aspirational/best-in-class (achievable but sensitive to execution/climate), or [MOD] modeled/derived. The single largest residual risk in the thesis is **climate-dependence of the dry-cooler ZLD architecture**, quantified in §1.4.

EXECUTIVE SUMMARY

Parameter	Value	Flag
Critical IT load	50.0 MW	Given
Target PUE	< 1.15 (design point 1.15; stretch 1.12)	[ASP]
Total facility power draw @ PUE 1.15	57.5 MW	[MOD]
Rack population	~379 × GB200 NVL72 @ 132 kW	[MOD]
GPU count	~27,288 Blackwell GPUs	[MOD]
Cooling architecture	D2C water-glycol (cold plate) + air-cooled dry coolers + adiabatic assist; ZLD	Design
Design WUE	0.02–0.20 L/kWh (vs 1.8–2.2 evaporative baseline)	[ASP/MOD]
Pre-GPU CapEx	~\$55M (11.1M/MW critical IT)	[MOD]
CapEx characterization	Upper-mid of pre-GPU band; justified by power redundancy + liquid loop	[STD]

Verdict: The technical thesis is **sound and buildable**. PUE < 1.15 is achievable with a hybrid dry-cooler/adiabatic loop in **temperate/cool climates**; it is **conditional and at risk in hot-dry climates** where either PUE breaches 1.15 (mechanical assist) or WUE rises above zero (adiabatic assist). The ZLD claim is **directionally honest but must be**



stated as "near-zero evaporative consumption," not literal zero. CapEx at \$555M is credible for the specified redundancy tier.

TASK 1 — THERMODYNAMIC & POWER LEDGER

1.1 PUE Derivation (the math)

PUE = Total Facility Power ÷ IT Power. Solving for the overhead budget:

$$PUE = \frac{P_{IT} + P_{overhead}}{P_{IT}} = 1.15 \rightarrow P_{total} = 50 \times 1.15 = 57.5 \text{ MW}$$

Total overhead budget = 7.5 MW. For the 1.12 stretch case, overhead compresses to **6.0 MW** — a punishing 20% reduction that leaves near-zero margin for mechanical cooling assist. This is why 1.15 is the design point and 1.12 is flagged aspirational.

1.2 Power Ledger @ PUE 1.15 (7.5 MW overhead allocation) [MOD]

Subsystem	Power (MW)	% of overhead	Basis / commentary
Critical IT load	50.00	—	379 racks × 132 kW
Liquid loop parasitics (CDU pumps, dry-cooler fans, adiabatic pumps)	1.70	22.7%	Pumping + fan power is the dominant overhead in a chiller-less design
Air loop (fan-wall / CRAH for the ~17 kW/rack air fraction)	1.30	17.3%	See §1.3 — NVL72 is not 100% liquid
UPS / rectification losses	1.60	21.3%	~96.8% eff. on protected load; Li-ion BESS + high-eff UPS
Transformer / MV-LV distribution losses	0.90	12.0%	Cascaded transformer + busway I ² R
Lighting / BMS / controls / security / office	0.70	9.3%	Non-IT house load
Reserve / commissioning margin	1.30	17.3%	Underwriting buffer; do not spend at design
Total facility	57.50	100%	PUE = 57.5/50 = 1.150

Auditor's flag: The reserve line (1.30 MW) is the honesty buffer. If a hot-climate site forces trim/mechanical assist, this reserve is the first casualty and PUE drifts toward 1.17–1.20. Do not underwrite 1.12 without a cool-climate site and elevated-temperature (W45/W40) coolant supply.

1.3 Cooling Architecture — Technical Honesty on D2C vs Immersion

The prompt's framing is **correct and must be preserved in the design record**. Key facts confirmed against vendor and reference-architecture sources:

- Each rack consumes 132 kW of power, with 115 kW liquid cooled and 17 kW air cooled. The GB200 NVL72 is therefore **not a 100% liquid-cooled box** — roughly 13% of rack heat (NVLink switch ancillaries, NICs, PSU, in-tray components) rejects to **air**, which is why the ledger carries a discrete air loop.
- The GB200 NVL72 ships only as a liquid-cooled rack: direct-to-chip cold plates on GPUs, CPUs, and NVLink switches, fed by CDUs and a facility water loop at roughly 2 L/s per rack.
- The coolant is **water/water-glycol, not dielectric**. Cold-plate specs require all wetted surfaces must be compatible with 50/50 EGW coolant per ASHRAE W55 water quality standards — EGW = ethylene glycol/water. This is the NVIDIA reference path.

Architecture decision — set the record straight:

Attribute	D2C water-glycol (SELECTED)	Two-phase dielectric immersion (REJECTED)
Coolant	50/50 EGW / treated water	Engineered fluid (e.g., fluorocarbon)
NVIDIA GB200 reference support	Yes — native	No — non-standard, voids reference design
Heat capture at chip	Cold plate, ~115 kW/rack	Tank submersion
Residual air heat	~17 kW/rack still needs air handling	Eliminated (but tank retrofit is extreme)
Serviceability	Rack-level, hot-swap trays	Fluid handling, hoist, drain time
Retrofit fit	Compatible with rack-and-roll	Requires tank infrastructure — poor retrofit fit

Verdict: For a **retrofit** with NVIDIA-referenced GB200 NVL72, **D2C water-glycol is the only defensible choice**. Dielectric immersion is a different architecture with fluid-cost, GWP/PFAS-regulatory, and serviceability liabilities and is **not** the NVIDIA reference path. Any pitch conflating "liquid cooling" with "immersion" is a red flag.

Loop topology (closed-loop ZLD):

[Cold plate @ chip] → TCS (Technology Cooling System, glycol) → [CDU liquid-liquid HX] → FWS (Facility Water System, closed loop) → [Dry coolers + adiabatic pre-cool pads] → heat rejected to atmosphere. Air fraction (~17kW/rack) → [fan wall / RDHX] → same FWS.

The **CDU** is the isolation boundary: Coolant Distribution Unit (CDU): Rack-external CDU supplies coolant at controlled temperature and flow. Typical CDU capacity: 150–200kW for NVL72 deployment. At ~379 racks, plan **~300–380 CDU-equivalent capacity units** in N+1 arrangement.

1.4 Water Math — the ZLD claim, honestly stated

IT energy basis: 50 MW × 8,760 h = 438 GWh/yr → **438 million kWh/yr** of IT load.

Cooling regime	WUE (L/kWh)	Annual water consumed	Flag
Traditional evaporative cooling tower (baseline)	1.8–2.2	788M – 964M L/yr (208–255 M gal)	[STD]
Dry-cooler-only (true ZLD, temperate climate)	~0.00–0.02	0 – 22M L/yr	[ASP]
Dry cooler + adiabatic assist (hot-climate reality)	0.05–0.20	22M – 88M L/yr	[MOD]



The evaporative baseline is well-supported: the average WUE across data centers is 1.8 L/kWh. Beating that average is a reasonable WUE goal. The consumptive reality of evaporative systems is severe: an evaporative cooling system supporting a 100 MW IT load would require a peak water withdrawal capacity of approximately 2.5 MGD. In hotter climates, this requirement could be substantially higher, even exceeding 5.0 MGD.

The closed-loop ZLD advantage is real and now industry-proven at fleet scale. Microsoft's closed-loop chip-cooling design confirms the mechanism: This zero-water evaporated for cooling design recycles water through a closed loop system. These new liquid cooling technologies recycle water through a closed loop. Once the system is filled during construction, it will continually circulate water between the servers and chillers to dissipate heat without requiring a fresh water supply. Fleet WUE has moved dramatically: average WUE has decreased from 2.3 L/kWh to 0.27 L/kWh in 2025.

THE HONEST ENGINEERING TRADE-OFF (this is the crux of the DD): dry cooling is not free. Microsoft states it plainly: Traditionally, water has been evaporated on-site to reduce the power demand of the cooling systems. Replacement of evaporative systems with mechanical cooling will increase our power usage effectiveness (PUE). However, our latest chip-level cooling solutions will allow us to utilize warmer temperatures for cooling than previous generations of IT hardware, which enables us to mitigate the power use with high efficiency economizing chillers with elevated water temperatures.**

Translation for underwriting: **you can have near-zero WUE OR sub-1.15 PUE cheaply — in a hot climate you may not get both.** The physics: a dry cooler can only reject heat to dry-bulb ambient; on a 40°C design day, approach temperatures collapse, fan power spikes (breaching the 1.7 MW liquid-loop budget), or you engage adiabatic spray pre-cooling — which **reintroduces water** and moves WUE from ~0 to 0.05–0.20. The regional spread is stark: Microsoft's WUE varies dramatically by location—Arizona operates at 1.52 L/kWh while Singapore achieves 0.02 L/kWh.

The enabling lever is warm-water D2C. GB200 cold plates tolerate minimum 2–3 L/min coolant flow per module and inlet temperature below 45°C. A **W40–W45 supply** widens the dry-cooler approach window and is the single most important design decision for reconciling ZLD with PUE < 1.15.

DD RULING ON ZLD: The correct memo language is "**near-zero evaporative water consumption (ZLD, closed-loop; no continuous makeup).**" Literal "zero-liquid-discharge" is defensible for the *process loop* (no blowdown, no discharge stream — the closed glycol loop is filled once and not discharged). But "zero water *consumption*" is only true in cool climates without adiabatic assist. **Do not let the sponsor market literal zero in a hot-dry site.**

TASK 2 — CAPEX BREAKDOWN (PRE-GPU, ~\$555M)

2.1 Itemized EPC Ledger [MOD]

EPC category	\$M	\$/MW crit-IT	%	Notes / benchmark
Land & Civil	40	0.80	7%	Site, grading, roads, security perimeter, water/sewer tie-in, retention
Core & Shell	95	1.90	17%	Structural (heavy — 1.36 t/rack point loads), halls, slab, fire, envelope



EPC category	\$M	\$/MW crit-IT	%	Notes / benchmark
Substation & Switchgear	175	3.50	32%	HV intake, transformers, MV/LV dist, UPS, Li-ion, busway — largest line
Backup Generation	120	2.40	22%	Gensets N+1, BESS bridging, fuel farm
ZLD / D2C Thermal Loop	95	1.90	17%	CDUs, dry coolers, adiabatic skids, TCS/FWS piping, thermal storage
Soft / EPC fee / commissioning / contingency	30	0.60	5%	Scripted L1–L5 functional testing, owner's engineer
TOTAL PRE-GPU	555	11.10	100%	

2.2 Benchmark Reconciliation & Honesty Flag

The \$500–650M pre-GPU range is on the high end — and correctly so. Current benchmarks:

- Standard shell-and-core: the average global data center construction cost increased from 7.7 to 10.7 million per MW... For 2026, JLL is forecasting the average global cost will increase 6% to \$11.3 million per MW.
- Critically, that shell figure **excludes** the AI fit-out: the figures in the chart only include the cost to construct the shell and core. Tenants are typically responsible for the tech fit-out which can cost as much as \$25 million per MW for AI infrastructure.

So our \$11.1M/MW pre-GPU is consistent with a **shell + full power + thermal loop** scope where the tenant supplies GPU/rack fit-out separately. The dominant cost driver is confirmed: Electrical and power systems remain the largest single expense, accounting for 40–50% of total construction costs... upgrading from Tier III to Tier IV redundancy could add another 15–25% to your budget. Our combined Substation+Backup lines (54%) reflect a **Tier III+ posture** — appropriate for AI training but a genuine cost sensitivity.

The cost-escalation thesis is well-attested: "The jump from 7M/MW in 2020 to 11M–\$20M/MW in 2026 isn't one cost driver. It's four: electrical density, liquid cooling, redundant power trains, and scripted functional testing."

GPU CapEx (separate, for context only): ~379 racks × ~3.0–3.5M/rack ≈ **\$1.1–1.3B** — i.e., *silicon dwarfs the building ~2:1, consistent with hyperscale TCO models where a typical one-gigawatt AI data center requires 38 billion in up-front capital expenditure...* Servers dominate this cost at \$5 billion per year, or 60% of the total.

Auditor's flags:

- **[FLAG — HIGH]** Substation lead time, not cost, is the binding constraint. Transformer/switchgear procurement now runs 80–130+ weeks. The \$175M line is credible; the *schedule* behind it is the risk.
- **[FLAG — MED]** Backup at \$120M assumes gensets + BESS bridging (not full-duration battery). If the site pursues gas-turbine or behind-the-meter generation, this line moves materially.
- **[FLAG — MED]** ZLD/D2C at 95M (1.9M/MW) is reasonable but carries the liquid-cooling premium; Turner & Townsend peg the incremental at a liquid-cooling cost premium of 7–10%. A dry-cooler-heavy design (more coils, more fan plant for hot climate) pushes the upper bound.



TASK 3 — PHASE 0 CONSORTIUM PARTNER PROFILES

3.1 Partner (1) — Tier-1 EPC Firm

Dimension	Scope & responsibility
Structural validation	Recertify slab/floor for 1.36 t/rack point loads at 379 positions. The rack weighs approximately 1.36 metric tons. Standard raised-floor tiles are rated for 250 kg per tile. A retrofit almost certainly requires slab-on-grade or structural reinforcement — raised floor is disqualified at this density.
Power delivery	Recertify distribution for roughly 130 kW of distribution per rack position on 415 V three-phase feeds. Validate busway ampacity, PDU sizing (200A+ per rack).
SCADA / BMS integration	Deliver unified control across power train, CDU/FWS, dry-cooler/adiabatic staging, leak detection (mandatory for D2C), and fire. Deliverable: single-pane telemetry with sub-loop granularity for PUE/WUE reporting, alarm federation, and automated adiabatic-assist staging logic.
Commissioning	Scripted L1–L5 functional testing, including integrated load-bank cooling trials simulating 132 kW/rack thermal steps and dry-cooler performance at design-day dry-bulb.
DD flag	EPC must warrant the CFD flow-distribution validation: CFD simulation required to validate flow distribution uniformity across the die footprint... Manifold design must ensure balanced flow distribution ($\pm 5\%$ flow rate per branch).

3.2 Partner (2) — Municipal Water Authority

Dimension	Scope & responsibility
Permitting sign-off	Withdrawal permit, discharge permit (ZLD closed loop = no continuous process discharge stream), backflow prevention on the one-time fill line.
Telemetry	Real-time makeup-water metering feeding the shared SCADA; monthly WUE attestation.
The permit thesis (confirmed advantage)	A genuine near-zero-evaporative design materially strengthens the municipal case in water-stressed regions . The public-water-system literature is explicit: a closed-loop cooled data center might only consume on the order of 5–10% of its water withdrawal (losing small amounts to leaks or incidental evaporation), returning ~90–95% as wastewater available for treatment. And an air-cooled data center consumes virtually zero water on-site. Versus an evaporative peer demanding a peak water withdrawal capacity of approximately 2.5 MGD, the ZLD design de-risks the interconnect politically and legally.



Dimension	Scope & responsibility
DD flag — honesty	The permit advantage is contingent on the site NOT relying on continuous adiabatic assist . If a hot-dry site engages adiabatic spray at WUE 0.20, annual makeup returns to ~88M L/yr — still ~9–11× better than evaporative, but no longer "zero." The permit application must state the design-day water draw, not the annual average.

3.3 Partner (3) — Compute Operator / Hyperscaler Tenant

Dimension	Scope & responsibility
Provides	GB200 NVL72 racks (~379), CDUs, in-rack coolant, network fabric (NVLink/InfiniBand), and the ~\$1.1–1.3B silicon CapEx. Owns hardware refresh (5–6 yr cycle).
Interface spec	Guarantees coolant supply temp/flow envelope ($\leq 45^{\circ}\text{C}$ inlet, 2–3 L/min per module), rack power factor, and the air/liquid heat split (115/17 kW). Facility must deliver FWS within the CDU's rated approach.
Compliance metrics	Contractual PUE ≤ 1.15 (annualized, climate-normalized), WUE ceiling (with adiabatic carve-out clause), thermal-availability SLA, and coolant water-quality spec (ASHRAE W55, 50/50 EGW).
DD flag	Tenant must accept climate-normalized PUE , not a flat number. A flat 1.15 SLA in a hot-dry site transfers un-hedgeable weather risk to the SPV. Reliability caveat noted: early GB200 racks carry early-rack reliability as a real operational caveat.

CONSOLIDATED RISK REGISTER & VERDICT

#	Risk	Severity	Mitigation
R1	Hot-climate PUE/WUE trade-off breaks one of the two targets	HIGH	Site selection (cool/temperate); W40–W45 warm-water design; climate-normalized SLA
R2	Substation/transformer lead time (80–130 wk)	HIGH	Owner-furnished long-lead procurement at Phase 0
R3	Structural retrofit for 1.36 t/rack	MED-HIGH	Slab reinforcement in Core & Shell budget; no raised floor
R4	"Literal zero water" over-marketing → permit/reputational exposure	MED	State design-day draw; use "near-zero evaporative" language
R5	GPU reliability / refresh mismatch to 14-yr facility life	MED	Tenant owns refresh; modular CDU/rack topology
R6	CapEx concentration in power train (54%)	MED	Fixed-price switchgear with escalation caps



FINAL VERDICT — CONDITIONAL PASS. The architecture is technically coherent and the numbers reconcile. The thesis is fundable **conditional on (a) a temperate/cool site, (b) warm-water D2C at W40–W45, (c) climate-normalized PUE/WUE SLAs, and (d) Phase-0 long-lead electrical procurement.** In a hot-dry site the design should be re-underwritten at PUE 1.18–1.20 or WUE 0.15–0.20 — pick one; the physics will not grant both cheaply.

Figures flagged [ASP] are best-in-class and execution/climate-sensitive; [MOD] are modeled from the stated 50 MW / 132 kW-rack basis; [STD] are current industry benchmarks. Silicon CapEx shown for context only and excluded from the \$555M pre-GPU total. This memo is technical DD, not investment advice or a legal opinion on permit outcomes.

References

1. [NVIDIA GB200 NVL72 by HPE | HPE Store](<https://buy.hpe.com/us/en/Compute/Rack-Scale-System/Nvidia-NVL-System/Nvidia-NVL-System/NVIDIA-GB200-NVL72-by-HPE/p/1014890104>)
2. [Nvidia Blackwell Explained: Data Center Impact | ModulEdge](<https://www.moduledge.com/blog/nvidia-blackwell>)
3. [NVIDIA GB200 NVL72 Cooling Requirements | ToneCooling](<https://tonecooling.com/nvidia-gb200-nvl72-cooling-requirements/>)
4. [A Guide to Data Center Water Usage Effectiveness (WUE) and Best Practices](<https://www.datacenterknowledge.com/cooling/a-guide-to-data-center-water-usage-effectiveness-wue-and-best-practices>)
5. [Small Bottle, Big Pipe: Quantifying and Addressing the Impact of Data Centers on Public Water Systems](<https://arxiv.org/pdf/2603.02705>)
6. [Sustainable by design: Next-generation datacenters consume zero water for cooling | The Microsoft Cloud Blog](<https://www.microsoft.com/en-us/microsoft-cloud/blog/2024/12/09/sustainable-by-design-next-generation-datacenters-consume-zero-water-for-cooling/>)
7. [Inside Microsoft's two-decade push to cut water intensity while scaling for growth - The Official Microsoft Blog](<https://blogs.microsoft.com/blog/2026/06/24/inside-microsofts-two-decade-push-to-cut-water-intensity-while-scaling-for-growth/>)
8. [Water Usage Efficiency: AI Data Center Cooling Without Crisis](<https://introl.com/blog/water-usage-efficiency-wue-ai-data-center-cooling-guide-2025>)
9. [2026 Global Data Center Market Outlook](<https://www.jll.com/en-us/insights/market-outlook/data-center-outlook>)
10. [Data Center Cost Per MW — 2026 Benchmarks](<https://www.irecruit.co/insights/data-center-construction-cost-per-mw-2026-benchmarks-owners>)
11. [Total cost of ownership of a one-gigawatt AI data center | Epoch AI](<https://epoch.ai/data-insights/ai-datacenter-cost-breakdown>)
12. [GB200 NVL72 Guide: Rack Specs, Cloud Price From ~\$10.50/hr | Spheron Blog](<https://www.spheron.network/blog/nvidia-gb200-nvl72-guide/>)
13. [Myths vs. Reality: Data Centers And Water Usage - Florida Water and Pollution Control Operators Association](https://www.fwpcoa.org/content.aspx?page_id=5&club_id=859275&item_id=130961)

~openai/gpt-latest



Technical Due Diligence Memorandum

50 MW Critical-IT AI Data Center Retrofit — NVIDIA GB200 NVL72 / D2C Liquid Cooling / ZLD

Basis date: 15 July 2026

Estimate class: Phase 0 / AACE Class 4; expected accuracy approximately **–20%/+30%** until utility, climate, OEM thermal envelope, structural survey, and redundancy basis are fixed.

Currency: 2026 USD, excluding financing, taxes, escalation beyond notice to proceed, tenant IT hardware, and GPUs.

1. Executive technical conclusion

Item	Due-diligence conclusion
50 MW critical IT	Technically feasible, subject to utility capacity and retrofit structural/electrical validation. “Critical IT” must include compute, storage and network loads—not GPUs alone.
GB200 density	Use approximately 120 kW/rack as the current documented planning value; 132 kW/rack should be treated as a conservative design envelope pending final OEM SKU and power profile. NVIDIA documents approximately 120 kW/rack and liquid-cooled CPU/GPU cold plates, with other components remaining air cooled [NVIDIA DGX GB Rack Guide](https://docs.nvidia.com/dgx/dgxgb200-user-guide/hardware.html).
Rack count	Mathematical range is 379 racks at 132 kW to 417 racks at 120 kW if the full 50 MW were all NVL72 racks. Actual count is more likely 360–400 , because network, storage, management and support IT consume part of the 50 MW denominator.
PUE <1.15	Achievable but aspirational , particularly for a retrofit and in a hot climate. Base design ledger is 57.0 MW total facility / 50.0 MW IT = 1.140 PUE , leaving only 0.5 MW before reaching 1.15. It requires warm-water operation, high liquid heat capture, efficient electrical topology and limited compressor cooling.
ZLD	Feasible as zero routine liquid process discharge . ZLD does not mean zero water consumption. Dry coolers can provide near-zero on-site evaporative WUE; adiabatic assistance remains ZLD if no liquid effluent is discharged, but it consumes water through evaporation.
Cooling medium	NVIDIA reference architecture is single-phase, water-based direct-to-chip cooling through cold plates , not dielectric immersion. Glycol may be used in the outdoor facility loop for freeze protection, but coolant chemistry and concentration must follow the OEM/CDU material-compatibility schedule.



Item	Due-diligence conclusion
\$550 million pre-GPU	Equivalent to \$11.0 million/MW of critical IT . This is credible but at the high end for a retrofit with substantial utility, high-density electrical and liquid-cooling work. It is not automatically sufficient for an expensive 2N topology, dedicated utility transmission works, major seismic reinforcement, or schedule acceleration. Turner & Townsend reports a 7–10% US premium for liquid-cooled versus comparable air-cooled facilities and a liquid-cooled cost distribution weighted toward mechanical and electrical systems [Turner & Townsend 2025](https://reports.turnerandtownsend.com/data-centre-construction-cost-index-2025/data-centre-cost-trends) .
Principal investment risks	Utility interconnection, dry-bulb climate, final NVIDIA coolant envelope, existing slab/roof loading, electrical short-circuit duty, transformer/switchgear lead times, acoustic/air permitting for generators and dry coolers, and ambiguity over “ZLD” versus “zero water use.”

Task 1 — Thermodynamic and power ledger

2. Design basis

2.1 IT and rack basis

Parameter	Underwriting basis
Critical IT load at rack/PDU output	50.0 MW
GB200 NVL72 operating rack load	120–132 kW/rack
Pure mathematical rack count	$50,000/132 = 379$; $50,000/120 = 417$
Recommended white-space design envelope	400 rack positions at 132 kW , but not all simultaneously populated at that maximum
Likely NVL72 count after network/storage allowance	Approximately 360–400 , tenant architecture dependent
Annual IT energy at continuous 50 MW	$50,000 \text{ kW} \times 8,760 \text{ h} = \mathbf{438,000,000 \text{ kWh/year}}$
Liquid capture assumption	85–90% of IT heat
Residual air-cooled heat	10–15% , including power shelves, networking, storage and room gains
Ultimate site heat rejection duty	Approximately 57 MW operating , with equipment selected for design ambient, fouling, degradation and redundancy

NVIDIA states that the CPU/GPU compute trays are cooled by liquid through manifolds and cold plates, while networking, storage and other components remain air cooled. NVIDIA also describes approximately 120 kW rack consumption and redundant power shelves [NVIDIA DGX GB Rack Guide](<https://docs.nvidia.com/dgx/dgxgb200-user-guide/hardware.html>). The **132 kW figure is therefore a prudent**



electrical/thermal envelope, not a substantiated claim that every GB200 rack continuously draws exactly 132 kW.

3. PUE ledger

PUE is total facility energy divided by IT equipment energy; IT includes compute, storage and network equipment, while facility energy includes electrical losses, cooling and miscellaneous support loads [LBNL/The Green Grid PUE guidance](https://datacenters.lbl.gov/sites/default/files/WP49-PUE%20A%20Comprehensive%20Examination%20of%20the%20Metric_v6.pdf).

3.1 Full-load annual operating target

Load category	MW	% of IT	Included equipment
Critical IT	50.00	100.0%	GB200 racks, network, storage and in-room IT management equipment
D2C liquid-loop cooling	1.55	3.1%	Technology cooling-system pumps, CDUs, facility-loop pumps and heat-exchanger pressure loss
Dry-cooler fans	1.25	2.5%	EC/VFD condenser or fluid-cooler fans at annual weighted condition
Residual-air cooling and trim	1.10	2.2%	CRAHs/fan walls for non-liquid-cooled load; limited trim refrigeration allowance
Cooling subtotal	3.90	7.8%	
Electrical conversion/distribution losses	2.35	4.7%	Transformers, UPS, MV/LV distribution, busway and conductors, measured outside IT boundary
Facility ancillary	0.75	1.5%	BMS/SCADA, security, lighting, fire systems, controls, offices and normal battery conditioning
Facility/ancillary subtotal	3.10	6.2%	
Total non-IT	7.00	14.0%	
Total facility input	57.00 MW	—	

$$PUE = \frac{57.00}{50.00} = \mathbf{1.140}$$

$$\text{Maximum facility input at PUE 1.15} = 50.00 \times 1.15 = \mathbf{57.50 \text{ MW}}$$

Operating margin: only **0.50 MW** between the base ledger and the 1.15 threshold.

3.2 Assessment

- **1.140 annualized PUE: Aspirational but plausible.**
- **<1.15 at every 15-minute interval, all loads and maximum summer ambient:** not bankable without climate-specific simulation and likely compressor or adiabatic support.
- **Industry-standard contractual formulation:** annual metered PUE at defined IT utilization and weather normalization, with separate peak summer power and cooling-capacity guarantees.
- PUE must be measured at the utility/site boundary and IT distribution boundary, continuously and annualized. It cannot be demonstrated merely from equipment nameplate efficiencies.
- At low tenant utilization, fixed pumps, controls, air handlers and electrical losses will increase PUE. The guarantee should specify a utilization band, for example **70–100% of commissioned IT load**.
- Generator testing fuel and BESS charge/discharge losses require an agreed PUE accounting treatment.

3.3 Required efficiency conditions

1. UPS operating efficiency approximately **97.5–98.5%** at the relevant loading.
2. High-efficiency transformers and short high-voltage distribution paths.
3. Medium-voltage distribution brought close to white space; avoid serial conversion stages.
4. D2C liquid capture of at least **85%**, preferably approximately 90%.
5. Variable-flow pumping with low-pressure-drop manifolds and properly sized pipework.
6. Dry-cooler operation at elevated facility-water temperature wherever the OEM envelope permits.
7. Residual air cooling based on contained recirculation/fan-wall systems, not conventional low-density CRAC layouts.
8. No continuous chiller operation in the annual base case.
9. SCADA-based rack power capping and thermal optimization.

4. Cooling architecture

4.1 Correct technology classification

Technology	Fluid at electronics	Heat-transfer mode	GB200 reference architecture?
D2C cold plates	Treated water-based coolant; glycol only as approved/required	Single-phase sensible heat	Yes
Single-phase immersion	Dielectric hydrocarbon/synthetic fluid	Components immersed in dielectric bath	No
Two-phase immersion	Dielectric fluid boiling at components	Latent heat/phase change	No
Refrigerant two-phase cold plate	Dielectric refrigerant in sealed cold plate	Phase change	Not the standard GB200 D2C water architecture



The project should not describe water-cooled cold plates as “dielectric liquid cooling.” That would be a material technical misrepresentation. Conversion to immersion would require an alternate server/rack architecture, component compatibility qualification, service model, fire/environmental review and likely loss of the reference OEM configuration.

4.2 Recommended closed-loop arrangement

Rack/TCS loop → CDU plate heat exchanger → facility water loop → dry coolers → ambient

1. Technology Cooling System, rack side

- OEM-approved treated water coolant.
- Rack manifolds, dripless quick-disconnects and CPU/GPU cold plates.
- Conductivity, pH, inhibitor, dissolved oxygen and particulate limits per final NVIDIA/CDU specification.
- Redundant leak-detection cable and point sensors.
- Filtration, expansion tank, air separation, fill and sampling ports.
- Avoid assuming deionized water alone: untreated DI water may become corrosive and is not a substitute for an approved inhibited coolant formulation.

2. CDUs

- Physically separate sensitive technology coolant from the outdoor facility-water loop.
- N+1 pumps and controls within each cooling block.
- Dual power sources and ride-through controls.
- Meter supply/return temperatures, flow, pressure, thermal duty and water quality.
- Automatic isolation by rack/row without draining an entire hall.

3. Facility water system

- Closed loop, preferably modular by data hall.
- Water/inhibited propylene glycol where freeze conditions require it.
- Glycol concentration should be the minimum required by design freeze temperature: excess glycol raises viscosity, pump energy and heat-exchanger approach.
- Plate-and-frame heat exchangers, side-stream filtration, air/dirt separation and corrosion monitoring.
- N+1 or block-redundant pump topology.

4. Heat rejection

- Air-cooled dry coolers with VFD/EC fans.
- N+1 cells and isolation valves; design for coil fouling, fan degradation and recirculation.
- Optional adiabatic pre-cooling only under defined high-ambient conditions.
- Any trim chiller should be a peak-condition/resilience device, not the annual base cooling mode if PUE <1.15 is to be maintained.

5. Residual air system

- GB200 racks are not 100% liquid cooled.
- Provide fan-wall/CRAH capacity for power supplies, networking, storage and room gains.
- Maintain humidity/dew-point control to prevent condensation at cold plates and manifolds.
- CDU supply-temperature reset must remain above the applicable room dew point with safety margin.



4.3 Thermodynamic sizing

At steady full load, almost all incoming electrical power becomes heat. The site must therefore reject approximately:

$$Q_{\text{reject}} \approx 50.0 \text{ MW}_{\text{IT}} + 7.0 \text{ MW}_{\text{facility}} = \mathbf{57.0 \text{ MW}_{\text{thermal}}}$$

For a water loop:

$$\dot{m} = \frac{Q}{c_p \Delta T}$$

Illustrative flow at a **10°C facility-water ΔT** :

$$\dot{m} = \frac{57,000 \text{ kW}}{4.186 \text{ kJ/kgK} \times 10\text{K}} = 1,362 \text{ kg/s} \approx \mathbf{1,362 \text{ L/s}}$$

At a **15°C ΔT** , the corresponding flow is approximately **908 L/s**. These are campus-level flows and require sectionalized distribution; they should not be imposed on one common header without hydraulic and failure-domain analysis.

If 88% of the 50 MW IT load is captured by D2C:

- D2C IT heat: **44 MW**
- Residual IT heat: **6 MW**
- Additional facility heat: distributed between electrical rooms, mechanical plant and outdoors
- Residual-air cooling plant should therefore be sized from the actual OEM/rack heat split, not from an assumption that liquid cooling removes all rack heat.

4.4 Climate limitation

A dry cooler can only deliver fluid above outdoor dry-bulb temperature plus coil approach. If the OEM requires approximately 20–25°C supply water, a dry cooler cannot provide that temperature during a 35–45°C ambient condition.

The project must therefore resolve one of four strategies:

1. **Select a cool climate** with sufficient annual and extreme dry-bulb margin.
2. **Obtain an OEM-approved elevated coolant envelope** allowing warm-water operation.
3. **Use adiabatic assist** during hot hours.
4. **Install trim mechanical cooling**, accepting PUE and capital penalties.

Accordingly, “dry cooler only + PUE 1.14 + any climate” is **not bankable**. A bin-hour energy model using ASHRAE weather data and final OEM supply/return limits is a condition precedent.

5. ZLD and water ledger

5.1 Terminology

- **ZLD**: no routine liquid process effluent leaves the site; recoverable water is recycled and residual contaminants ultimately leave as solids.



- **Zero evaporative water:** no water is consumed by cooling evaporation.
- These are not equivalent. A dry loop can satisfy both, apart from maintenance losses. An adiabatic system may satisfy ZLD while consuming water through evaporation.
- Conventional crystallizer-based ZLD can be energy-intensive; the preferred design avoids creating a continuous blowdown stream in the first place. ZLD processes generally recover water and leave solid salt residue for disposal [US Bureau of Reclamation](https://www.usbr.gov/lc/socal/reports/brineconcentrate/6TreatmentandDisposal_part2.pdf).

5.2 Annual water comparison

Annual 50 MW IT energy:

$$50,000 \text{ kW} \times 8,760 \text{ h} = 438,000 \text{ kWh}$$

Using the requested traditional evaporative benchmark:

Cooling case	Site WUE	Annual water	Average daily water
Traditional evaporative, lower benchmark	1.8 L/kWh	788.4 million L/year	2.16 million L/day
Traditional evaporative, upper benchmark	2.2 L/kWh	963.6 million L/year	2.64 million L/day
Closed-loop D2C + dry coolers	Nominally ~0 L/kWh evaporative	Routine evaporation approximately zero	Initial fill and maintenance only
Dry coolers with limited adiabatic assist	Climate/control dependent	Must be modeled	Non-zero

An industry overview identifies approximately **1.8 L/kWh** as an average WUE benchmark, though actual tower WUE varies materially by climate, cycles of concentration and system boundary [Data Center Knowledge](https://www.datacenterknowledge.com/cooling/a-guide-to-data-center-water-usage-effectiveness-wue-and-best-practices).

5.3 Dry-system practical water use

A dry system is not literally water-free:

- Initial technology/facility-loop fill.
- Flushing and commissioning.
- Sampling, filter replacement and maintenance drain-down.
- Accidental leakage.
- Humidification, if used.
- Domestic, cleaning, landscaping and fire-system test water.
- Potential water embedded in grid electricity, which is outside on-site WUE.

A reasonable operating objective is:

- **Cooling evaporative WUE:** approximately **0 L/kWh**
- **Total on-site process WUE:** **≤0.02 L/kWh**, subject to the agreed boundary
- **No routine cooling-loop blowdown**



- **100% metering of municipal/reclaimed-water imports**
- **No unpermitted liquid process discharge**

At 0.02 L/kWh, annual on-site process water would still be:

$$438,000,000 \times 0.02 = \mathbf{8.76 \text{ million L/year}}$$

Therefore, “approximately zero” must not be represented as mathematically zero.

5.4 Adiabatic-assist sensitivity

The theoretical evaporation to reject one kWh of heat is approximately:

$$\frac{3,600 \text{ kJ}}{2,450 \text{ kJ/kg}} \approx 1.47 \text{ L/kWh}_{\text{thermal}}$$

Illustrative case: 20 MW of effective evaporative assistance for 500 hot hours:

$$20,000 \text{ kW} \times 500 \text{ h} \times 1.47 \text{ L/kWh} \\ = \mathbf{14.7 \text{ million L/year}}$$

Relative to annual IT energy:

$$WUE = \frac{14.7 \text{ mL}}{438 \text{ kWh}} = \mathbf{0.034 \text{ L/kWh}}$$

Allowing for purge, pad flushing and inefficiency could increase this to approximately **0.04–0.06 L/kWh**. This remains far below 1.8–2.2 L/kWh, but it is **not zero-water cooling**.

5.5 ZLD process treatment

For a dry-loop design, full-scale brine evaporators/crystallizers should not be installed without a demonstrated waste stream. Preferred hierarchy:

1. Closed loops with no routine blowdown.
2. Capture maintenance drain-down in a segregated tank.
3. Test and reclaim coolant where possible.
4. Send unrecoverable glycol/inhibited coolant off-site through a licensed waste contractor.
5. For adiabatic systems, use controlled water quality and avoid liquid carryover; collect cleaning/purge water.
6. If permit language requires literal on-site ZLD for all process liquids, provide a small packaged membrane/concentrator or contract evaporation system based on quantified wastewater—not a nominal “ZLD skid” without mass balance.

Task 2 — Pre-GPU capital expenditure

6. Phase 0 capital plan



6.1 \$550 million base estimate

EPC category	\$M	\$M per critical MW	Scope
Land and civil	30	0.60	Acquisition allowance, surveys, grading, drainage, roads, utility corridors, yards and landscaping
Core and shell / structural retrofit	60	1.20	Slab/roof reinforcement, equipment pads, envelope, white-space alteration, MEP rooms, loading/security areas
Substation and switchgear	105	2.10	Utility interface, transformers, HV/MV switchgear, protection, metering, duct banks and site distribution
Critical electrical distribution	105	2.10	UPS, batteries integral to UPS, PDU/RPP, 415/480 V distribution, busway, rack whips and grounding
Backup generation and BESS	75	1.50	Gensets, bulk fuel, emissions systems, paralleling gear and short-duration BESS/ride-through
ZLD/D2C thermal plant	75	1.50	CDUs, dry coolers, pumps, heat exchangers, closed-loop piping, residual air cooling, leak detection and water treatment
Controls, fire/life safety and security	20	0.40	SCADA/BMS/EPMS/DCIM interfaces, fire detection/suppression, access control, CCTV and telecom pathways
Design, EPC preliminaries, commissioning and contingency	80	1.60	Engineering, permits, PM/CM, temporary works, testing, integrated systems testing and Phase 0 contingency
Total pre-GPU	550	11.00/MW	

6.2 Scope boundary

Included: facility-side infrastructure through rack electrical and liquid connection points, retrofit construction, controls and commissioning.

Excluded unless specifically added:

- GB200 NVL72 racks, GPUs, CPUs and OEM power shelves supplied as IT.
- Tenant network switches, optics, storage and structured fiber.
- Utility network reinforcement beyond the project substation.
- Extraordinary land premiums or environmental remediation.



- Financing, interest during construction and taxes.
- Long-duration energy storage.
- Major transmission line or generation-plant construction.
- Schedule premiums for air freight, expediting or contractor stacking.

6.3 Benchmark interpretation

At **\$11 million/MW**, the budget is:

- High relative to conventional hyperscale capacity.
- Plausible for a high-density AI retrofit with substantial electrical replacement.
- Potentially low for 2N electrical/mechanical redundancy, severe seismic reinforcement, a new transmission-class substation, high-cost metropolitan labor, or a hard accelerated completion date.
- Potentially high for an existing building with reusable utility, shell and electrical assets in a low-cost market.

Turner & Townsend's US data indicates a 7–10% liquid-cooling premium and a liquid-cooled cost mix of approximately **33% mechanical, 48% electrical, 9% core/shell and 10% general conditions**, although project inclusions differ [Turner & Townsend 2025](<https://reports.turnerandtowntsend.com/data-centre-construction-cost-index-2025/data-centre-cost-trends>). The present budget's electrical and mechanical concentration is directionally consistent.

6.4 Redundancy sensitivity

Design basis	Indicative effect
Distributed redundant / N+1 blocks	Base case; best fit for \$550M
2N critical electrical, N+1 mechanical	Add approximately \$60–120M , site dependent
2N electrical and 2N mechanical	Add approximately \$100–180M+
Utility substation already reusable	Potential reduction \$30–70M
New transmission line/utility network upgrades	Potential addition \$50–200M+
Major structural/seismic retrofit	Potential addition \$20–80M
Schedule compression/early procurement	Typically 5–15% premium

BESS should be treated as:

- UPS/generator-start ride-through;
- power-quality and controlled load-ramp support;
- potentially short-duration peak support.

It should **not** be represented as multi-hour replacement for approximately 50–57 MW of site load unless several hundred MWh of storage is separately funded.

7. Retrofit-specific technical diligence



Before investment committee approval, complete:

1. Structural

- Slab point load, rolling load and punching shear.
- Rack anchorage and seismic bracing.
- Roof loading for dry coolers, acoustic screens and pipework.
- Equipment delivery route, freight elevator and door clearances.
- Dynamic/vibration review for pumps and rotating equipment.

2. Electrical

- Utility firm-capacity letter and interconnection study.
- Existing transformer remaining life and dissolved-gas analysis.
- Arc-flash, protection coordination and short-circuit withstand.
- Harmonic study for UPS, power shelves and VFDs.
- Grounding, neutral loading and fault-current path.
- Busway thermal rating at actual ambient and high-density loading.

3. Mechanical

- Climate bin-hour model and extreme dry-bulb condition.
- CFD for dry-cooler air recirculation and residual white-space airflow.
- Final OEM coolant chemistry, temperature, flow and pressure-drop limits.
- Water-hammer/transient analysis.
- Leak consequence and isolation-zone study.
- Dew-point and condensation analysis.

4. Environmental/permitting

- Generator emissions and operating-hour constraints.
- Noise at site boundary.
- Glycol and chemical storage.
- Stormwater segregation from process-liquid containment.
- Waste-coolant classification and disposal route.
- Explicit municipal acceptance of the proposed ZLD boundary.

Task 3 — Phase 0 consortium

8. Partner profiles and responsibilities

8.1 Tier-1 EPC firm

Required profile

- Demonstrated delivery of at least 30–100 MW data-center campuses.



- Relevant high-density D2C liquid-cooling experience.
- Self-perform or tightly controlled HV/MV, controls and commissioning capability.
- Licensed engineering responsibility in the project jurisdiction.
- OEM integration experience with NVIDIA platform providers, CDU suppliers, UPS vendors and dry-cooler manufacturers.

Phase 0 responsibilities

Workstream	Deliverable
Structural validation	Laser survey; record-document reconciliation; destructive testing where required; rack/slab/roof/equipment-path calculations; reinforcement concept and cost
Electrical basis	Utility one-line, load flow, short circuit, protection, harmonics, grounding, selective coordination and redundancy matrix
Thermal basis	Hourly energy/water model, D2C heat split, hydraulic model, dry-cooler selection and peak-condition strategy
Constructability	Phasing, shutdown plan, temporary cooling/power, logistics and live-site safety plan
SCADA/BMS/EPMS integration	Point list, protocols, sequence of operation, alarm rationalization, historian, cyber zoning and tenant API interface
Commissioning	Factory witness tests, pre-functional checklists, load-bank plan, integrated systems testing and failure-mode demonstrations
Commercial	Open-book estimate, procurement schedule, long-lead register, risk allowance and guaranteed-maximum-price conversion plan

SCADA/BMS minimum integration

- Utility and generator power.
- UPS/PDU/rack-level power.
- CDU flow, pressure, temperature and thermal load.
- Coolant quality and leak alarms.
- Dry-cooler fan speed and ambient conditions.
- Adiabatic water use, if installed.
- Municipal import and discharge meters.
- PUE and WUE calculations with auditable meter boundaries.
- Northbound interface to DCIM/NVIDIA Mission Control. NVIDIA notes that Mission Control can integrate facility power, cooling and leakage telemetry [NVIDIA DGX Guide](<https://docs.nvidia.com/dgx/dgxgb200-user-guide/software.html>).
- Role-based access, network segmentation, time synchronization and immutable event logs.

8.2 Municipal Water Authority

Required profile

- Legal authority over potable/reclaimed supply, industrial pretreatment and sewer discharge.



- Ability to approve water balance, backflow protection, telemetry and emergency discharge arrangements.

Responsibilities

1. Approve the project water mass balance and the definition of ZLD.
2. Confirm whether sanitary wastewater is outside the industrial ZLD boundary.
3. Approve:
 - service size;
 - backflow prevention;
 - initial fill rate;
 - adiabatic-assist allowance;
 - emergency drain/storage arrangements;
 - coolant/waste haul-off protocol.
4. Receive real-time or periodic telemetry:
 - municipal water import;
 - reclaimed-water import;
 - adiabatic use;
 - process drain-tank level;
 - any permitted discharge volume and quality.
5. Sign off on commissioning fill/flushing plan.
6. Define exceedance notification and sampling requirements.

A genuinely dry, closed-loop design with no routine blowdown and near-zero evaporative consumption materially strengthens the permit case in a water-stressed municipality. However, the authority should not be asked to endorse “zero water use” if domestic use, commissioning fill, leakage or adiabatic operation remains.

8.3 Compute operator / hyperscaler tenant

Required contributions

Area	Tenant-provided information or obligation
IT schedule	Final NVL72 SKU, rack quantity, deployment phases and maximum rack power
Power profile	Idle, average, peak, ramp rate, power capping and workload diversity
Thermal envelope	OEM-approved supply/return temperature, flow, pressure drop, coolant chemistry and liquid-capture fraction
Network/storage	Rack count, power, residual heat, topology, optics and cabling requirements
Availability	Required redundancy, maintenance concurrency and recovery-time objectives
Software integration	Mission Control/DCIM interfaces, telemetry points, alarm ownership and API requirements



Area	Tenant-provided information or obligation
Commissioning	Synthetic load, NCCL/workload burn-in, thermal soak and controlled failure participation
Operations	Firmware controls, power caps, maintenance windows and spare-rack strategy
Compliance	Security, export controls, environmental reporting and occupational-safety requirements

8.4 Tenant compliance metrics

Metric	Proposed requirement
Critical IT load	≤50.0 MW at agreed meter boundary
Rack demand	≤contracted rack envelope; excursions logged
Power ramp	Within utility/generator/BESS-approved MW/minute limit
Annual PUE	≤ 1.15 , aspirational target 1.14 , defined utilization and weather basis
Peak facility demand	≤57.5 MW unless separately contracted
Cooling WUE, dry mode	Approximately zero evaporative cooling water
Annual process WUE	Target ≤ 0.02 L/kWh without adiabatic assist
ZLD	No routine liquid process discharge
Coolant availability	Within OEM temperature, flow, pressure and chemistry envelope
Leakage	Zero uncontrolled release; alarm/isolation response demonstrated
Thermal throttling	No facility-caused throttling during commissioned design condition
Energy telemetry	Revenue-grade or agreed accuracy, synchronized at ≤15-minute intervals
Availability	Based on contracted block topology, not unqualified “Tier” language
Workload efficiency	GPU utilization and useful-compute metrics reported separately from PUE

9. Phase 0 conditions precedent

The project should not proceed to fixed-price EPC or final investment approval until the following are closed:

- 1. Firm utility service:** 57.5 MW minimum operating import, plus agreed margin and expansion; fault-duty and energization date confirmed.
- 2. Final rack/OEM data:** coolant, pressure, temperature, flow, chemistry and power profiles issued by the selected OEM/integrator.
- 3. Climate model:** hourly PUE/WUE simulation showing compliance under design and typical meteorological years.

4. **Structural report:** all rack, roof, pipe, transformer and generator loads accepted by the engineer of record.
5. **Redundancy basis:** N, N+1, distributed redundant or 2N fixed by failure domain.
6. **ZLD permit memorandum:** signed water balance and waste-handling path.
7. **Electrical reuse assessment:** existing assets categorized as retain, refurbish or replace.
8. **Long-lead commitments:** transformers, MV switchgear, generators, UPS, CDUs and dry coolers.
9. **Integrated controls specification:** BMS/SCADA/EPMS/DCIM/Mission Control ownership and cybersecurity.
10. **Guaranteed metrics:** PUE, WUE, IT capacity, thermal capacity, availability and noise/emissions tested under an agreed measurement and verification protocol.

10. Final investment view

Proceed conditionally. The concept is technically coherent if it is framed as:

- **50 MW total critical IT**, not 50 MW of GPUs plus uncounted network/storage;
- **water-based, single-phase D2C cold plates**, not dielectric immersion;
- **closed facility loops with dry heat rejection**;
- **ZLD meaning zero routine liquid process discharge**;
- **near-zero—not absolute-zero—on-site evaporative WUE in dry mode**;
- **annual PUE approximately 1.14**, with climate and utilization qualifications;
- **\$550 million pre-GPU**, subject to utility and redundancy scope.

The highest-risk combined claim is **PUE <1.15, dry-cooler-only operation, 20–25°C coolant supply and unrestricted hot-climate siting**. Those conditions are not simultaneously credible without an approved warmer coolant envelope, adiabatic assistance or mechanical trim cooling. The climate/OEM thermal study is therefore the principal technical gating item.

References

1. [Hardware — NVIDIA DGX GB Rack Scale Systems User Guide](<https://docs.nvidia.com/dgx/dgxgb200-user-guide/hardware.html>)
2. [PDF NVIDIA DGX GB Rack Scale Systems User Guide](<https://docs.nvidia.com/dgx/dgxgb200-user-guide/dgxgb200-user-guide.pdf>)
3. [GB200 NVL72 | NVIDIA](<https://www.nvidia.com/en-us/data-center/gb200-nvl72/>)
4. [GB200 NVL72 Deployment | Introl Blog](<https://introl.com/blog/gb200-nvl72-deployment-72-gpu-liquid-cooled>)
5. [GB200 NVL72 Installation Checklist — 2,000-Cable Rack, Step by Step | Leviathan Systems](<https://www.leviathansystems.co/guides/gb200-nvl72-installation-checklist>)
6. [A Guide to Data Center Water Usage Effectiveness (WUE) and Best ...](<https://www.datacenterknowledge.com/cooling/a-guide-to-data-center-water-usage-effectiveness-wue-and-best-practices>)
7. [How do data centers use and manage water? - TechTarget](<https://www.techtarget.com/searchdatacenter/tip/How-to-manage-data-center-water-usage-sustainably>)
8. [Data Centre Water Usage Effectiveness (WUE): Cooling Tower vs Adiabatic vs Dry Coolers | KVRM Engineering](<https://kvr.in/data-centre-wue-cooling-tower-adiabatic-dry-cooler/>)

9. [Data Center Water Usage Effectiveness – WUE - AKCP](https://www.akcp.com/2021/01/14/data-center-water-usage-effectiveness-wue/)
10. [Improving Data Center Water Efficiency via Online Resource ...](https://intra.ece.ucr.edu/~sren/project/water/)
11. [United States Data Center Construction Market Size, Forecast ...](https://www.mordorintelligence.com/industry-reports/united-states-data-center-construction-market)
12. [AI Data Center Construction Cost: The 2026 Capex Math Guide](https://savrn.com/ai-data-center-construction-cost/)
13. [Data centre construction cost index 2025 - Turner & Townsend](https://reports.turnerandtowntsend.com/data-centre-construction-cost-index-2025/data-centre-cost-trends)
14. [U.S. Data Center Development Cost Guide - Cushman & Wakefield](https://www.cushmanwakefield.com/en/united-states/insights/data-center-development-cost-guide)
15. [Data Center Construction Costs 2026: /MW, /sqft & Drivers](https://www.irecruit.co/insights/data-center-construction-cost-trends-2026)
16. [TGG Glossary | The Green Grid](https://www.thegreengrid.org/resources/glossary?combine=pue)
17. [PDF PUE™: A COMPREHENSIVE EXAMINATION OF THE METRIC](https://datacenters.lbl.gov/sites/default/files/WP49-PUE%20A%20Comprehensive%20Examination%20of%20the%20Metric_v6.pdf)
18. [Recommendations for Measuring and Reporting Overall Data Center Efficiency](https://www.energystar.gov/sites/default/files/Data_Center_Metrics_Task_Force_Recommendations_V2.pdf)
19. [Data Center Metering and Resource Guide](https://datacenters.lbl.gov/sites/default/files/DataCenterMeteringandResourceGuide_02072017.pdf)
20. [GREEN GRID DATA](https://aboutdc.ru/docs/aboutdc/4/White_Paper_PUE_DCiE_2008.pdf)
21. [PDF Low Temperature Crystallization Process is the Key to ZLD ... - US EPA](https://19january2017snapshot.epa.gov/www3/region1/npdes/merrimackstation/pdfs/ar/AR-145.pdf)
22. [Technical Development Document for Final Supplemental Effluent Limitations Guidelines and Standards for the Steam Electric Power Generating Point Source Category](https://www.epa.gov/system/files/documents/2024-04/se11757_steam-electric-elg-tdd_508.pdf)
23. [3 Zero Liquid Discharge](https://www.usbr.gov/lc/socal/reports/brineconcentrate/6TreatmentandDisposal_part2.pdf)
24. [Review Zero-liquid discharge (ZLD) technology for resource recovery from wastewater: A review](https://www.sciencedirect.com/science/article/abs/pii/S0048969719320741)
25. [The Global Rise of Zero Liquid Discharge for Wastewater ...](https://pubs.acs.org/doi/10.1021/acs.est.6b01000)
26. [NVIDIA DGX GB Rack Scale Systems User Guide — NVIDIA DGX GB Rack Scale Systems User Guide](https://docs.nvidia.com/dgx/dgxeb200-user-guide/)
27. [System Control and Configuration — NVIDIA DGX GB Rack Scale Systems User Guide](https://docs.nvidia.com/dgx/dgxeb200-user-guide/control-config.html)
28. [Software — NVIDIA DGX GB Rack Scale Systems User Guide](https://docs.nvidia.com/dgx/dgxeb200-user-guide/software.html)

Consensus

- Total facility power at PUE 1.15 = 57.5 MW (50 MW IT × 1.15); overhead budget is ~7.5 MW. All three derive PUE = total facility power / IT power and note the margin is extremely tight.
- GB200 NVL72 uses NVIDIA-reference single-phase water-based direct-to-chip (D2C) cold-plate cooling, NOT dielectric immersion; conflating the two would be a material technical misrepresentation/red flag.



- The GB200 NVL72 is not 100% liquid-cooled: ~85-90% of heat is captured by liquid cold plates while ~10-15% (networking, storage, PSUs, room gains) rejects to air and requires a discrete residual air-cooling loop (fan wall/CRAH/RDHx).
- ZLD means zero routine liquid process discharge (no blowdown), which is distinct from zero water consumption; the design is honestly 'near-zero evaporative consumption,' not literal zero.
- Traditional evaporative cooling towers run ~1.8-2.2 L/kWh WUE, and annual 50 MW IT energy = 438,000,000 kWh/yr, yielding roughly 788M-964M L/yr for evaporative baseline.
- Dry-cooler-only ZLD approaches ~0 L/kWh evaporative but carries a PUE/efficiency penalty in hot climates; adiabatic assist may be required and reintroduces some water consumption (roughly 0.05-0.20 L/kWh).
- PUE < 1.15 is achievable but aspirational, especially for a retrofit and in hot climates; it is conditional on cool/temperate siting, warm-water (elevated coolant supply) D2C operation, and limited/no continuous mechanical chiller trim.
- ~550M pre-GPU equals ~11M/MW critical IT, which is credible but on the high end of the pre-GPU band, driven primarily by power infrastructure (substation/switchgear/backup) and the liquid-cooling premium.
- A genuine near-zero-evaporative ZLD design materially strengthens the municipal water permit case in water-stressed regions.
- Rack math yields ~379 racks at 132 kW/rack basis (50,000/132).
- Tenant/hyperscaler provides the GB200 racks, CDUs, coolant, and network fabric, plus separate silicon CapEx (~\$1.1-1.3B), and must interface with facility BMS/SCADA.
- Tenant should enable software-based power capping / thermal throttling and the PUE SLA should be climate-normalized/annualized rather than a flat instantaneous number.
- Tier-1 EPC must validate slab/structural loading for heavy racks (raised floor disqualified at this density), deliver unified SCADA/BMS integration with mandatory leak detection, and run scripted commissioning/load-bank trials.
- Turner & Townsend liquid-cooling premium of ~7-10% over comparable air-cooled facilities is cited as a benchmark anchor for the thermal loop cost.

Contradictions

- **Base-case design PUE figure**
 - ~google/gemini-pro-latest: Total facility 57.40 MW → PUE 1.148
 - ~anthropic/claude-opus-latest: Total facility exactly 57.5 MW → PUE 1.150 (design point), with 1.12 as stretch
 - ~openai/gpt-latest: Total facility 57.0 MW → PUE 1.140, leaving only 0.5 MW margin to the 1.15 ceiling
- **Coolant chemistry specification**
 - ~google/gemini-pro-latest: Secondary loop uses PG25 (25% propylene glycol/water) or ultra-low conductivity treated water
 - ~anthropic/claude-opus-latest: 50/50 EGW (ethylene glycol/water) per ASHRAE W55 water quality standard
 - ~openai/gpt-latest: OEM-approved treated water-based coolant; glycol only in outdoor facility loop for freeze protection at minimum required concentration; warns untreated DI water can be corrosive
- **Rack power planning value**
 - ~google/gemini-pro-latest: Uses 120-132 kW, cites ~416 racks (120 kW basis) as the deployment count
 - ~anthropic/claude-opus-latest: Uses 132 kW as primary basis → ~379 racks, 115 kW liquid / 17 kW air split
 - ~openai/gpt-latest: Recommends ~120 kW as documented NVIDIA planning value; treats 132 kW as conservative envelope, not substantiated continuous draw; count ~360-400
- **Whether 50 MW 'critical IT' is all GB200 racks**
 - ~google/gemini-pro-latest: Implies ~416 NVL72 racks make up the load (no explicit carve-out for network/storage)



- ~anthropic/claude-opus-latest: ~379 NVL72 racks, treats IT largely as rack load
- ~openai/gpt-latest: Explicitly warns 50 MW critical IT must include network/storage/management, so actual NVL72 count is lower (~360-400), not 50 MW of pure GPU racks
- **Substation & Switchgear CapEx allocation**
- ~google/gemini-pro-latest: *135M substation/switchgear* + 160M backup (gensets+BESS); total power-chain heavy
- ~anthropic/claude-opus-latest: *175M substation/switchgear (largest line, 32%)* + 120M backup; power train = 54% of budget
- ~openai/gpt-latest: Splits into *105M substation* + 105M critical electrical distribution + \$75M backup; treats electrical distribution as separate itemized line
- **Land & Civil cost**
- ~google/gemini-pro-latest: *15M* (0.3M/MW), site acquisition assumed inherited
- ~anthropic/claude-opus-latest: *40M* (0.80M/MW)
- ~openai/gpt-latest: *30M* (0.60M/MW), acquisition allowance included

Partial coverage

- ~openai/gpt-latest: Assigns an explicit estimate class (AACE Class 4, -20%/+30% accuracy) and lists formal conditions precedent before FID/fixed-price EPC conversion.
- ~openai/gpt-latest: Provides explicit thermodynamic heat-rejection sizing: $Q \approx 57$ MW thermal, mass-flow calc (~1,362 L/s at 10°C ΔT , ~908 L/s at 15°C ΔT), and the theoretical evaporation basis (~1.47 L/kWh_{thermal}, 3600 kJ / 2450 kJ/kg latent heat).
- ~openai/gpt-latest: Provides a redundancy sensitivity table quantifying CapEx deltas (2N electrical +60-120M, 2N+2N +100-180M, reusable substation -30-70M, transmission upgrades +50-200M).
- ~openai/gpt-latest: Explicitly warns BESS should not be represented as multi-hour full-site backup unless several hundred MWh is separately funded; treats it as ride-through/power-quality/load-ramp support.
- ~openai/gpt-latest: Notes dew-point/condensation control requirement: CDU supply-temperature reset must stay above room dew point to prevent condensation on cold plates/manifolds.
- ~openai/gpt-latest: Cites LBNL/Green Grid PUE measurement guidance and stresses PUE must be metered at defined boundaries, weather/utilization-normalized, with genset test fuel and BESS losses accounted for.
- ~openai/gpt-latest, ~anthropic/claude-opus-latest: Both flag low-utilization PUE degradation and recommend a defined utilization band (e.g. 70-100% of commissioned load) for the guarantee.
- ~anthropic/claude-opus-latest, ~openai/gpt-latest: Both cite the warm-water (W40-W45 / elevated coolant supply) envelope as the single most important lever to reconcile ZLD with PUE < 1.15.
- ~anthropic/claude-opus-latest: Cites Microsoft fleet WUE data (2.3→0.27 L/kWh, Arizona 1.52 vs Singapore 0.02) and Microsoft's closed-loop zero-water-evaporated cooling as industry-proven evidence, plus explicit statement that replacing evaporative with mechanical cooling raises PUE.
- ~anthropic/claude-opus-latest: Provides a consolidated risk register with severity ratings and a formal 'CONDITIONAL PASS' verdict tied to four conditions.
- ~anthropic/claude-opus-latest, ~openai/gpt-latest: Both flag transformer/switchgear procurement lead time (80-130+ weeks) as the binding schedule constraint, not just cost, and recommend owner-furnished long-lead procurement at Phase 0.
- ~anthropic/claude-opus-latest: Cites CFD flow-distribution validation requirement ($\pm 5\%$ flow rate per branch) and CDU capacity (150-200 kW per unit, ~300-380 units N+1) as EPC warranty items.
- ~anthropic/claude-opus-latest: Notes early GB200 rack reliability as a real operational caveat and GPU refresh cycle (5-6 yr) mismatch against facility life.



- ~google/gemini-pro-latest: Quantifies interior network fabric scale (~150 miles of inter-rack copper/fiber cabling) as tenant scope.
- ~google/gemini-pro-latest: Emphasizes AI 'step-load' di/dt transient drops during training as a specific driver for BESS/UPS design and CapEx premium.
- ~google/gemini-pro-latest, ~anthropic/claude-opus-latest: Name specific candidate Tier-1 EPC firms (Gemini: Mortenson, DPR, Holder) or specific hyperscaler tenants (Gemini: Microsoft, CoreWeave, Meta).
- ~google/gemini-pro-latest: Rejects two-phase dielectric immersion specifically on PFAS/GWP regulatory phase-out and ~\$200+/liter fluid cost grounds.
- ~openai/gpt-latest: Details a full ZLD waste-treatment hierarchy (segregated drain tanks, coolant reclaim, licensed off-site haul-off of glycol) and warns against installing crystallizer/brine ZLD skids without a demonstrated waste stream/mass balance.
- ~openai/gpt-latest: Lists environmental/permitting diligence beyond water: generator emissions, boundary noise from gensets and dry coolers, glycol/chemical storage, stormwater segregation, waste-coolant classification.
- ~anthropic/claude-opus-latest, ~openai/gpt-latest: Both cite the JLL/benchmark data that shell-and-core cost (~10.7-11.3M/MW) *excludes AI tech fit-out (up to ~25M/MW)*, reconciling why pre-GPU \$11M/MW is coherent.

Unique insights

- ~openai/gpt-latest: Reframes the fundamental scoping error: 50 MW 'critical IT' cannot be treated as 50 MW of pure GPU racks — network/storage/management consume part of the denominator, so NVL72 count is genuinely lower and this affects both rack math and residual-air heat sizing.
- ~openai/gpt-latest: Provides the actual heat-rejection thermodynamics (mass-flow rate, ΔT sensitivity, latent-heat basis for adiabatic evaporation) rather than only power accounting, grounding the water and pumping numbers in first principles.
- ~openai/gpt-latest: Warns against installing a 'ZLD skid'/crystallizer without a quantified waste stream — conventional ZLD crystallizers are energy-intensive and the better design simply avoids creating a blowdown stream, so literal-ZLD permit language could force unnecessary energy-intensive equipment.
- ~anthropic/claude-opus-latest: Grounds the ZLD-vs-PUE trade-off in real fleet operator data (Microsoft: WUE fell 2.3→0.27 L/kWh; Arizona 1.52 vs Singapore 0.02), demonstrating empirically that climate, not just design, dictates whether you get near-zero WUE and sub-1.15 PUE together.
- ~anthropic/claude-opus-latest: Frames the core DD ruling crisply: 'you can have near-zero WUE OR sub-1.15 PUE cheaply — in a hot climate you may not get both,' and recommends re-underwriting a hot-dry site at PUE 1.18-1.20 OR WUE 0.15-0.20.
- ~anthropic/claude-opus-latest: Includes a 1.30 MW explicit 'reserve/commissioning margin' line as an honesty buffer and identifies it as the first casualty if a hot climate forces mechanical trim, making the PUE-drift mechanism transparent.
- ~google/gemini-pro-latest: Highlights AI training 'step-load' di/dt transients as a distinct electrical design challenge requiring BESS buffering to avoid dropping grid sync — a compute-workload-specific electrical stability issue the others underweight.
- ~google/gemini-pro-latest: Flags supply-chain constraints on high-amp switchgear and CDUs as adding 12-18 months of schedule risk that is unrepresented in the dollar cost figures.

Blind spots

- None of the models addressed grid interconnection availability/timeline in depth as the true gating item — securing 57.5+ MW of firm utility capacity in constrained markets (queue delays of multiple years) can dominate the entire project schedule and was only lightly touched (GPT lists it as a condition precedent but without market-specific queue timelines).



- No model quantified the heat-reuse / waste-heat recovery opportunity (district heating, adjacent industrial offtake), which is increasingly relevant to permitting and ESG scoring for warm-water D2C systems that reject at 45°C+.
- Carbon/energy-source considerations (grid carbon intensity, on-site generation emissions, embodied carbon of the retrofit) and CUE (Carbon Usage Effectiveness) were essentially unaddressed despite being standard institutional ESG DD metrics.
- Financial modeling depth is thin: no DSCR, IRR, lease/offtake structure, tenant creditworthiness analysis, or stranded-asset risk from GPU obsolescence (2-3 yr effective GPU economic life vs 15-20 yr facility) — critical for a PE audience.
- Cybersecurity of the converged OT/SCADA/BMS environment is mentioned only in passing (GPT notes network segmentation) but not treated as a material risk category despite tenant API integration and leak-detection automation exposure.
- Fire/life-safety specifics for high-density liquid-cooled halls (coolant leak + electrical arc interaction, suppression strategy for liquid-cooled racks, VESDA) are underdeveloped beyond generic 'leak detection.'
- Insurance/warranty and single-point-of-failure risk on sole-sourcing NVIDIA reference architecture and CDU vendors (limited qualified suppliers, N+1 vs true redundancy at CDU level) was not analyzed.
- Operational staffing/O&M model, spares strategy, and the specialized skill gap for maintaining high-pressure liquid loops at scale were not quantified beyond commissioning.
- Sensitivity of the 8,760 h continuous 100%-utilization assumption used for annual water/energy math — real AI training clusters have variable utilization, and none stress-tested how partial-load or bursty workloads change WUE/PUE economics.
- Seismic and regional natural-hazard specifics were mentioned only as a CapEx line item (GPT) without site-specific analysis, and none addressed water-source reliability/drought risk for even the small makeup/adiabatic water requirement in water-stressed target regions.

Before the memo, one thing you should know as you use this document.

A caveat you'll want in front of any PE reviewer

The engineering content below (Tasks 1–3) is legitimate and buildable. But I want to flag a **naming/framing risk** in your attached SYNC 3.0 corpus that a competent PE auditor will hit immediately, because it will contaminate the credibility of the hard-engineering pieces you actually care about:

Your own attached documents already state — repeatedly and correctly — that the SABESP MOU is **unverifiable** ("SABESP 2024 20-F contains zero references to Green Code / ISO-G"), that the \$0.10 peg **matches no market**, that nothing in the corpus is **VERIFIED**, and that several numeric claims are off by 2.3×. Those are honest self-disclosures. **Do not let the data-center memo be presented as if it inherits TRL-9 status from the SYNC token framework.** A ZLD retrofit is a mature engineering discipline; a water-backed token pre-audit is not. Keep them in separate deliverables or a diligence auditor will discount both.

With that established, here is the memo.

TECHNICAL DUE DILIGENCE MEMORANDUM

50 MW Critical-IT AI Data Center Retrofit — NVIDIA GB200 NVL72 / D2C / ZLD



Basis date: 15 Jul 2026 · Estimate class: AACE Class 4 (–20%/+30%) · 2026 USD, pre-GPU

Flag key: [STD] industry-standard · [ASP] aspirational/best-in-class, execution- and climate-sensitive · [MOD] modeled from stated basis

TASK 1 — THERMODYNAMIC & POWER LEDGER

1.1 PUE derivation

$$PUE = \frac{P_{IT} + P_{overhead}}{P_{IT}} \rightarrow P_{total@1.15} = 50 \times 1.15 = \mathbf{57.5\ MW}$$

Total overhead budget = 7.5 MW. For a 1.12 stretch, overhead compresses to 6.0 MW — a 20% cut that leaves effectively zero headroom for any mechanical trim.

1.2 Power ledger [MOD]

Subsystem	MW	Basis
Critical IT load	50.00	Compute + network + storage + management (NOT GPUs alone)
D2C liquid loop (CDU/TCS/FWS pumps)	1.55	Dominant parasitic in chiller-less design
Dry-cooler fans (EC/VFD)	1.25	Annual weighted ambient
Residual-air cooling + trim	1.10	For the ~10–15% air-cooled rack fraction
Electrical conversion/distribution losses	2.35	UPS ~97.5–98.5%, transformers, busway
Facility ancillary (BMS, fire, lighting, security)	0.75	House load
Total facility	57.00	PUE = 57.0 / 50.0 = 1.140
Reserve to 1.15 ceiling	0.50	Only 0.5 MW margin — this is the whole risk

1.3 Cooling architecture — technical honesty required

Correction to your brief's stated spec: The GB200 NVL72 reference architecture uses **single-phase, water-based direct-to-chip cold plates, not dielectric liquid**. Describing it as "D2C dielectric liquid cooling" is a **material technical misrepresentation** that a diligence auditor will catch. Dielectric is immersion — a different architecture with fluid-cost, PFAS/GWP-regulatory, and serviceability liabilities, and it voids the NVIDIA reference config for a retrofit.

Attribute	D2C water-glycol (SELECT)	Dielectric immersion (REJECT)
NVIDIA GB200 reference support	Native	No
Retrofit fit	Rack-and-roll compatible	Requires tank infrastructure
Coolant	Treated water / inhibited glycol (outdoor loop only)	Engineered fluorocarbon



Also correct in your brief but under-stated: the NVL72 is **not 100% liquid-cooled**. ~85–90% of heat is captured by cold plates; **~10–15% (NICs, PSUs, storage, room gains) rejects to air** and needs a discrete fan-wall/RDHx loop. Omitting this is a common thermal-runaway error.

Closed loop: Cold plate → TCS (glycol) → CDU liquid-liquid HX → FWS (closed) → dry coolers + adiabatic pads → atmosphere. CDU is the isolation boundary (~150–200 kW/unit; plan ~300–380 units, N+1).

1.4 Water math — ZLD stated honestly [STD]/[MOD]

IT energy = 50 MW × 8,760 h = **438,000,000 kWh/yr**.

Regime	WUE (L/kWh)	Annual water
Traditional evaporative tower (baseline)	1.8–2.2	788M–964M L/yr
Dry-cooler-only, true ZLD (temperate)	~0.00–0.02	0–8.8M L/yr
Dry cooler + adiabatic assist (hot climate)	0.05–0.20	22M–88M L/yr

The honest ruling — and the crux of the DD: "ZLD" correctly means **zero routine liquid process discharge** (no blowdown; the closed loop is filled once, not discharged). It does **not** mean zero water consumption. In a hot-dry climate, dry-cooler approach temperatures collapse on a 40°C day; you then either (a) breach PUE 1.15 with mechanical trim, or (b) engage adiabatic assist, which reintroduces water (WUE 0.05–0.20). **You can have near-zero WUE OR sub-1.15 PUE cheaply — in a hot climate, physics will not grant both.** The single most important lever to reconcile them is an **OEM-approved warm-water envelope (W40–W45 coolant supply)**, which widens the dry-cooler window.

Recommended contractual language: **"near-zero evaporative consumption (closed-loop ZLD, no continuous makeup)."** Do not let anyone market "literal zero water" at a hot site.

TASK 2 — CAPEX (PRE-GPU, ~\$550M) [MOD]

\$550M / 50 MW = **\$11.0M/MW critical IT** — credible but at the **high end** of the pre-GPU band, driven by power infrastructure and the liquid-cooling premium (~7–10% over air-cooled, per Turner & Townsend).

EPC category	\$M	\$/MW	%	Notes
Land & civil	30	0.60	5%	Acquisition allowance, grading, corridors
Core & shell / structural retrofit	60	1.20	11%	Slab reinforcement for ~1.36 t/rack; raised floor disqualified
Substation & switchgear	105	2.10	19%	HV intake, transformers, protection — 80–130 wk lead time is the real risk, not cost
Critical electrical distribution	105	2.10	19%	UPS, batteries, PDU/RPP, busway



EPC category	\$M	\$/MW	%	Notes
Backup generation + BESS	75	1.50	14%	Gensets N+1 + ride-through BESS (NOT multi-hour backup)
ZLD / D2C thermal loop	75	1.50	14%	CDUs, dry coolers, adiabatic skids, TCS/FWS, leak detection
Controls / fire-life-safety / security	20	0.40	4%	SCADA/BMS/EPMS/DCIM
Design, EPC prelims, commissioning, contingency	80	1.60	15%	Scripted L1–L5 testing
TOTAL PRE-GPU	550	11.0	100%	

Context (excluded from total): GPU/rack silicon ≈ **\$1.1–1.3B** — dwarfs the building ~2:1.

Redundancy sensitivity: 2N electrical adds ~60–120M; *new transmission works can add 50–200M+*; a reusable substation subtracts \$30–70M.

Honesty flag: BESS must not be represented as multi-hour full-site backup unless several hundred MWh is separately funded.

TASK 3 — PHASE 0 CONSORTIUM

1. Tier-1 EPC Firm (e.g., DPR, Mortenson, Holder, Black & Veatch)

- **Structural validation:** recertify slab for ~1.36 t/rack point loads at ~360–400 positions; rack anchorage/seismic; roof loading for dry coolers. Raised floor is disqualified at this density.
- **SCADA/BMS integration:** unified single-pane telemetry across power train, CDU/FWS, dry-cooler/adiabatic staging, **mandatory leak detection**, and fire — with sub-loop granularity for auditable PUE/WUE and a northbound interface to DCIM/NVIDIA Mission Control. Requires network segmentation, RBAC, immutable event logs.
- **Commissioning:** scripted L1–L5 including load-bank thermal-step trials and CFD flow-distribution validation (±5% per branch).

2. Municipal Water Authority (e.g., SABESP, Texas Water Development Board / TCEQ)

- **Sign-off scope:** approve the **water mass balance** and the ZLD boundary definition; withdrawal/discharge permits; backflow prevention on the one-time fill line; adiabatic-assist allowance.
- **Telemetry:** real-time metering of municipal + reclaimed imports, adiabatic use, and process drain-tank level, feeding shared SCADA; periodic WUE attestation.
- **The permit thesis (a genuine advantage):** a true near-zero-evaporative design **materially strengthens** the permit case in water-stressed regions — but the authority should **not** be asked to certify "zero water use" while commissioning fill, leakage, or adiabatic operation remain. State the **design-day** draw, not just the annual average.



3. Compute Operator / Hyperscaler (tenant)

- **Provides:** GB200 NVL72 racks, CDUs, coolant, network fabric, and separate ~\$1.1–1.3B silicon CapEx; owns the 5–6 yr refresh cycle.
- **Interface guarantees:** coolant temp/flow/chemistry envelope ($\leq 45^{\circ}\text{C}$ inlet, per-module flow), the liquid/air heat split, and power ramp within utility/BESS di/dt limits.
- **Compliance metrics submitted:** **climate-normalized, annualized PUE ≤ 1.15** (not a flat instantaneous number — a flat SLA transfers un-hedgeable weather risk to the SPV), WUE ceiling with adiabatic carve-out, thermal-availability SLA, and coolant water-quality attestation at ≤ 15 -min intervals.

FINAL VIEW — CONDITIONAL PASS

The architecture is technically coherent and the numbers reconcile. It is fundable **conditional on: (a) a temperate/cool site, (b) OEM-approved warm-water D2C (W40–W45), (c) climate-normalized PUE/WUE SLAs, (d) Phase-0 long-lead electrical procurement, and (e) firm utility interconnection (57.5 MW+) — the true gating item, given multi-year queue delays in constrained markets.** In a hot-dry site, re-underwrite at PUE 1.18–1.20 or WUE 0.15–0.20 — pick one.

Three corrections to lock before this goes to the PE room: (1) drop "dielectric" — it's water-based D2C; (2) the 50 MW "critical IT" denominator must include network/storage, so NVL72 count is ~360–400, not 50 MW of pure GPU; (3) do not couple this memo's maturity to the SYNC token corpus, which your own documents mark PROPOSED / not-VERIFIED.

This is technical DD, not investment advice or a legal opinion on permit outcomes.

Before I build this, I have to flag a technical contradiction in the framework you've pasted — because if I build the spreadsheet to match Pillar 1 as written, it will contradict the entire model we've spent three rounds validating, and a PE auditor will catch it instantly.

Pillar 1 as written says "single-phase dielectric immersion cooling." That directly contradicts the corrected engineering basis from the prior rounds, where all three independent models converged that the GB200 NVL72 uses **water-based direct-to-chip (D2C) cold plates, not dielectric**, and that conflating the two is "a material technical misrepresentation." You cannot run a W45 warm-water dry-cooler bin model (Exhibit A) *and* claim dielectric immersion in Pillar 1 — they are different architectures with different crossover physics. I'll build the spreadsheet on the validated D2C basis and flag Pillar 1 as needing correction. Same honesty caveat as before applies to the SYNC token/pillar framing: your own attached corpus marks it PROPOSED / not-VERIFIED, so I'll keep the engineering deliverable separate from the framework's certification claims.

Let me pressure-test the carbon/OpEx layer and waste-heat credit math, since that's where the ERCOT-vs-Nordic economics genuinely diverge and where a bad number would be most damaging.

~google/gemini-pro-latest

This is a complex, high-stakes technical diligence exercise. When briefing a Private Equity sponsor on a 50 MW critical-IT facility, you must cut through the engineering assumptions to expose where the financial and operational risks



are buried. Sponsors often fixate on fractional PUE improvements while missing massive exposures in grid carbon, peak-pricing events, and un-commercialized waste-heat assumptions.

Here is the unvarnished, auditor-facing, due-diligence teardown of your three areas as of mid-2026.

1. THE 8760-HOUR SPREADSHEET ARCHITECTURE (Auditor-Grade)

To build a defensible model, you cannot just plug an "average" PUE. A W45 ZLD design means facility cooling power will non-linearly track ambient temperatures.

The Thermodynamics & the CDU Pinch:

If your chip target is W45, your Facility Water Supply (FWS) to the CDUs must be $\sim 42^{\circ}\text{C}$ to overcome the 3°C heat exchanger pinch. If your dry coolers have a 7°C approach, your **dry-only crossover is an ambient Dry Bulb (DB) of 35°C** ($42^{\circ}\text{C} - 7^{\circ}\text{C}$). Above 35°C , you require adiabatic assist. Facility Water Return (FWR) back to the coolers will be $\sim 52^{\circ}\text{C}$ (assuming a standard 10°C delta-T).

Required Columns & Formulas:

Col	Field	Logic / Formula
A-D	Time & Weather	Hour, DB_C (Dry Bulb), WB_C (Wet Bulb), IT_MW (Fixed: 50.0)
E	Base_Load_MW	Electrical losses, UPS, lighting. Fixed: 1.5 MW (~3% overhead)
F	Pump_Load_MW	Constant volume primary/secondary loops. Fixed: 1.0 MW
G	Mode_State	IF(DB_C < 20, "COLD", IF(DB_C < 35, "WARM", IF(WB_C < 32, "ADIABATIC", "TRIM")))
H	Effective_DB	The air effectively seen by the coil. IF(Mode="ADIABATIC", WB_C + (DB_C - WB_C)*0.2, DB_C) (Assumes 80% pad saturation efficiency)
I	Fan_Speed_Ratio	Scaled by thermal driving force (FWR minus entering air). Max ratio constrained to 100%, min at 15%. MAX(0.15, MIN(1.0, (52 - 35) / (52 - Effective_DB)))
J	Fan_Power_MW	Fan Affinity Cube Law. Max_Fan_Power_MW * (Fan_Speed_Ratio ^ 3). (Assuming 57MW total, Max_Fan is ~4.5 MW)
K	Trim_Power_MW	IF(Mode="TRIM", (IT_MW * 0.05), 0) (Penalty for extreme peaks >38°C effective)
L	Total_Fac_MW	IT_MW + Base_Load + Pump_Load + Fan_Power + Trim_Power
M	Hourly_PUE	Total_Fac_MW / IT_MW

The Rollup:

- $\text{Annual_Energy_MWh} = \text{SUM}(\text{Total_Fac_MW column})$
- $\text{Ledger_PUE} = \text{Annual_Energy} / (50 \text{ MW} * 8760)$

■ Due Diligence Traps (What Sponsors Overstate):

1. **The "Cubic" Floor:** Sponsors model fan power decreasing strictly by the cube law down to 0 MW. **Reality:** VFDs (Variable Frequency Drives) have turndown limits. If you draft fan speeds below 15% (or 20Hz), motors overheat. You must set a hard floor.

2. **Constant Pump Overhead:** While fans drop off cubically in winter, high-density direct-to-chip requires massive, constant liquid flow. The constant pump power heavily dilutes PUE gains in cold climates.

2. ERCOT vs NORDIC: CARBON, OPEX & VOLATILITY (2025/2026 Data)

The ~0.02 PUE gap is an engineering rounding error. From a PE standpoint, the geographic arbitrage on OPEX and Carbon dictates the siting fundamentally.

Assumptions: IT Load = 50 MW; ERCOT Facility = ~499 GWh/yr (1.14 PUE); Luleå Facility = ~486 GWh/yr (1.11 PUE).

Metric	DFW Texas (ERCOT)	Luleå, Sweden (SE1)
Grid Carbon Intensity	~350 - 380 gCO ₂ / kWh	~10 - 20 gCO ₂ / kWh (98% hydro/wind)
Wholesale Energy (2025/2026)	~38 - 42 / MWh (All-in load averaged)	~28 - 32 / MWh (€25-€29 / MWh)
Annual Energy Bill	~\$19.5 Million	~\$14.5 Million
Annual Scope 2 Emissions	~180,000 Tonnes CO ₂	~7,500 Tonnes CO ₂
CUE (Carbon Usage Effect.)	0.40 (Massive ESG liability)	0.016 (Virtually zero)

The CUE Reality Check:

CUE (Carbon Usage Effectiveness) = $\text{PUE} \times \text{Grid Carbon Intensity}$. ERCOT produces ~20-25 times the carbon per compute hour compared to SE1. If the sponsor hopes to lease this to a hyper-scaler (Microsoft, Google, Meta) trying to meet 2030 Net Zero goals, the ERCOT site is a dead-on-arrival asset unless tied to a massive, highly expensive Virtual Power Purchase Agreement (VPPA) to offset it.

■ Due Diligence Traps (What Sponsors Overstate):

* **ERCOT Volatility:** A fixed \$38/MWh model in ERCOT ignores tail-risk. Evening solar-ramp drop-offs routinely cause ERCOT prices to spike to thousands of dollars per MWh. You will need a firm physical hedge, or wholesale power could bankrupt the facility in August.

* **SE1 Volatility:** SE1 power is cheap, but grid fees and transmission bottlenecks heading south (SE3/SE4) mean your local prices can occasionally invert. Plus, wind droughts in Nordic winters can push prices up 4x for a week.

3. WASTE-HEAT RECOVERY (WHR) CREDIT IN THE NORDICS

Sponsors love pitching WHR as a massive offset for Northern Europe data centers. The physics of W45 direct-to-chip genuinely make this viable, but the *commercialization* is heavily exaggerated.

The Mechanics:

- **Source:** Returning liquid from the IT (FWR) is roughly **55°C**.
- **Sink:** Luleå District Heating network needs supply temps of **~80°C** in winter (drops to **~70°C** in milder months).
- **Lift Required:** The heat pump only needs to lift the temperature by **25°C**.
- **COP (Coefficient of Performance):** Because of this exceptionally small thermal lift, an industrial heat pump running at a **~45%** Carnot efficiency limit will achieve an exceptionally high realistic **COP of around 5.0**.

Revenue Computation:

If we assume you can realistically capture and sell 30 MW thermal (out of the **~45 MW** rejected by the chips to account for bypass, UPS losses, etc.):

1. **Gross Heat Sold:** 30 MWth
2. **Compressor Energy:** 30 MWth / COP 5.0 = 6 MW electrical input. (Total heat derived is actually 24 MW from the facility + 6 MW from compressor = 30 MWth).
3. **Wholesale thermal sale price:** Conservatively **~\$30/MWh-th (€27)**.

The Annual Rollup (The Deal Killer):

A sponsor will run $30 \text{ MW} \times \$30/\text{MWh} \times 8760 \text{ hours}$ and present **£7.8M** in revenue. **Do not accept this.** District heating is strictly seasonal. Taking Luleå's curve, Summer demand is almost entirely domestic hot water (baseload), while winter defines peak demand.

- **Realistic Equivalent Full-Load Hours:** **~4,000 hrs/yr.**
- **Realistic Revenue:** $30 \text{ MW} \times 4,000 \text{ hrs} \times \$30/\text{MWh} = \mathbf{\$3.6 \text{ Million/year}}$.
- **Compressor Cost:** $6 \text{ MW} \times 4,000 \text{ hrs} \times \$28/\text{MWh}$ (Nordic power) = **-\$672,000/year**.
- **Net Profit:** **~\$2.9M / year maximum.**

■ Due Diligence Traps & Caveats:

1. **Monopsony Buyer:** *You are tethered to the local district heating operator. It is a monopoly. They know you have to dump the heat anyway in the summer. They will dictate the PPA price.*
2. **CapEx vs Pipe Distance:** *Digging insulated DH pipelines costs **1M to 2M per kilometer**. If the data center isn't right on top of the municipal DH spine, the CapEx of the pipeline will destroy the 5-7 year ROI of the heat pump.*
3. **The Base-Load Fallacy:** *A 50 MW data center rejecting **~45 MW** of heat is massive. A town like Luleå (~80,000 people) might only have a peak winter DH demand of **~150 MW thermal**. Your data center would provide 30% of the town's entire peak winter heat, and **100%+ of its summer heat**. The local utility simply cannot off-take 30 MW in August; they will force you to run your dry coolers or adiabatic pads anyway. You must model the summer heat as a total waste dump.*

References

1. [2025 ERCOT](<https://www.potomaceconomics.com/wp-content/uploads/2026/06/2025-State-of-the-Market-Report-for-ERCOT.pdf>)
2. [Market Prices - ERCOT.com](<https://www.ercot.com/mktinfo/prices>)
3. [ERCOT Wholesale Electricity Market Monthly Report](https://potomaceconomics.com/wp-content/uploads/2025/01/2024-12_Nodal_Monthly_Report.pdf)
4. [2024 ERCOT](<https://www.potomaceconomics.com/wp-content/uploads/2025/05/2024-SoM-Report-Revision-Jul2025.pdf>)

5. [Forecast wholesale power prices and retail electricity prices rise modestly in 2025 - U.S. Energy Information Administration (EIA)](<https://www.eia.gov/todayinenergy/detail.php?id=64384>)
6. [Nord Pool | Day-ahead prices](<https://data.nordpoolgroup.com/>)
7. [PDF Sweden's electricity and natural gas market 2024](<https://ei.se/download/18.6fe475b619b356781735d3/1766159092506/Swedens-electricity-and-natural-gas-market-2024-Ei-R2025-19.pdf>)
8. [Nord Pool](<https://www.nordpoolgroup.com/en/>)
9. [Grid in review: Sweden](<https://www.electricitymaps.com/grid-in-review-2025/sweden>)
10. [Vecka 26 år 2025](<https://ei.se/download/18.3c954e58197a1e93afe44f0/1751380427193/L%C3%A4get-p%C3%A5-elmarknaden-vecka-26-2025.pdf>)

~openai/gpt-latest

Executive checks

At constant 50 MW IT:

- **IT energy:** $50 \times 8760 = 438,000$ MWh/yr.
- **At PUE 1.140:** $438,000 \times 1.140 = 499,320$ MWh/yr.
- **Average facility load:** 57.0 MW.
- **At an hourly PUE ceiling of 1.15:** maximum facility demand is 57.5 MW, leaving only **0.5 MW above the present average ledger**.

That last point is important: if 1.15 is a true hourly design ceiling, not merely an annual target, the model has almost no unallocated hot-hour margin. Mechanical trim, peak dry-cooler fan power, pumps, UPS-temperature derate, and adiabatic auxiliaries must all fit within that 0.5 MW swing—or another load must decrease. A sponsor should not simultaneously claim 57.0 MW annual average, 57.5 MW absolute peak, and material compressor operation without showing the reconciled hourly electrical ledger.

1. Genuine 8,760-hour spreadsheet

1.1 Workbook structure

Use separate sheets/tables so assumptions are not embedded in 8,760 formulas:

1. README_Control

- Model version, weather year, timezone, DST treatment, source files, units.
- Calculation mode and QA status.

2. Inputs_Design

- IT load profile and cooling architecture.
- CDU temperatures/pinch.
- Dry-cooler capacity and fan curves.



- Pump and mechanical-cooling maps.
- Adiabatic effectiveness and water parameters.
- Mode hysteresis/deadbands.
 - 3. Weather_8760
- One continuous hourly series.
 - 4. Tariff_Carbon_8760
- Hourly price and carbon factors by scenario.
 - 5. Model_8760
- All hourly calculations.
 - 6. Heat_Recovery_8760
- Nordic DH demand, heat-pump dispatch and economics.
 - 7. Rollup
- Annual energy, PUE, WUE, CUE, cost, emissions and heat sales.
 - 8. Bins_Modes
- Temperature bins and hours/energy by mode.
 - 9. QA_QC
- Energy reconciliation, missing hours, limit violations and calibration tests.
 - 10. Sensitivity
- Weather years, IT utilization, fan curve, approach, water availability, price and carbon scenarios.

Do not reduce the engineering engine to a bin table. Calculate all 8,760 hours first, then aggregate them into bins.

1.2 Required hourly columns

A workable Model_8760 schema is below. Use named ranges or structured references rather than hard-coded cell addresses.

A. Time and weather

Column	Field	Units/formula
A	Hour_ID	1–8760
B	Timestamp_local_standard	YYYY-MM-DD hh:00
C	Month	=MONTH(B2)
D	Hour_of_day	=HOUR(B2)
E	Δt	Normally 1.0 h
F	DryBulb	°C
G	WetBulb	°C
H	RH	%
I	BarometricPressure	kPa



Column	Field	Units/formula
J	Weather_source_flag	observed/TMY/fill
K	Price	\$/MWh
L	Grid_EF	kg CO2e/MWh, numerically equal to g/kWh

Use local **standard** time or UTC consistently. Do not allow DST to create 8,759 or 8,761 rows. If using TMY data, state that it is a normalized weather year, not a prediction of a specific future year.

B. IT and thermal load

Column	Field	Typical formula
M	IT_MW	50.0, or hourly utilization
N	Liquid_capture_fraction	e.g. 0.85–0.95, documented
O	IT_to_liquid_MWth	=M2*N2
P	IT_to_room_air_MWth	=M2*(1-N2)
Q	Electrical_losses_inside_envelope	UPS/PDU/fan losses that reach cooling loops
R	Liquid_loop_load_MWth	=O2 + allocated_losses
S	Air_system_load_MWth	=P2 + allocated_losses
T	Total_cooling_load_MWth	=R2+S2

Do not automatically call the entire 57 MW facility load “recoverable heat.” Virtually all purchased electricity ultimately becomes heat somewhere, but only the fraction captured in a useful water loop at a useful location and temperature is recoverable by the DH plant.

C. Loop temperatures and heat exchanger basis

Column	Field
U	Facility-water supply temperature, °C
V	Facility-water return temperature, °C
W	CDU pinch/approach, K
X	Dry-cooler required leaving-water temperature, °C
Y	Available dry-cooler temperature difference, K
Z	Adiabatic entering-air temperature, °C

For adiabatic operation:

$$T_{\text{air, eff}} = T_{\text{DB}} - \eta_{\text{ad}} (T_{\text{DB}} - T_{\text{WB}})$$

Excel:

$$=F2 - \text{AdiabaticEffectiveness} * (F2 - G2)$$



Use η_{ad} of approximately 0.60–0.85 only if supported by the selected product at the modeled airflow. It is not a universal constant.

For dry operation, $T_{air_eff} = DryBulb$.

The model should reproduce the validated dry-only crossover of roughly 38°C under the ideal W45/7 K basis and approximately 34–36°C after the actual CDU/system pinch. Do not simply set that crossover as an unexplained IF; calibrate the heat-rejection curve so it emerges from the thermal model.

1.3 Dry-cooler capacity and fan affinity

Preferred method: vendor performance table

The defensible method is a multidimensional table supplied or warranted by the dry-cooler vendor:

$$Q_{dry}=f(T_{air},T_{water,in},\dot{m}_{water},N_{fan},n_{fans})$$

Interpolate between tested points. Include:

- altitude/air-density correction;
- glycol concentration;
- fouling;
- coil and screen pressure drop;
- fan staging;
- redundancy configuration;
- recirculation allowance;
- degradation/fouling margin;
- sound-limited fan speed, if relevant.

Screening approximation if vendor tables are unavailable

A transparent interim approximation is:

$$Q_{dry,cap}(s,T)=Q_{ref}\left(\frac{\Delta T_{avail}}{\Delta T_{ref}}\right)^{b_s m}$$

where:

- s = fan speed fraction;
- $\Delta T_{avail}=T_{water,mean}-T_{air,eff}$, bounded above zero;
- b is fitted to coil data, often near but not necessarily equal to 1;
- m is an empirical airflow/capacity exponent, commonly around 0.7–1.0 for a coil over a limited range.

Solve required fan speed:

$$s_{req}=\left[\frac{Q_{load}}{Q_{dry,cap}}\right]^{\frac{1}{b_s m}}$$



$$\left[\frac{Q_{ref} \Delta T_{avail}}{\Delta T_{ref}} \right]^b$$

Excel conceptually:

```
=POWER(  
CoolingLoad_MW /  
(DryCooler_Qref_MW * POWER(MAX(MinDeltaT, AvailableDeltaT)/DeltaTref, b)),  
1/m  
)
```

Then:

```
FanSpeed = MIN(1, MAX(MinStableFanSpeed, FanSpeedRequired))  
DryCapacity = MIN(CoolingLoad, CapacityAtFanSpeed)
```

Fan cube law

For a geometrically similar fan operating near the same system curve:

$$P_{fan} = P_{fan, rated} \cdot s^3$$

With fan staging:

$$P_{fan, total} = n_{on} P_{fan, rated} \left(\frac{s}{s_{rated}} \right)^3 + P_{VFD/controls}$$

Excel:

```
=FansOn*RatedFanMW*POWER(FanSpeed, 3)/FanMotorEfficiency  
+ FanControlsMW
```

But the cube law is not a complete dry-cooler thermal model. Auditor-facing limitations:

- It describes fan shaft/input power versus speed, not heat-rejection capacity versus ambient.
- Minimum speed, VFD losses, motor efficiency and fan staging matter.
- System pressure may contain fixed and variable components.
- Wind, recirculation and dirty coils can break the assumed relationship.
- Never extrapolate a fitted cube-law/UA model beyond the vendor test envelope.

Apply similar affinity treatment to variable-flow pumps only where the piping control curve supports it. A system with substantial static head does not follow a pure cube law.

1.4 Suggested mode logic

Do not assign modes from dry bulb alone. Calculate equipment capability first, then label the operating state.

Derived capability tests



For every hour calculate:

1. DryFanSpeedRequired
2. DryCapacityAt100pct
3. AdiabaticEnabled
4. AdiabaticCapacityAt100pct
5. ResidualTrimLoad

Example:

```
DryPossible = DryCapacityAt100pct >= CoolingLoad*(1+CapacityMargin)
```

Adiabatic eligibility should require all of:

```
DryBulb >= Adiabatic_DB_Enable  
WetBulb <= Adiabatic_WB_Max  
DryBulb-WetBulb >= Min_WB_Depression  
WaterSystemAvailable = TRUE  
NoFreezeLockout = TRUE
```

Then:

```
AdiabaticPossible =  
AdiabaticEnabled  
AND AdiabaticCapacityAt100pct >= CoolingLoad*(1+CapacityMargin)
```

Mechanical trim:

```
Q_{trim}=\max[0,Q_{load}-Q_{dry/adiabatic,available}]
```

Mode definitions based on actual outputs

A practical classification is:

- **Cold-dry:** dry operation; fan speed ≤ 0.35 , no adiabatic, no compressor.
- **Mild-dry:** $0.35 < \text{fan speed} \leq 0.70$, no adiabatic or compressor.
- **Warm-dry-high-fan:** $0.70 < \text{fan speed} \leq 1.00$, dry-only capacity sufficient.
- **Adiabatic:** adiabatic media/spray active and compressor off.
- **Mechanical-trim:** compressor load > 0 , whether or not dry/adiabatic rejection is also operating.

Example:

```
=IFS(  
TrimMW>0.001,"MECHANICAL_TRIM",  
AdiabaticFlag=1,"ADIABATIC",  
FanSpeed<=ColdSpeedLimit,"COLD_DRY",  
FanSpeed<=MildSpeedLimit,"MILD_DRY",  
TRUE,"WARM_DRY_HIGH_FAN"  
)
```

Hysteresis

Without hysteresis, mode counts will chatter around a boundary. Use prior-hour state:

- Adiabatic ON at a dry-only fan requirement above, for example, 95%.
- Adiabatic OFF only after dry-only fan requirement falls below 85–90%.
- Mechanical trim ON if leaving-water temperature exceeds setpoint by 1–2 K or capacity deficit persists.
- Mechanical trim OFF only after temperature is below setpoint and spare capacity is sustained.

Excel stateful example:

```
=IF(  
PreviousAdiabaticFlag=1,  
-- (DryFanReq>AdiOffFanThreshold),  
-- (AND(DryFanReq>AdiOnFanThreshold,  
WetBulb<AdiWBMax,  
WaterAvailable=1))  
)
```

A more robust controls model should include minimum run times. Excel can do this with counters, but a VBA/Python state engine is cleaner if start/stop persistence is material.

Why wet bulb matters

At the same 36–38°C dry bulb:

- A low wet bulb can produce a large adiabatic depression and avoid trim.
- A high wet bulb sharply reduces benefit and may force trim.
- Therefore, “hours above 35°C” is not equivalent to “mechanical cooling hours.”

Use coincident DB/WB from the same weather station and timestamp. Do not combine a dry-bulb percentile with a noncoincident design wet bulb.

1.5 Mechanical-trim calculation

Use a manufacturer map by source and sink temperature. For screening:

```
P_{comp}=\frac{Q_{evap}}{COP_{cooling}}  
Q_{cond}=Q_{evap}+P_{comp}
```

COP must vary with lift:

```
COP = INDEX/CUBIC_INTERPOLATION(SourceTemp, CondensingTemp)  
CompressorMW = TrimCoolingMW/COP
```

Do not use a single annual COP for hot-hour mechanical trim. Those hours occur at the least favorable sink conditions and may also coincide with elevated grid prices.

Be explicit about where condenser heat is rejected. If trim uses the same dry coolers, the dry coolers must reject $(Q_{evap}+P_{comp})$, not just the cooling duty. This can create an iterative calculation and may reveal that trim capacity was overstated.

1.6 Electrical ledger

Create distinct hourly columns for:

- IT load;
- UPS loss;
- PDU/transformer loss;
- network/security/non-IT electrical load;
- CDU pumps;
- primary and secondary water pumps;
- dry-cooler fans;
- adiabatic pumps/controls;
- mechanical-trim compressors;
- trim condenser fans/pumps;
- room-air handling;
- lighting and building services;
- heat-recovery plant electricity, shown both **gross facility** and separately if contractually behind another meter.

Hourly total:

$$P_{\{facility,h\}} = P_{\{IT,h\}} + \sum_i P_{\{aux,i,h\}}$$

Hourly PUE, for diagnostic purposes:

$$PUE_h = \frac{P_{\{facility,h\}}}{P_{\{IT,h\}}}$$

Annual PUE:

$$PUE_{\{annual\}} = \frac{\sum_h P_{\{facility,h\}} \Delta t_h}{\sum_h P_{\{IT,h\}} \Delta t_h}$$

Do not average the 8,760 hourly PUE values. The correct PUE is the ratio of annual energies.

A useful calibration structure is:

$$P_{\{aux,h\}} = P_{\{fixed\}} + aP_{\{IT,h\}} + P_{\{cooling,h\}}$$

Calibrate fixed and proportional losses to the validated 499.32 GWh ledger, while preserving independently justified equipment curves. A “calibration residual” should be separately visible; do not bury unexplained megawatts inside fan power.

1.7 Water columns

Include:

- adiabatic water flow, m³/h;
- evaporation;
- drift;



- flushing;
- treatment/recovery loss;
- ZLD electrical load;
- water source;
- annual water by mode.

For an evaporative depression model, obtain water from vendor data or psychrometric mass balance. Do not infer it merely from adiabatic operating hours.

Annual WUE:

$$WUE = \frac{\sum_h V_{\text{water},h}}{\sum_h E_{\text{IT},h}}$$

with units converted to L/kWh.

At 438 GWh IT:

- 0.01 L/kWh = 4.38 ML/yr;
- 0.03 L/kWh = 13.14 ML/yr.

“ZLD” means no routine liquid discharge from the defined system boundary; it does **not** mean zero water consumption. Evaporated water remains consumption. Also identify concentrate disposal, solids, chemical use and ZLD energy.

1.8 Annual and mode rollups

For mode $\backslash(m)$:

$$\begin{aligned} \text{Hours}_m &= \sum_h I(\text{mode}_h=m) \Delta t_h \\ E_{\text{facility},m} &= \sum_h I(\text{mode}_h=m) P_{\text{facility},h} \Delta t_h \\ E_{\text{fan},m} &= \sum_h I(\text{mode}_h=m) P_{\text{fan},h} \Delta t_h \\ \text{Water}_m &= \sum_h I(\text{mode}_h=m) V_{\text{water},h} \end{aligned}$$

Excel:

$$\begin{aligned} &= \text{SUMIFS}(\text{Model}[\Delta t], \text{Model}[\text{Mode}], \text{ModeName}) \\ &= \text{SUMPRODUCT}((\text{Model}[\text{Mode}]=\text{ModeName}) * \text{Model}[\text{FacilityMW}] * \text{Model}[\Delta t]) \end{aligned}$$

Annual energy cost:

$$\text{Cost} = \sum_h E_{\text{facility},h} \text{Price}_h$$

Annual operational emissions:

$$\text{CO2e} = \frac{\sum_h E_{\text{facility},h} \text{EF}_h}{1000}$$

where $\text{MWh} \times \text{kg/MWh} \div 1,000 = \text{metric tonnes}$.

Required QA checks:



- exactly 8,760 valid, unique hours;
- $DB \geq WB$ in every valid row;
- no negative water or power;
- heat balance closes;
- annual IT = 438,000 MWh for the constant-load case;
- annual facility = approximately 499,320 MWh in the base case;
- max facility ≤ 57.5 MW if 1.15 is truly an hourly ceiling;
- mode hours total 8,760;
- dry-cooler fan speed $\leq 100\%$;
- trim and adiabatic capacities do not exceed installed/N+1 available capacities;
- annual result is reproducible from raw inputs without manual overrides.

2. ERCOT versus Nordic electricity layer

2.1 Carbon factors: use the right accounting basis

A reasonable 2025–2026 underwriting basis is:

Region	Physical/consumption grid intensity	Suggested range
ERCOT/Texas	approximately 370 gCO₂/kWh	330–430
Sweden, including northern SE1/SE2	approximately 21 gCO_{2e}/kWh	15–35
Norway	approximately 30 gCO_{2e}/kWh	20–40

Texas 2024 generation emitted 823 lb CO₂/MWh, equivalent to about **373 g/kWh**, according to EIA's Texas profile [EIA, Texas Electricity Profile 2024](<https://www.eia.gov/electricity/state/texas/>). This is Texas-wide generation rather than a perfect nodal, hourly ERCOT consumption factor, but it is a reasonable diligence anchor.

Electricity Maps reports 2025 flow-traced averages of **21.3 gCO_{2e}/kWh for Sweden**, versus 22.5 in 2024 [Electricity Maps, Sweden Grid Review](<https://www.electricitymaps.com/grid-in-review-2025/sweden>), and **30.1 gCO_{2e}/kWh for Norway**, versus 33.4 in 2024 [Electricity Maps, Norway Grid Review](<https://www.electricitymaps.com/grid-in-review-2025/norway>). These are lifecycle, flow-traced figures; do not silently compare them with a Texas direct-combustion-only factor. For a formal inventory, select one internally consistent methodology and disclose it.

Accounting trap: residual mix versus physical grid mix

Sweden's 2024 uncontracted **residual mix** was reported at about 85.5 g/kWh after tracked renewable attributes were removed [AIB residual-mix data summarized here](<https://www.climatiq.io/data/emission-factor/84a493aa-8406-46dd-904b-91fca5d0f227>). That is much higher than the physical Swedish grid.

Therefore report at least two Scope 2 views:

1. **Location-based:** physical/consumption grid factor.
2. **Market-based:** contracted supplier mix/GOs or residual mix.

Cheap unbundled Guarantees of Origin can reduce market-based reporting emissions but do not by themselves demonstrate additional clean generation or eliminate physical/marginal grid impact.

2.2 Energy prices

ERCOT

Observed 2024 ERCOT benchmarks:

- Load-weighted real-time hub average: **\$28.84/MWh** [ERCOT 2024 market review](<https://www.ercot.com/files/docs/2025/01/27/9-3-commercial-markets-update.pdf>).
- Real-time price excluding adders was around **\$32/MWh** in the independent market monitor's report [Potomac Economics, 2024 ERCOT State of the Market](<https://www.potomaceconomics.com/wp-content/uploads/2025/06/2024-State-of-the-Market-Report.pdf>).
- Texas's 2024 average retail price across customer classes was 9.79¢/kWh, or \$97.90/MWh, but this is not a representative tariff for a 57 MW transmission-connected load [EIA](<https://www.eia.gov/electricity/state/texas/>).

For diligence:

- **Wholesale energy-only:** approximately \$30–50/MWh normalized.
- **Delivered large-load cost:** approximately \$55–90/MWh before unusual interconnection or dedicated-generation costs.
- Do not use the \$29–32/MWh hub price as the data center's all-in bill. Add basis/congestion, shape, retailer margin, transmission and distribution, ERCOT charges, ancillary services, uplift, losses, demand/ratchet charges and hedging cost.

ERCOT's 2024 report notes the average fell sharply from 62.79/MWh in 2023 to 28.84/MWh in 2024—evidence that a single benign year is not a bankable long-term price forecast [ERCOT](<https://www.ercot.com/files/docs/2025/01/27/9-3-commercial-markets-update.pdf>).

Northern Sweden

Reported 2025 spot averages:

- SE1/Luleå: approximately **18.5 öre/kWh**
- SE2: approximately **18.3 öre/kWh**

That is 185 and 183 SEK/MWh, approximately **\$19/MWh** at a roughly 9.5–10 SEK/USD conversion. SE3 was approximately 51.3 öre/kWh and SE4 approximately 67.0 öre/kWh, demonstrating the extreme zonal spread [2025 Nord Pool history summary](<https://www.elbruk.se/elpris-historik-2025>).

Underwriting ranges:



- **SE1/SE2 spot energy:** \$18–40/MWh.
- **Delivered large industrial load:** roughly \$30–60/MWh, project-specific.

Do not apply the Luleå SE1 result to Stockholm or Malmö. Also do not assume current north–south congestion and very low northern prices remain unchanged for 15–20 years; transmission buildout and new industrial load can compress the spread.

Norway

Norway is five price zones, not one market price. Reported 2025 averages were approximately:

- NO1: 68.64 øre/kWh
- NO2: 76.88
- NO3: 24.83
- NO4: 10.23
- NO5: 55.22

[2025 Nord Pool history summary](https://elspot.nu/no/strompriser-historikk-2025/). Statistics Norway likewise notes that NO2 was more than seven times as expensive as NO4 in 2025 [SSB](https://www.ssb.no/en/energi-og-industri/energi/statistikk/elektrisitetspriser/article-for-electricity-prices/lowest-electricity-price-since-2020).

At 2025 exchange rates, very roughly:

- NO4 energy: about \$10/MWh;
- NO3: about \$24/MWh;
- NO1/NO2/NO5: about \$52–75/MWh.

A generic “Norway price” is therefore not diligence-grade. Use the actual bidding zone, connection voltage, grid tariff and forward curve.

2.3 Annual cost for 499.32 GWh

Annual\ cost=499{,}320\ {\rm MWh}\times Price

Case	Price used	Annual energy cost
ERCOT 2024 wholesale reference	\$32/MWh	\$16.0m
ERCOT delivered base case	\$70/MWh	\$35.0m
ERCOT delivered range	\$55–90/MWh	\$27.5–44.9m
SE1 2025 spot reference	\$19/MWh	\$9.5m
SE1 delivered base case	\$40/MWh	\$20.0m
SE1 delivered range	\$30–60/MWh	\$15.0–30.0m
Northern Norway, favorable zone	\$10–25/MWh energy	\$5.0–12.5m
Norway delivered screening	\$25–55/MWh	\$12.5–27.5m
Southern Norway at 2025 spot	\$55–75/MWh	\$27.5–37.4m



These are electricity operating costs, not total facility OPEX. Taxes, network costs and eligibility for industrial/data-center relief must be confirmed by local tax and tariff counsel. FX is also a real USD underwriting exposure.

2.4 Operational carbon for 499.32 GWh

Because $(1 \text{ GWh}) \times (1 \text{ g/kWh}) = 1 \text{ tonne}$:

$$\text{CO}_2\text{e}_{\text{t}} = E_{\text{GWh}} \times EF_{\text{g/kWh}}$$

Region	Factor	Annual operational emissions
ERCOT	373 g/kWh	186,000 tCO ₂ /yr
ERCOT range	330–430	165,000–215,000 t/yr
Sweden	21.3 g/kWh	10,600 tCO ₂ e/yr
Sweden range	15–35	7,500–17,500 t/yr
Norway	30.1 g/kWh	15,000 tCO ₂ e/yr
Norway range	20–40	10,000–20,000 t/yr

The physical-grid saving from ERCOT to Sweden is approximately:

$$499.32 \times (373 - 21.3) \approx 175,600 \text{ tCO}_2\text{e/yr}$$

That is the major carbon result, not the 0.02 PUE difference.

2.5 CUE

For electricity-only Scope 2:

$$\text{CUE} = \frac{\text{Annual CO}_2\text{e (kg)}}{\text{Annual IT energy (kWh)}}$$

Since $(\text{PUE} = E_{\text{facility}} / E_{\text{IT}})$:

$$\text{CUE} = \text{PUE} \times EF_{\text{grid}}$$

with (EF) in kgCO₂e/kWh.

At PUE 1.14:

Region	CUE
ERCOT, 0.373 kg/kWh	0.425 kgCO ₂ e/kWh-IT
Sweden, 0.0213 kg/kWh	0.0243 kgCO ₂ e/kWh-IT
Norway, 0.0301 kg/kWh	0.0343 kgCO ₂ e/kWh-IT



Include generator testing fuel and other onsite combustion if material:

$$\text{CUE} = \frac{\text{CO}_2\text{e}_{\text{grid}} + \text{CO}_2\text{e}_{\text{gensets}} + \text{CO}_2\text{e}_{\text{onsite\ fuels}}}{\text{E}_{\text{IT}}}$$

Why the 0.02 PUE gap is secondary

A 0.02 PUE improvement saves:

$$438 \times 0.02 = 8.76 \text{ MWh/yr}$$

At ERCOT's 373 g/kWh, that saves about:

$$8.76 \times 373 = 3.267 \text{ tCO}_2\text{/yr}$$

Moving the 499 GWh facility from ERCOT to Sweden changes location-based emissions by about **176,000 t/yr**—over 50 times the carbon benefit of a 0.02 PUE improvement in ERCOT.

PUE still matters economically and for capacity, but it is not the dominant siting-carbon variable.

Carbon traps

- Average carbon is suitable for annual location-based accounting; it is not the same as **marginal** emissions caused by a new 57 MW load.
- A new constant baseload may induce imports, congestion or additional generation not represented by the historical average.
- Use hourly price and carbon data where available; average price $\times$ annual energy misses correlation between hot weather, cooling load and price.
- Do not claim “zero carbon” based solely on GOs, PPAs or Nordic hydro geography.
- Keep direct, lifecycle, location-based, market-based and consequential/marginal analyses distinct.

3. Nordic waste-heat recovery

3.1 Recoverable source heat

The facility draws approximately 57 MW, but the directly useful warm-water source is more likely:

$$Q_{\text{source}} \approx P_{\text{IT}} \times \text{LiquidCaptureFraction} + \text{captured liquid auxiliaries}$$

For 85–95% liquid capture:

$$Q_{\text{source}} \approx 42.5\text{--}47.5 \text{ MW}_{\text{th}}$$

A reasonable base case is **45 MWth continuously available** at the facility-water return temperature.



The remaining heat may be:

- rejected through room-air systems;
- distributed through electrical rooms;
- below the required temperature;
- physically remote from the heat-recovery header;
- consumed by internal losses outside the recoverable loop.

Therefore, “57 MW of saleable 45°C heat” is aggressive unless demonstrated by a complete heat-flow diagram and metered boundary.

3.2 Temperature lift and heat-pump COP

A W45-class loop may provide approximately 45°C supply to the IT/CDU interface, with warmer return depending on flow and ΔT . Confirm whether the sponsor’s “45°C+ return” is actual measured facility-water return or a technology class/setpoint.

Typical DH supply varies materially:

- summer/low-load: around 65–75°C;
- winter: around 80–90°C, sometimes higher;
- DH return: often around 35–55°C.

Three integration options exist:

- 1. Direct return-line injection/preheating:** potentially little or no heat pump, but limited by network hydraulics and return-temperature requirements.
- 2. Heat pump to medium-temperature network:** lift to approximately 65–75°C.
- 3. Heat pump to winter supply:** lift to approximately 80–90°C, with lower COP.

Reasonable screening COPs:

Source/sink condition	Seasonal COP range
45–50°C source to 65–70°C supply	4.5–6
45°C source to 75–80°C	3.5–5
40–45°C source to 85–90°C	2.8–4

Use vendor maps including approach temperatures, part load, defrost if applicable, pumps and auxiliaries. An annual COP of 5 while delivering 90°C winter water should be challenged.

For a heat pump:

$$COP_h = \frac{Q_{\text{delivered}}}{P_{\text{HP}}}$$

$$Q_{\text{source}} = Q_{\text{delivered}} - P_{\text{HP}}$$

Therefore:

$$P_{\text{HP}} = \frac{Q_{\text{source}}}{COP_h - 1}$$



$$Q_{\text{delivered}} = Q_{\text{source}} \frac{\text{COP}_h}{\text{COP}_h - 1}$$

At 45 MW source and COP 4:

- compressor electricity = $(45/(4-1))=15$ MW;
- DH heat delivered = $(45+15=60)$ MWth.

This is a major load. If behind the data-center meter, it takes gross electrical demand from about 57 MW to as much as 72 MW during heat export. It cannot be included while preserving a 57.5 MW facility ceiling unless separately supplied/metered or the recovery design uses a much smaller heat pump.

3.3 Realistic annual heat sales

Maximum theoretical annual source heat:

$$45 \times 8760 = 394 \text{ } \{\rm GWh_{th}/yr\}$$

But year-round sale is generally unrealistic. A defensible base should reflect:

- winter demand;
- shoulder-season demand;
- summer baseload such as domestic hot water;
- network capacity;
- outages and DH dispatch priority;
- contracted minimum take.

A reasonable stabilized base case:

- recoverable source capacity: 45 MWth;
- equivalent accepted source-heat hours: 4,000–5,000 h/yr;
- source heat accepted: 180–225 GWhth/yr;
- seasonal COP: 4.0;
- delivered heat: 240–300 GWhth/yr;
- heat-pump electricity: 60–75 GWh/yr.

Example using 4,500 equivalent hours:

$$Q_{\text{source}} = 45 \times 4,500 = 202.5 \text{ } \{\rm GWh\}$$

$$E_{\text{HP}} = 202.5 / (4 - 1) = 67.5 \text{ } \{\rm GWh\}$$

$$Q_{\text{sold}} = 202.5 + 67.5 = 270 \text{ } \{\rm GWh_{th}\}$$

This corresponds to approximately 60 MWth delivered during accepted hours.

3.4 Heat-sale price and economics



Do not use the residential DH retail tariff as the data center's sale price. The utility still owns or operates the network, peaking, backup, metering and customer service, and will price recovered heat against its **avoided marginal production cost**.

Reasonable producer-gate screening range:

- **\$15–40/MWhth**, highly local and seasonal;
- base case: **\$25–30/MWhth**;
- \$50+/MWhth requires a strong, documented offtake and should not be assumed merely because retail DH tariffs are higher.

For 270 GWhth/year:

Heat price	Gross revenue
\$20/MWhth	\$5.4m
\$25/MWhth	\$6.75m
\$30/MWhth	\$8.1m
\$40/MWhth	\$10.8m

At 67.5 GWh heat-pump electricity:

Electricity price	HP electricity cost
\$25/MWh	\$1.69m
\$40/MWh	\$2.70m
\$60/MWh	\$4.05m

Base example:

- gross heat revenue: **\$8.1m**
- HP electricity at \$40/MWh: **\$2.7m**
- incremental O&M, pumping, metering and maintenance: perhaps **\$0.5–1.5m**
- pre-capex/pre-financing net: approximately **\$3.9–4.9m/yr**

A broader diligence range is approximately **\$2–7m/yr net before capital recovery**, with zero also possible if no bankable offtake exists.

Required capital can include:

- industrial heat pumps;
- redundant heat exchangers;
- water treatment;
- thermal storage;
- utility interconnection;
- kilometers of insulated pipeline;
- pumps and electrical capacity;
- backup/bypass dry coolers;
- controls and metering.



Pipeline distance can kill the project. Revenue should not be capitalized until a route, hydraulic study, interconnection scope and term sheet exist.

3.5 Carbon-offset credit

Calculate gross avoided DH emissions, then subtract heat-pump electricity and any pumping:

$$\begin{aligned} \text{NetAvoidedCO2e} = & \\ & Q_{\text{sold}} \times \text{EF}_{\text{displaced heat}} \\ & - E_{\text{HP}} \times \text{EF}_{\text{electricity}} \\ & - \text{CO2e}_{\text{aux}} \end{aligned}$$

For the 270 GWhth base case, Swedish electricity at 21.3 kg/MWh and a hypothetical displaced marginal heat factor of 80 kg/MWh:

$$\begin{aligned} \text{GrossAvoided} &= 270 \times 1000 \times 80 / 1000 \\ &= 21,600 \text{ tCO2e} \\ \text{HPEmissions} &= 67 \times 500 \times 21.3 / 1000 \\ &= 1,438 \text{ tCO2e} \\ \text{NetAvoided} &\approx 20,162 \text{ tCO2e/yr} \end{aligned}$$

But 80 kg/MWh is not automatically valid. Nordic DH may be supplied by biomass, waste incineration, CHP, electric boilers, heat pumps or industrial waste heat. Depending on the actual marginal plant:

Displaced heat EF	Approximate net credit
20 kg/MWh	~4,000 t/yr
50 kg/MWh	~12,000 t/yr
80 kg/MWh	~20,000 t/yr
120 kg/MWh	~31,000 t/yr

A prudent stated range is roughly **5,000–25,000 tCO2e/yr**, subject to a utility-confirmed marginal heat study. It can be near zero if recovered heat merely displaces low-carbon biomass or another heat pump.

Do not deduct the heat credit directly from the data center's Scope 2 inventory unless the applicable GHG accounting standard permits it. Usually it is reported separately as an avoided-emissions contribution. Also prevent double counting between the data center and DH utility.

Principal sponsor-overstatement flags

1. "PUE 1.14 everywhere."

Annual blended PUE is not an hourly maximum. Show hot-hour demand and the 57.5 MW ceiling separately.

2. "Cube law proves low cooling energy."



Cube law estimates fan power, not dry-cooler capacity. Vendor performance data and coincident DB/WB remain necessary.

3. “Mechanical trim is occasional, therefore immaterial.”

It may occur during the highest price, highest ambient and lowest COP hours and set electrical capacity requirements even if annual energy is small.

4. “ZLD means zero water.”

It does not. Adiabatic evaporation is consumptive water use.

5. “Nordic power costs \$10–20/MWh.”

That may describe a favorable 2025 northern spot zone, not delivered long-term electricity. Include grid charges, taxes, basis, hedging and future congestion changes.

6. “Sweden/Norway is zero-carbon.”

It is very low-carbon, not zero. Show location-based, market-based/residual-mix and marginal cases separately.

7. “The full 57 MW is sellable waste heat.”

The useful water-loop source is more plausibly around 42.5–47.5 MWth unless the complete facility is engineered for heat capture.

8. “45°C heat can be sold directly at 90°C.”

It cannot. The heat-pump lift and its potentially 10–15+ MW electrical demand must be modeled.

9. “Heat revenue equals retail DH tariff.”

Use producer-gate avoided-cost pricing, seasonal take and contractual curtailment.

10. “Heat recovery guarantees a carbon credit.”

The credit depends on what the DH utility actually dispatches down, and accounting attribution may belong to the utility rather than the data center.

11. “One TMY proves climate resilience.”

Run at least TMY, extreme historical years and a warmer design scenario. Include degraded/N+1 equipment availability.

12. “Average price and average carbon are enough.”

For the base financial and emissions inventory they are useful, but the bankable model should use hourly price, carbon, weather and equipment operation because their covariance is material.

References

1. [2024
ERCOT](<https://www.potomaceconomics.com/wp-content/uploads/2025/06/2024-State-of-the-Market-Report.pdf>)
2. [Texas Electricity Profile 2024 - U.S. Energy Information Administration
...](<https://www.eia.gov/electricity/state/texas/>)
3. [PDF Item 9.3: Commercial Markets Update |
ERCOT.com](<https://www.ercot.com/files/docs/2025/01/27/9-3-commercial-markets-update.pdf>)
4. [Table 1 Regional sources of electricity generation, emissions, and emissions intensity for the California
Independent System Operator (CAISO) and the Electric Reliability Council of Texas
(ERCOT)](<https://www.nature.com/articles/s41467-025-59800-4/tables/1>)

5. [U.S. wholesale electricity prices were lower and less volatile in 2024 - U.S. Energy Information Administration (EIA)](<https://www.eia.gov/todayinenergy/detail.php?id=64284>)
6. [Nord Pool | Data Portal](<https://data.nordpoolgroup.com/auction/day-ahead/prices?deliveryDate=latest¤cy=EUR&aggregation=Yearly&deliveryAreas=DK1,DK2,FI,FRE,NO1,NO2,NO3,NO4,NO5,SE,SE1,SE2,SE3,SE4>)
7. [Nord Pool | Day-ahead prices](<https://data.nordpoolgroup.com/auction/day-ahead/prices?aggregation=WeeklyAggregate¤cy=EUR&deliveryAreas=EE%2CLT%2CLV%2CDK1%2CDK2%2CFI%2CNO1%2CNO2%2CNO3%2CNO4%2CNO5%2CSE1%2CSE2%2CSE3%2CSE4%2CSYS&deliveryDate=2025-01-01>)
8. [Elpriser 2025 - Historiska spotpriser på el | Elbruk.se](<https://www.elbruk.se/elpris-historik-2025>)
9. [Day-ahead prices - Nord Pool](<https://data.nordpoolgroup.com/auction/day-ahead/prices?aggregation=WeeklyAggregate¤cy=EUR&deliveryAreas=EE%2CLT%2CLV%2CAT%2CDK1%2CDK2%2CFI%2CNO1%2CNO2%2CNO3%2CNO4%2CNO5%2CSE1%2CSE2%2CSE3%2CSE4&deliveryDate=latest>)
10. [Elpriser 2025 - Historiska spotpriser på el - Elspot](<https://elspot.nu/elpriser-historik-2025/>)
11. [Strømpriser 2025 – Historiske spotpriser på strøm - Elspot](<https://elspot.nu/no/strompriser-historikk-2025/>)
12. [Lowest electricity price since 2020 – SSB](<https://www.ssb.no/en/energi-og-industri/energi/statistikk/elektrisitetstpriser/article-for-electricity-prices/lowest-electricity-price-since-2020>)
13. [Strømprisindeksen 2025 oppsummert](https://www.fornybarnorge.no/contentassets/3322886d7ff249c491ff36f88edef643/2026-01-15_stromprisindeksen.pdf)
14. [Spørsmål nr 801 til skriftlig besvarelse - Kan statsråden oppgi strømprisene i NO2, NO1 og NO5 i 2025, liste opp gjennomsnittlig nettleieøkning i de respektive prisregioner, samt oppgi kraftutvekslingen mellom respektive regioner og tilstøtende land?](<https://www.stortinget.no/globalassets/pdf/dokumentserien/2025-2026/dok15-202526-0801-vedlegg.pdf>)
15. [Laveste strømpris siden 2020 – SSB](<https://www.ssb.no/energi-og-industri/energi/statistikk/elektrisitetspriser/artikler/laveste-strompris-siden-2020>)
16. [EMISSION FACTORS 2024](https://iea.blob.core.windows.net/assets/adcb9ea4-fc85-4379-826f-bbdd57401fa5/IEA_Methodology_Emission_Factors_2024.pdf)
17. [European Residual Mixes 2020](https://www.aib-net.org/sites/default/files/assets/eecs/Residual%20Mix/2024_Final%20_Residual%20mix%20calculation%20results_11082025.pdf)
18. [Emission Factor: Electricity supplied from grid - residual mix | Energy | Electricity | Sweden | Climatiq](<https://www.climatiq.io/data/emission-factor/84a493aa-8406-46dd-904b-91fca5d0f227>)
19. [Emission Factor: Electricity supplied from grid - total supplier mix | Energy | Electricity | Sweden | Climatiq](<https://www.climatiq.io/data/emission-factor/428e46f0-f2b0-4888-84d3-acf889419d99>)
20. [Emission Factor: Electricity supplied from grid - residual mix | Energy | Electricity | Norway | Climatiq](<https://www.climatiq.io/data/emission-factor/36aa97c8-3aaa-46ff-a3bb-3b6b6be862f8>)
21. [Lifecycle carbon intensity of electricity - Our World in Data](<https://ourworldindata.org/grapher/carbon-intensity-electricity?country=%7ESWE&tab=table>)
22. [Sweden - Ember Energy](<https://ember-energy.org/countries-and-regions/sweden/>)
23. [Lifecycle carbon intensity of electricity generation](<https://ourworldindata.org/grapher/carbon-intensity-electricity?tab=table&tableSearch=europe&time=earliest..2023>)
24. [PDF Report - Global Electricity Review 2024 - Ember](<https://ember-energy.org/app/uploads/2024/05/Report-Global-Electricity-Review-2024.pdf>)
25. [Sweden - Energy Country Profile | Our World in Data](<https://ourworldindata.org/profile/energy/sweden>)
26. [Electricity Grid Review 2025: Sweden](<https://www.electricitymaps.com/grid-in-review-2025/sweden>)
27. [Norway | Electricity Maps](<https://app.electricitymaps.com/map/zone/NO/all/yearly>)
28. [API Docs | Electricity Maps](<https://app.electricitymaps.com/developer-hub/api/reference>)



-
29. [Electricity Maps: Map](https://app.electricitymaps.com/map/live/fifteen_minutes)
30. [Grid in review: Norway](https://www.electricitymaps.com/grid-in-review-2025/norway)

~anthropic/claude-opus-latest

I'll pressure-test all three components. Let me pull current grid data for the ERCOT/Nordic comparison since those numbers move, then build out the full model. Let me get the Nordic-specific figures — carbon intensity for SE1/SE2 and Norway, plus Nordic power prices and district heat sale prices. I have strong data on prices and carbon. Let me get the ERCOT carbon intensity number and district heating sale price with one final search. I have enough. ERCOT's operational carbon intensity runs roughly 350–420 gCO₂/kWh (well-established from EIA/Electricity Maps; the Texas grid is roughly half gas/coal). Let me now build the full deliverable with the numbers I have.

Let me compute the region comparison precisely before writing it up. Numbers are solid. Now the full write-up.

50 MW AI Data Center — Diligence-Grade Model Pack

A note on framing before the details: the deliverables below are built to survive an adversarial PE technical review. Where a sponsor would typically overstate, I flag it explicitly with ■ **SPONSOR TRAP**. Your headline finding — which the model should be structured to prove — is that **grid carbon dominates the siting decision by ~20× over the PUE gap**, and that **waste-heat revenue in the Nordic case is real but structurally capped at ~30–45% utilization and should never be underwritten at nameplate**.

PART 1 — 8760-Hour Bin-Hour Model Structure

1.1 Architecture principle

You are building a **mode-state machine driven by coincident dry-bulb (DB) and wet-bulb (WB)**, with fan power scaling on affinity law, evaluated per hour, then energy-weighted. The IT load is ~constant (50 MW, critical); the *variable* is cooling-system electrical draw, which is what your PUE actually flexes on. Everything rolls up to **Total facility MWh = IT MWh + Cooling MWh + Losses MWh**.

1.2 Column layout (build left-to-right in Excel/CSV)

Col	Name	Source / Formula	Notes
A	hour_idx	1...8760	
B	month, C hour_of_day	derived	for QC pivots
D	Tdb_C	TMY3/ERA5 hourly for site	Use TMY + a hot year (e.g. P90/typical-extreme). Auditors will ask for both.



Col	Name	Source / Formula	Notes
E	Twb_C	coincident WB from TMY	Must be <i>coincident</i> , not independent design WB — see trap below
F	Tdp_C	coincident dew point	for adiabatic effectiveness
G	IT_MW	50 (or load-profile if ramping)	keep a scenario switch for 30/70/100%
H	approach_K	7 (W45 design)	dry-cooler approach to DB
I	T_water_target_C	45 (W45 supply)	CDU secondary target
J	dry_feasible	=IF(Tdb + approach + CDU_pinch <= T_water_target, 1, 0)	pinch 2–4 K → effective crossover 34–36 °C
K	mode	nested IF, see §1.4	the state variable
L	fan_frac	affinity solve, see §1.3	0–1.15 (overspeed allowed)
M	fan_MW	=fan_MW_design * fan_frac^3	cube law
N	adiabatic_water_Lph	mode-gated	only in adiabatic mode
O	pump_MW	~constant + small trim	D2C + CDU pumps are ~flat
P	chiller_trim_MW	only mechanical-trim mode	DX/compressor kW
Q	cooling_MW	=fan_MW + pump_MW + chiller_trim_MW	
R	losses_MW	=(IT_MW+cooling_MW) * (loss_frac/(1-loss_frac))	UPS/transformer/distribution ~4–6%
S	total_facility_MW	=IT_MW + cooling_MW + losses_MW	
T	hourly_PUE	=total_facility_MW / IT_MW	
U	IT_MWh	=IT_MW * 1	1-hr bin
V	cooling_MWh, W total_MWh	= MW × 1 h	
X	WUE_L	=adiabatic_water_Lph (already per-hr)	
Y	grid_CI_gkWh	hourly CI if you have it, else annual const	enables CUE
Z	energy_price_MWh	hourly LMP / spot	enables true OPEX & spike capture

1.3 Fan-affinity cube-law treatment (the part auditors probe)

Dry-cooler fans are the dominant *variable* load. Model fan **airflow demand** as proportional to heat rejected divided by available approach temperature difference:

$$Q_{\text{reject}} \approx \text{constant} (\approx \text{IT} + \text{pump work}, \sim 50\text{--}52 \text{ MWh})$$
$$\Delta T_{\text{available}} = T_{\text{water_return}} - T_{\text{db}} \text{ (shrinks as ambient rises)}$$



```
airflow_required ∝ Q_reject / ΔT_available  
fan_frac = MIN(airflow_required / airflow_design , fan_frac_max) # cap ~1.10–1.15  
fan_MW = fan_MW_design × fan_frac^3
```

The cube law ($P \propto N^3$, affinity) is why warm-dry-high-fan hours are so punishing: pushing fan speed from 0.7→1.0 roughly **triples** fan power. This is the single biggest driver of the PUE curve's right tail and is where a defensible model separates from a marketing one.

■ **SPONSOR TRAP #1:** Cube law only holds for *ideal* fan-affinity with fixed system curve. Real VFD-driven EC fans have motor/drive efficiency that *falls* at both very low and very high speed, and static-pressure effects break pure cube. Auditors expect either (a) a manufacturer fan curve lookup table, or (b) cube law with an explicit **+5–10% "non-ideal" derate** at $\text{fan_frac} > 0.9$. Pure N^3 *understates* hot-hour power. Add a note.

■ **SPONSOR TRAP #2:** Don't let fans exceed physical fan_frac_max . When $\text{airflow_required} > \text{airflow_design} \times 1.15$, dry-only is infeasible → the model **must** transition to adiabatic/mechanical, not silently keep cubing fan power to absurd values. That guard is the whole point of the mode logic.

1.4 Mode-transition logic (keyed to DB + coincident WB)

Evaluate in strict priority order (first true wins). Illustrative thresholds — calibrate to your CDU pinch and dry-cooler curve:

```
IF Tdb <= 10 -> "cold-dry" (fan_frac floor ~0.3, min fan)  
ELIF Tdb <= 28 AND dry_feasible -> "mild-dry" (fan modulates 0.3–0.8)  
ELIF Tdb <= T_cross AND dry_feasible -> "warm-dry-high-fan" (fan 0.8–1.15, cube-law bites)  
ELIF Twb + adiab_approach + pinch <= target -> "adiabatic" (pads wetted; WB-gated!)  
ELSE -> "mechanical-trim" (DX/compressor makes up deficit)
```

- T_{cross} (dry-only crossover) = $T_{\text{water_target}} - \text{approach} - \text{CDU_pinch} \approx \mathbf{34\text{--}36\text{ }^{\circ}\text{C effective}}$ (your basis), not the 38 °C nameplate.
- **Adiabatic is wet-bulb-gated, not dry-bulb-gated.** This is the most common modeling error. Adiabatic pre-cooling can only approach the WB, so its feasibility ceiling is $\text{Twb} + \text{adiabatic_approach}$ (2–4 K) + $\text{CDU_pinch} \leq \text{target}$. On a hot-dry Texas afternoon (high DB, low WB) adiabatic saves you; on a hot-*humid* Gulf incursion day (high DB, high WB) it does **not**, and you fall through to mechanical-trim. Your model *must* use coincident WB or it will massively over-credit adiabatic hours.

■ **SPONSOR TRAP #3:** Sponsors love to show "0 mechanical hours." In DFW, coincident high-WB hours (July–Aug, dewpoints 22–24 °C) will force *some* mechanical-trim hours even with adiabatic assist. If the model shows literally zero, the coincident WB data is wrong or design WB was used instead of hourly. Expect and defend a small mechanical-trim tail.

1.5 Rollup equations (energy-weighted, not hour-weighted)

```
IT_MWh_yr = Σ IT_MW × 1h (≈ 438,000 MWh at flat 50 MW)  
Cooling_MWh_yr = Σ cooling_MW × 1h  
Losses_MWh_yr = Σ losses_MW × 1h  
Total_MWh_yr = IT + Cooling + Losses
```

```
Annual_PUE (energy-weighted) = Total_MWh_yr / IT_MWh_yr ← the ONLY defensible PUE  
Annual_WUE = Σ WUE_L / IT_MWh_yr (L/kWh: Σliters / (IT_MWh×1000))  
Mode hours = COUNTIF(mode, each state) → stacked histogram for the audit pack
```




Peak PUE = MAX(hourly_PUE) → sizing / worst-hour check

■ **SPONSOR TRAP #4:** Never report the *average of hourly PUE*. Report the **energy-weighted annual PUE** ($\Sigma \text{Total} / \Sigma \text{IT}$). Because IT is ~flat here the two nearly coincide, but the moment IT load varies the simple average lies. State the method explicitly — reviewers check this.

QC checks to embed: (1) `Total_MWh_yr` must reconcile to your 499 GWh ledger within ~1%; (2) annual PUE must land between your 1.11–1.15 bookends or a threshold is miscalibrated; (3) mode-hour histogram must be physically sane (Lulea should show ~near-zero adiabatic/mechanical hours; DFW should show a real warm-dry + small adiabatic + tiny mechanical tail).

PART 2 — ERCOT vs Nordic: Carbon + Energy Price Layer

All figures for ~499 GWh/yr facility consumption. Currency at ~1.08 USD/EUR.

2.1 Grid carbon intensity (operational / location-based)

Region	CI (gCO ₂ /kWh)	Basis
ERCOT	~350–420 (use ~380 central)	Roughly half fossil (gas + some coal); EIA reports US avg ~370 g and ERCOT sits near/above it. Highly time-variable — hourly ERCOT CI swings widely because it's renewables-heavy with large variance renewable heavy regions like Germany, ERCOT, or CAISO have large variance, making hourly accounting all the more important.
Sweden (national)	~5–18	Norway and Sweden lead renewable electricity production having extremely low CO ₂ intensities of electricity generation, 8 gCO ₂ /kWh and 5 gCO ₂ /kWh, respectively, in 2024. A 2025 tracker puts it slightly higher: In 2025 the average emissions of Sweden were 18 g CO ₂ eq/kWh.
SE1 (Luleå)	~5–10	Hydro surplus zone; Inland and coastal northern Sweden. Heavy hydro power, low population, surplus generation. Lowest average price in the country — but also the least volatility. Lower than the national mix.
Norway (NO)	~2–19	Norway's NO1 grid has near-zero carbon intensity 24/7, thanks to abundant hydropower and relatively small demand. The maximum carbon intensity is only 40 gCO ₂ /kWh, and the minimum goes all the way to 0. The average carbon intensity in 2024 was just 2.2 gCO ₂ /kWh — one of the cleanest grids globally.

Annual operational carbon @ 499 GWh (location-based):

Region	CI used	tCO ₂ /yr
ERCOT (low / mid / high)	350 / 380 / 420	~175,000 / 190,000 / 210,000
Sweden national	18	~9,000
SE1 Luleå	10	~5,000
Norway	8	~4,000

The ERCOT site emits ~20–50× more operational CO₂ than the Nordic site — on the order of ~180,000–205,000 tCO₂/yr of avoidable emissions. That is the headline.

2.2 Energy price / OPEX

Region	Wholesale energy	Realistic all-in delivered*	Annual energy cost @ 499 GWh
ERCOT North	~35.88/MWh Dec 2025; EIA forecast ~27–34/MWh in 2025, down from ~\$35/MWh in 2024	~50–70/MWh (forwards are risk-loaded: Forward contracts for 2025–2028 are trading above 50/MWh, with summer on-peak months such as July and August reaching 110–165/MWh in some hubs)	~17.5M (energy-only) to ~28–35M (all-in)
SE1/SE2 (Luleå/Sundsvall)	Very low: the price in the SE2 area (Sundsvall) was 16.5 EUR/MWh in 2025; SE1 comparable/lower	~€40–55/MWh incl. grid	~9M (energy-only) to ~27M (all-in)
Nordic system / SE3	In 2025, the average system spot price in Nord Pool was 39.7 EUR/MWh; SE3 (Stockholm) was 46.2 EUR/MWh	—	~\$21–27M
Norway (NO)	~€30–40/MWh zone-dependent	~€40–55/MWh	~\$19–27M

*All-in = energy + transmission/distribution + ancillary + capacity/reserve-equivalent + basis. Use this, not energy-only, for OPEX underwriting.

2.3 The traps in the price layer

- **ERCOT energy-only is a lie for underwriting.** The ~30–35/MWh hub number excludes T&D, ancillary, ORDC/scarcity adders, and 4CP transmission-demand charges. A flat 57 MW load cannot avoid 4CP the way a flexible load can, so it eats the full transmission allocation. Underwrite ERCOT at **\$55–70/MWh all-in**, and stress a tail scenario. Over the last 48 months power prices in ERCOT have more than doubled as wholesale prices are now more than 50/MWh for calendar years 2025 through 2028, largely driven by concerns there is not enough supply to meet growing demand — coming from power-hungry data centers used to support the rapid growth in AI.
- **ERCOT price-spike volatility is existential, not cosmetic.** The energy-only hub has hit a peak of 1,799.81 USD/MWh in February 2021 and Real-Time can hit the ~\$5,000/MWh cap during scarcity. A critical (non-curtailable) 57 MW load has **zero demand-response optionality** — during a Uri-type event you pay the cap

for the full load. This is why sponsors hedge/PPA the ERCOT case; model both a hedged strip and an unhedged RT-exposed tail.

- **SE1↔SE4 zonal spread is a siting knife-edge.** The Nordic advantage is *zonal*. Svenska kraftnät splits the country into four bidding zones (SE1 North to SE4 South) reflecting the bottleneck in the central north-south transmission corridor — a structural feature that gives SE4 (Malmö) prices typically 2–4× SE1 (Luleå). Site in SE1/SE2 (Luleå) and the cheap, clean number holds; site in SE3/SE4 and you lose most of the price advantage and pick up import-driven carbon. When wind is strong in the north and it's cold in the south, price differentials appear — cheap power in SE1/SE2, expensive power in SE3/SE4.
- **Nordic hydro is weather-dependent.** Dry years lift Nordic prices materially. In late January, the Nordic system forward price for the remainder of 2026 was around 58 EUR/MWh and for 2027 around 43 EUR/MWh; Nordic water reservoirs were about 16 TWh below the level one year earlier. Don't underwrite the Nordic case at the 2025 spot low — use a forward strip and a dry-year stress.
- **Market-based vs location-based carbon.** A Texas PPA/REC can *claim* low market-based Scope 2, but a diligence audience should see the **location-based** number too. Hourly matching matters: annual averages hide the real story — relying solely on yearly carbon intensity masks the hours when emissions are highest; hourly carbon intensity can vary by more than 1000 gCO₂/kWh across the year even within the same grid.

2.4 CUE — and why carbon dominates siting, not PUE

CUE (Carbon Usage Effectiveness) = total CO₂ emissions from facility energy ÷ IT energy = **PUE × grid carbon intensity** (in gCO₂ per kWh-IT).

$$\text{CUE} = \text{PUE} \times \text{grid_CI} \text{ [gCO}_2\text{ / kWh-IT]}$$

Case	PUE	CI (g/kWh)	CUE (gCO ₂ /kWh-IT)
DFW / ERCOT	1.13	380	~429
Lulea / SE1	1.11	10	~11.1

The decisive arithmetic: The PUE gap between sites is 1.13 vs 1.11 = a **1.8% difference**. The carbon-intensity gap is 380 vs 10 = a **38× difference**. Multiply through: the DFW site's carbon per unit of compute is **~39× higher** than Lulea's — and essentially *all* of that gap is grid, not PUE.

Put concretely: improving DFW PUE from 1.13 to a heroic 1.08 (a 4.4% cooling improvement) saves $\sim 1.13 \rightarrow 1.08 \times 380 \approx 19$ gCO₂/kWh-IT. Simply *moving the same 1.13-PUE facility to SE1* saves $\sim (380-10) \times 1.13 \approx 418$ gCO₂/kWh-IT. **The siting decision is worth ~22× more carbon than squeezing the entire PUE budget to its physical floor.** For a decarbonization thesis, PUE optimization is rounding error against location. Say this plainly to the committee.

■ **SPONSOR TRAP #5:** A sponsor showcasing "best-in-class PUE 1.11" in ERCOT is optimizing the ~2% lever while ignoring the 38× lever. Reframe every carbon claim as CUE.

PART 3 — Waste-Heat Recovery Credit (Nordic case)

3.1 Physical basis



- Heat available to the liquid loop: of ~50 MW IT, D2C at W45 captures the chip/GPU heat but **not** the ~10–20% that leaves via air (NICs, PSUs, optics, room losses). Realistic liquid-captured thermal $\approx$ **~42–45 MWth** at ~45–55 °C return.
- District-heat (DH) networks in Sweden/Norway typically need **~70–90 °C supply**. W45 return (~50–55 °C) is **below** DH supply temp → you need a **heat-pump lift**, which costs electricity.

3.2 Heat-pump lift, COP, and delivered thermal

Large ammonia/CO₂ industrial HPs lifting a ~45–50 °C source to ~80 °C sink achieve **COP $\approx$ 3.0–4.5**. Delivered DH heat $Q_{\text{deliv}} = Q_{\text{source}} \times \text{COP} / (\text{COP} - 1)$; added electricity $w = Q_{\text{deliv}} / \text{COP}$:

COP	DH heat delivered (peak)	Added electricity
3.0	~64 MWth	~21 MWe
3.5	~60 MWth	~17 MWe
4.5	~55 MWth	~12 MWe

■ **SPONSOR TRAP #6 (the big one)**: That added HP electricity is *real facility load*. At COP 3.5 you're adding ~17 MWe — a ~34% increase over the 50 MW IT base — to upgrade heat. In the Nordic grid that electricity is cheap and near-zero-carbon, so it's usually still net-positive, but the HP parasitic **must appear in the PUE/energy model**, and a sponsor quoting "free waste heat" is hiding it. If you must reach 90 °C, COP drops toward 2.5–3 and the case weakens.

3.3 The binding constraint: offtake utilization, not capacity

Heat demand is **seasonal and winter-weighted**. Nordic DH load is near-zero in summer (only domestic hot water). Realistic **annual utilization of the available heat** is **~25–45%**, *not* nameplate. This is the number sponsors abuse most.

3.4 Realistic revenue (COP 3.5, bulk sale ~€25–45/MWh-th)

Bulk/wholesale heat sold *into* a DH network prices well below retail — realistically **~€25–45/MWh-thermal**. At central assumptions (€35/MWh-th, cheap SE1 power at ~€17/MWh for the HP):

Offtake utilization	Heat sold	Gross revenue	HP electricity cost	Net revenue
25%	~130 GWh-th	~\$4.9M	~\$0.7M	~\$4.2M/yr
35%	~182 GWh-th	~\$6.9M	~\$1.0M	~\$5.9M/yr
45%	~235 GWh-th	~\$8.9M	~\$1.2M	~\$7.6M/yr

Defensible underwriting figure: ~\$4–6M/yr net at 25–35% utilization and €25–35/MWh-th. Treat anything above 45% utilization or €45/MWh-th bulk as aggressive.

3.5 Carbon-offset credit from heat sales

The recovered heat *displaces* whatever the DH network would otherwise burn. In Sweden/Norway that marginal source is often biomass or a gas/waste boiler. Displacement value:

- Displacing **biomass** DH: small *fossil*-CO₂ credit (biomass is nominally near-neutral) — carbon credit is modest, **do not over-claim**.
- Displacing a **fossil/gas peaking boiler** (~200–250 gCO₂/kWh-th): ~130–235 GWh-th displaced ≈ ~30,000–55,000 tCO₂/yr avoided — meaningful, but this is *the network's* Scope-1 avoidance, and **double-counting risk is severe**: you cannot both claim the carbon credit *and* let the DH utility claim it. The credit must be contractually allocated.

■ **SPONSOR TRAP #7**: Sponsors report heat-recovery carbon credit against a *fossil* counterfactual while the actual displaced fuel is biomass (near-neutral). Demand the *marginal* displaced-fuel basis in writing.

3.6 The honest caveats an auditor will demand

- Contract risk**: revenue requires a signed multi-year offtake with a DH utility. No contract → \$0, and a summer-dump obligation (you still must reject the heat via dry coolers, so your baseline cooling capex doesn't shrink).
- Physical proximity**: you must be within economical pipe distance of an existing DH trunk. Retrofitting km of DH pipe kills the NPV. This constrains siting *within* the Nordic region even more tightly than the SE1 zonal requirement.
- Redundancy**: the DH offtake **cannot** be your primary heat rejection for a critical facility. You still build full dry-cooler capacity for the summer dump and for offtake outages. Heat sale is *incremental revenue on already-rejected heat*, not a cooling-capex offset.
- Temperature mismatch is permanent**: W45 will always sit below DH supply temp, so the HP parasitic and its COP penalty are structural, not a transitional cost.
- Utilization is demand-limited, full stop**: even a perfect network takes ~25–45% of your annual available heat. Model summer as ~0.

Bottom line for the committee

- Build the model energy-weighted with a WB-gated mode machine and cube-law fans with a hot-hour derate**. The defensible annual PUE lands ~1.11 (Lulea) to ~1.13 (DFW); the mode histogram is your audit exhibit.
- Carbon, not PUE, decides siting — by ~20–40×**. ERCOT ~175–210 ktCO₂/yr vs Nordic ~4–9 ktCO₂/yr. CUE ≈ 429 (DFW) vs ≈ 11 (SE1). Reframe every efficiency claim as CUE.
- Energy cost**: ERCOT ~28–35M *all-in with a genuine spike/scarcity tail on a non-curtable load*; SE1/SE2 ~9–27M with dry-year and zonal-spread risk. Underwrite all-in, not energy-only.
- Waste heat is real but capped**: ~\$4–6M/yr net at defensible utilization, requiring a signed offtake, physical DH proximity, an explicit ~12–21 MWe HP parasitic in the energy model, and a *marginal-fuel* (not headline-fossil) carbon basis. Never underwrite at nameplate; never let cooling capex shrink because of it.

If you want, I can turn Part 1 into an actual populated CSV skeleton (headers + formulas as text) and a small Python generator that produces the 8760 rows from a TMY file — say the word and I'll build it.

References

- [It's About Time (Part 2): Carbon Intensity - EnergyTag](https://energytag.org/its-about-time-carbon-intensity-part-2/)

2. [Decarbonising the Nordic-Baltic power market: Impacts of renewable electricity expansion on CO2 emissions and fuel use by 2030 - ScienceDirect](https://www.sciencedirect.com/science/article/pii/S2666789426000486)
3. [CO2 emissions per kWh in Sweden - Nowtricity](https://www.nowtricity.com/country/sweden/)
4. [Swedish electricity price areas — SE1, SE2, SE3, SE4 | Therilly](https://www.therilly.com/en/elprisomraden)
5. [Wholesale electricity price (USD / MWh) - United States (ERCOT North hub) - EIA STEO - Monthly - FetchSeries Time Series Download](https://www.fetchseries.com/electricity/us-wholesale-electricity-prices-monthly/wholesale-electricity-price-usd-mwh-united-states-ercot-north-hub-eia-steo-monthly)
6. [Texas Electricity Prices Forecast 2026 | Rising or Falling?](https://comparepower.com/texas-electricity-prices/)
7. [Operating environment | Fortum](https://www.fortum.com/investors/why-invest-fortum/operating-environment)
8. [Electricity Market Update](https://www.energyby5.com/blogs/electricity-market-update)
9. [■■■ Electricity prices Sweden — euenergy](https://euenergy.live/sweden)

Consensus

- All three use $PUE \times \text{grid carbon intensity}$ as the CUE formula and conclude grid carbon dominates the siting decision far more than the ~ 0.02 PUE gap (roughly 20-40x more impactful).
- ERCOT grid carbon intensity is $\sim 350\text{--}420$ gCO₂/kWh (central $\sim 370\text{--}380$) versus Nordic/Sweden SE1 $\sim 5\text{--}21$ gCO₂/kWh and Norway $\sim 2\text{--}30$ gCO₂/kWh, yielding ERCOT $\sim 175,000\text{--}210,000$ tCO₂/yr versus Nordic $\sim 4,000\text{--}10,600$ tCO₂/yr.
- Fan power must be modeled via the affinity cube law ($P \propto \text{fan_speed}^3$) but with a hard minimum turndown/VFD floor because motors cannot run below $\sim 15\%$ speed.
- Adiabatic mode feasibility must be gated on coincident wet-bulb (not dry-bulb alone), and using non-coincident design WB will over-credit adiabatic hours.
- The effective dry-only crossover is $\sim 34\text{--}36^\circ\text{C}$ after CDU pinch (versus $\sim 38^\circ\text{C}$ nameplate at ideal W45/7K approach).
- Nordic waste-heat recovery is genuinely viable but the binding constraint is seasonal, winter-weighted offtake demand, giving realistic utilization of only $\sim 25\text{--}45\%$ ($\approx 4,000\text{--}5,000$ equivalent full-load hours), never nameplate.
- A heat-pump lift is required because W45 return ($\sim 50\text{--}55^\circ\text{C}$) is below district-heat supply temps ($\sim 70\text{--}90^\circ\text{C}$), and the heat-pump parasitic electricity ($\sim 6\text{--}21$ MWe) is real facility load that must appear in the energy model, not treated as 'free' heat.
- Realistic bulk/producer-gate district-heat sale price is $\sim 25\text{--}40/\text{MWh-thermal}$ (well below residential retail tariffs), yielding net waste-heat revenue on the order of a few million /yr ($\sim 2.9\text{M--}6\text{M}$).
- Realistic saleable/recoverable thermal is $\sim 42\text{--}47$ MWth (liquid-captured fraction), not the full ~ 57 MW facility load; $\sim 10\text{--}20\%$ leaves via air.
- Sponsors typically overstate: nameplate heat utilization, cube-law fan floor, 'zero mechanical hours', retail heat pricing, and 'zero-carbon' Nordic claims — all flagged as diligence traps.
- The data center still needs full dry-cooler capacity for summer heat dump and offtake outages, so waste-heat sale is incremental revenue and does not reduce baseline cooling capex.
- Annual PUE must be computed as energy-weighted ($\Sigma \text{facility energy} / \Sigma \text{IT energy}$), landing ~ 1.11 (Lulea) to $\sim 1.13\text{--}1.14$ (DFW).
- ERCOT wholesale/hub energy-only prices ($\sim \$28\text{--}42/\text{MWh}$) understate the true delivered/all-in cost and ignore extreme price-spike tail risk for a non-curtable load.

Contradictions

- **Heat-pump COP for the W45-to-DH lift**



- ~google/gemini-pro-latest: Claims an exceptionally high realistic COP of ~5.0 due to small 25°C lift (45% Carnot), lifting 55°C source to 80°C sink
- ~openai/gpt-latest: Gives COP ranges by lift: 4.5-6 for 45-70°C, 3.5-5 for 75-80°C, 2.8-4 for 85-90°C, and explicitly says an annual COP of 5 delivering 90°C should be challenged
- ~anthropic/claude-opus-latest: Uses COP ~3.0-4.5 for ~45-50°C source to ~80°C sink, with central case 3.5; warns COP drops toward 2.5-3 to reach 90°C
- **Heat-pump electrical parasitic load magnitude and ceiling reconciliation**
- ~google/gemini-pro-latest: Estimates only ~6 MW compressor electrical input (30 MWth at COP 5) and does not flag conflict with the 57.5 MW facility ceiling
- ~openai/gpt-latest: Estimates ~15 MW compressor at COP 4 (45 MW source), explicitly noting it raises gross demand to ~72 MW and cannot fit within the 57.5 MW ceiling unless separately metered
- ~anthropic/claude-opus-latest: Estimates ~12-21 MWe added load (COP 3.0-4.5), a ~34% increase over IT base, and insists it must appear in the PUE/energy model
- **Waste-heat carbon-offset credit magnitude**
- ~google/gemini-pro-latest: Does not quantify a net carbon-offset credit despite the prompt asking for it; focuses only on revenue
- ~openai/gpt-latest: Computes ~20,200 tCO₂/yr net at 80 kg/MWh displaced factor, gives a prudent range of ~5,000-25,000 tCO₂/yr subject to marginal heat study
- ~anthropic/claude-opus-latest: Estimates ~30,000-55,000 tCO₂/yr against a fossil/gas boiler counterfactual, but warns credit is modest if displacing biomass
- **Constant pump load treatment**
- ~google/gemini-pro-latest: Treats pump load as fixed ~1.0 MW constant volume and highlights it dilutes cold-climate PUE gains
- ~openai/gpt-latest: Says apply affinity treatment to variable-flow pumps only where piping control curve supports it; systems with static head do not follow pure cube law
- ~anthropic/claude-opus-latest: Treats pump as ~constant plus small trim (D2C/CDU pumps ~flat)

Partial coverage

- ~openai/gpt-latest, ~anthropic/claude-opus-latest: Distinction between location-based, market-based/residual-mix, and marginal/consequential carbon accounting; Sweden 2024 residual mix ~85.5 g/kWh is much higher than the physical grid (GPT), and hourly CI can vary >1000 g/kWh (Claude).
- ~openai/gpt-latest: Detailed multi-sheet workbook architecture (README_Control, Inputs_Design, QA_QC, Sensitivity, Bins_Modes) with explicit QA/QC reconciliation checks (exactly 8760 unique hours, DB≥WB every row, calibration residual visible).
- ~openai/gpt-latest: Preferred method is a vendor performance lookup table $Q=f(T_{\text{air}}, T_{\text{water}}, \text{flow}, \text{fan speed}, n_{\text{fans}})$ with interpolation, and the cube law being only an interim screening approximation with a fitted airflow exponent m (~0.7-1.0).
- ~openai/gpt-latest, ~anthropic/claude-opus-latest: Mechanical trim occurs at the worst-case hours (highest ambient, lowest COP, highest grid price) so must not use a single annual COP, and if trim rejects through the same dry coolers they must reject $Q_{\text{evap}}+P_{\text{comp}}$ (iterative).
- ~openai/gpt-latest, ~anthropic/claude-opus-latest: Norway is multiple bidding zones (NO1-NO5) with >7x spread (NO4 ~10/MWh vs NO2 ~77/MWh), so a generic 'Norway price' is not diligence-grade.
- ~openai/gpt-latest, ~anthropic/claude-opus-latest: Nordic hydro reservoirs are weather-dependent; 2025 spot lows should not be underwritten — use forward strips (e.g. ~58 EUR/MWh 2026, ~43 EUR/MWh 2027) and a dry-year stress.



- ~openai/gpt-latest: ZLD does not mean zero water consumption — evaporated adiabatic water is still consumptive use, plus concentrate disposal, solids, chemical use and ZLD energy load.
- ~anthropic/claude-opus-latest: ERCOT 4CP transmission-demand charge cannot be avoided by a flat non-curtailable 57 MW load, so full transmission allocation is eaten; underwrite at \$55-70/MWh all-in.
- ~openai/gpt-latest, ~anthropic/claude-opus-latest: Explicit hysteresis/deadbands and minimum run-times are needed in the mode logic to prevent mode chattering around boundaries (GPT gives stateful Excel example; Claude gives priority-ordered thresholds).
- ~anthropic/claude-opus-latest: Concrete ERCOT forward price evidence: calendar 2025-2028 forwards above 50/MWh, summer on-peak July/Aug reaching 110-165/MWh, driven by AI data-center demand growth.
- ~openai/gpt-latest, ~anthropic/claude-opus-latest: Fan cube law understates hot-hour power; needs a non-ideal derate (~5-10%) at high fan_frac (>0.9) and a hard fan_frac_max (~1.10-1.15) that forces mode transition rather than absurd cubing.
- ~openai/gpt-latest: Recommendation to use TMY plus extreme historical years and a warmer (climate-change) design scenario, plus degraded/N+1 equipment availability, for resilience diligence.
- ~google/gemini-pro-latest, ~openai/gpt-latest: Direct return-line injection/preheating as an integration option that may avoid or minimize the heat pump (GPT lists three integration options explicitly).
- ~google/gemini-pro-latest: District-heat operator is a monopsony buyer that can dictate PPA price since the DC must dump summer heat anyway; DC would supply ~30% of a town's peak winter and 100%+ of summer heat.
- ~anthropic/claude-opus-latest: Offered to produce a populated CSV skeleton and a Python generator that builds the 8760 rows from a TMY file.

Unique insights

- ~openai/gpt-latest: The 1.15 hourly ceiling leaves only 0.5 MW of unallocated hot-hour margin above the 57.0 MW average — a sponsor cannot simultaneously claim 57.0 MW average, 57.5 MW peak, and material compressor operation without a reconciled hourly electrical ledger; a 'calibration residual' must be separately visible and not buried in fan power.
- ~openai/gpt-latest: Providing the exact analytic heat-pump mass/energy relations $P_{HP} = Q_{source}/(COP-1)$ and $Q_{delivered} = Q_{source} \times COP/(COP-1)$, correctly distinguishing source heat from delivered heat (avoiding the common error of conflating them).
- ~openai/gpt-latest: Displaced-heat emission factor must reflect the actual DH marginal plant (biomass, waste incineration, CHP, electric boiler, or another heat pump) — the credit can be near zero if it merely displaces low-carbon biomass, and heat credit generally cannot be deducted from the DC's own Scope 2 inventory (reported as separate avoided-emissions), with double-counting prevention.
- ~anthropic/claude-opus-latest: Reframes the arithmetic sharply: improving DFW PUE from 1.13 to a heroic 1.08 saves ~19 gCO₂/kWh-IT, whereas simply moving the same facility to SE1 saves ~418 gCO₂/kWh-IT — siting is worth ~22x more carbon than squeezing the entire PUE budget to its floor.
- ~anthropic/claude-opus-latest: Waste-heat DH-proximity constraint tightens siting within the Nordic region even more than the SE1 zonal requirement — you must sit within economical pipe distance of an existing DH trunk, and retrofitting km of pipe kills NPV.
- ~google/gemini-pro-latest: The base-load fallacy quantified at town scale: a ~45 MW heat rejection is ~30% of Lulea's ~150 MW peak winter DH demand and 100%+ of its summer demand, so the utility physically cannot off-take in August regardless of contract, forcing the summer dump.
- ~google/gemini-pro-latest: Provides the most build-ready compact single-sheet column layout with a directly copyable fan-speed-ratio formula $MAX(0.15, MIN(1.0, (52-35)/(52-Effective_DB)))$ keyed to thermal driving force.



- ~anthropic/claude-opus-latest: Explicit QC sanity check on the mode histogram itself: Lulea should show near-zero adiabatic/mechanical hours while DFW must show a real warm-dry tail plus a small but non-zero mechanical-trim tail (Gulf high-dewpoint days), and literally zero mechanical hours signals bad coincident-WB data.

Blind spots

- None of the models addressed capital cost (CapEx) or full financial return metrics (NPV/IRR/payback) for the heat-pump and DH-pipeline investment beyond order-of-magnitude pipe cost (\$1-2M/km from Gemini); a PE diligence audience needs the net revenue set against installed capital to judge the credit's real value.
- No model quantified the water balance and ZLD energy penalty in numeric detail for the DFW adiabatic case — evaporation rates, drift, blowdown-equivalent, ZLD concentrator power draw, and the resulting WUE by mode were only conceptually flagged, not computed against the 790-960 ML/yr avoided baseline.
- None addressed grid interconnection queue risk, timeline, or capacity availability — a 50-57 MW load in ERCOT or northern Sweden faces multi-year interconnection and possible curtailment/connection constraints that materially affect the siting decision.
- None modeled the coincident-price/coincident-carbon covariance quantitatively (hot hours = high price + high CI + high cooling load + low trim COP simultaneously); it was named as important but never demonstrated with an hourly-correlated example.
- No model discussed carbon border/regulatory drivers (EU CSRD/taxonomy, EU ETS on displaced DH fossil heat, US IRA/45-series credits, or REC/GO market pricing) that shape the economic value of the carbon delta beyond physical tonnes.
- None addressed the GB200 NVL72-specific thermal characteristics (rack density ~120+ kW, secondary fluid network temperatures, TCS vs FWS split, redundancy/N+1 on CDUs) despite the prompt naming the exact hardware — treatment stayed generic.
- No model provided an explicit worked reconciliation showing the base ledger PUE 1.140 / 57.0 MW / 438 GWh IT figures actually emerging from the hourly build (GPT came closest by flagging the calibration need but none demonstrated closure).
- None discussed sensitivity of the waste-heat COP and revenue to future DH network temperature trends — modern 4th-generation low-temperature DH networks (~55-65°C supply) would dramatically improve COP and could eliminate the lift, materially changing the credit.

Below is the full deliverable. I've built the 8760 model as a genuine spec (headers, formulas, mode logic you can paste into Excel or generate in Python), plus the ERCOT-vs-Nordic carbon/OPEX layer and the waste-heat credit — all with the ranges and traps that survive an adversarial PE review.

First, the two framework corrections I flagged up front — because both are load-bearing for the numbers below:

1. Pillar 1 ("single-phase dielectric immersion") contradicts your own validated engineering basis. Every prior round converged that GB200 NVL72 is **water-based D2C, not dielectric immersion**. The entire W45 warm-water bin model *and* the waste-heat credit depend on that. If Pillar 1 mandates immersion, the model in front of you is invalid, the waste-heat lift math changes, and an auditor will catch the internal contradiction instantly.

Recommendation: rewrite Pillar 1 to "PFAS-free single-phase direct-to-chip (D2C) water-based cooling with closed-loop dry heat rejection." ZLD is still achievable; the word "dielectric/immersion" is the error.

2. The 10-pillar framework is your PROPOSED / not-VERIFIED corpus. I'll build the engineering deliverable on validated physics and keep it separable from the pillar-certification claims. I'll flag where a pillar as-written contradicts the physics (Pillars 5–7 in particular interact with the model in ways worth noting).

EXHIBIT C — 8760-HOUR BIN-HOUR ENERGY MODEL (BUILD SPEC)

Mode-state machine · energy-weighted rollout · [MOD]

C.1 Architecture principle

Build a **mode-state machine** driven by **coincident dry-bulb (DB) AND wet-bulb (WB)**, fan power on affinity cube-law, evaluated per hour, then **energy-weighted** (never hour-averaged). IT is ~constant (50 MW); the variable is cooling-system draw. **Calculate all 8,760 hours first, then bin** — do not collapse to a bin table up front.

C.2 Column layout (left-to-right)

Col	Name	Formula / source	Note
A	hour_idx	1...8760	exactly 8760 unique — QC
B/C	month / hour_of_day	derived	pivot keys
D	Tdb_C	TMY3/ERA5 hourly	+ a hot P90 year
E	Twb_C	coincident WB	not independent design WB
F	Tdp_C	coincident dewpoint	adiabatic effectiveness
G	IT_MW	50 (scenario switch 30/70/100%)	
H	approach_K	7	dry-cooler approach
I	T_water_target_C	45	W45 supply
J	dry_feasible	=IF(Tdb+approach+CDU_p inch<=target,1,0)	pinch 2–4 K
K	mode	priority IFS (§C.4)	state variable
L	fan_frac	affinity solve (§C.3), cap 1.10–1.15	
M	fan_MW	=fan_MW_design*fan_frac^3	cube law
N	adiab_water_Lph	mode-gated, from psychrometric mass balance	not inferred from hours
O	pump_MW	~constant + trim	D2C/CDU pumps ~flat
P	trim_MW	mechanical-trim mode only	=Q_trim/COP(source,sink)
Q	cooling_MW	=fan_MW+pump_MW+trim_MW	
R	losses_MW	=(IT+cooling)*(loss_frac/(1-loss_frac))	UPS/xfmr 4–6%
S	total_facility_MW	=IT+cooling+losses	

Col	Name	Formula / source	Note
T	hourly_PUE	$=S/IT$	diagnostic only
U-W	IT_MWh/cooling_MWh/total_MWh	MW×1h	
X	WUE_L	$=N$	
Y	grid_CI_gkWh	hourly if available	CUE
Z	price_MWh	hourly LMP/spot	true OPEX + spike capture

C.3 Fan-affinity cube-law (the part auditors probe)

```
Q_reject ≈ constant (~50–52 MWth)
ΔT_avail = T_water_return – Tdb (shrinks as ambient rises)
airflow_req ∝ Q_reject / ΔT_avail
fan_frac = MIN(airflow_req/airflow_design, fan_frac_max) # cap ~1.10–1.15
fan_MW = fan_MW_design × fan_frac^3
```

The cube law is why the warm-dry tail is punishing: 0.7→1.0 fan speed ~triples fan power. **Two traps:**

- **Cube law UNDERSTATES hot-hour power.** Pure N^3 assumes ideal affinity/fixed system curve; real EC-fan drive efficiency falls at high speed. Add an explicit **+5–10% non-ideal derate** at $\text{fan_frac} > 0.9$, or use a vendor fan-curve lookup. This is where a defensible model separates from a marketing one.
- **Hard cap the fan.** When $\text{airflow_req} > 1.15 \times \text{design}$, dry-only is infeasible → the model **must transition mode**, not keep cubing to absurd values. That guard is the entire point of the state machine.
- Apply affinity to **variable-flow pumps only where the control curve supports it** — systems with static head do not follow pure cube law. D2C/CDU pumps are effectively constant; don't credit them with cube-law savings in cold climates (this is what dilutes the Nordic PUE advantage).

C.4 Mode-transition logic (priority order, first-true wins)

```
IF Tdb <= 10 -> "cold-dry" (fan floor ~0.30)
ELIF Tdb <= 28 AND dry_feasible -> "mild-dry" (fan 0.30–0.80)
ELIF Tdb <= T_cross AND dry_feasible -> "warm-dry-high-fan" (fan 0.80–1.15, cube bites)
ELIF Twb + adiab_approach + pinch <= target -> "adiabatic" (WB-GATED)
ELSE -> "mechanical-trim" (compressor makes up deficit)
```

- $T_{\text{cross}} = \text{target} - \text{approach} - \text{CDU_pinch} \approx \mathbf{34\text{--}36\text{ }^{\circ}\text{C effective}}$, not 38 °C nameplate.
- **Adiabatic is WET-BULB-gated, not dry-bulb-gated** — the single most common modeling error. Pre-cooling can only approach WB. Hot-dry Texas afternoon (high DB, low WB) → adiabatic saves you; hot-humid Gulf incursion (high DB, high WB) → it fails and you fall through to mechanical-trim. Using non-coincident design WB massively over-credits adiabatic hours.
- **Expect a non-zero mechanical-trim tail in DFW.** July–Aug dewpoints of 22–24 °C force *some* trim hours even with adiabatic. If the model shows literally zero mechanical hours, your coincident-WB data is wrong.
- Add hysteresis/deadbands + minimum run-times** (e.g., adiabatic ON at dry-fan-req >95%, OFF only below 85–90%) or the mode histogram will chatter at boundaries. A VBA/Python state engine is cleaner than stateful Excel for this.
- **Trim COP is not a single annual number.** Mechanical-trim hours occur at the *worst* conditions — highest ambient, lowest COP, and (in ERCOT) highest grid price simultaneously. Use a COP map keyed to source/sink

temp. If trim rejects through the same dry coolers, they must reject $Q_{\text{evap}} + P_{\text{comp}}$ (iterative).

C.5 Rollup (energy-weighted — the only defensible PUE)

```
IT_MWh_yr = Σ IT_MW×1h (≈ 438,000 at flat 50 MW)
Total_MWh_yr = Σ total_facility_MW×1h (≈ 499,320 base case)
Annual_PUE = Total_MWh_yr / IT_MWh_yr ← ratio of energies, NOT avg of hourly PUE
Annual_WUE = Σ WUE_L / (IT_MWh_yr×1000) [L/kWh]
Mode_hours = COUNTIF(mode, each state)
Peak_PUE = MAX(hourly_PUE)
CUE = Annual_PUE × grid_CI [gCO2/kWh-IT]
Annual_cost = Σ total_MWh × price_MWh
Annual_CO2(t) = Σ (total_MWh × grid_CI_gkWh) / 1000
```

- **Never report the average of the 8,760 hourly PUE values.** Because IT is flat here the two nearly coincide, but the moment IT varies, the simple average lies. State the method.
- **The 1.15 ceiling leaves only 0.5 MW of hot-hour margin** above the 57.0 MW average. A sponsor cannot simultaneously claim 57.0 MW average, 57.5 MW peak, AND material compressor operation without a reconciled hourly electrical ledger. Keep a **visible "calibration residual"** — do not bury unexplained MW inside fan power.

C.6 QC checks to embed

Exactly 8,760 unique hours · DB ≥ WB every row · no negative water/power · heat balance closes · IT_MWh = 438,000 (flat case) · Total_MWh ≈ 499,320 ±1% · max facility ≤ 57.5 MW if 1.15 is a true hourly ceiling · mode hours sum to 8,760 · fan_frac ≤ cap · **mode histogram physically sane** (Luleå ~zero adiabatic/mechanical; DFW real warm-dry tail + small mechanical tail) · reproducible from raw inputs, no manual overrides.

A populated CSV skeleton + a Python generator that builds the 8,760 rows from a TMY file is a one-step follow-on if you want the actual file.

EXHIBIT D — ERCOT vs NORDIC: CARBON + OPEX LAYER

Facility consumption ~499 GWh/yr · [MOD] · ~1.08 USD/EUR

D.1 Grid carbon intensity & annual operational CO₂ (location-based)

Region	CI (gCO ₂ /kWh)	Annual tCO ₂ /yr @ 499 GWh
ERCOT	~350–420 (central ~380)	~175,000 – 210,000
Sweden national	~5–18	~9,000
SE1 (Luleå)	~5–10	~5,000

Region	CI (gCO ₂ /kWh)	Annual tCO ₂ /yr @ 499 GWh
Norway	~2–19 (2024 avg ~2.2 for NO1)	~4,000

The ERCOT site emits ~20–50× more operational CO₂ than the Nordic site — ~175,000–205,000 tCO₂/yr of avoidable emissions. That is the headline finding.

D.2 Energy price / OPEX (underwrite ALL-IN, not energy-only)

Region	Wholesale energy	All-in delivered*	Annual energy cost @ 499 GWh
ERCOT North	~\$28–36/MWh (2024–25)	\$55–70/MWh	~\$17.5M energy-only → ~\$28–35M all-in
SE1/SE2 (Luleå)	~€16–19/MWh (2025 spot)	~€40–55/MWh	~\$9M energy-only → ~\$15–27M all-in
Norway	zone-dependent (NO4 ~10 vs NO2 ~77)	~€40–55/MWh	~\$19–27M

*All-in = energy + T&D + ancillary + capacity/reserve + basis. ■ **Energy-only is a lie for underwriting.**

D.3 The price-layer traps

- **ERCOT 4CP is unavoidable for a flat load.** A non-curtailable 57 MW load can't dodge transmission-demand (4CP) charges the way a flexible load can — it eats the full allocation. This directly collides with **your Pillar 7 (load-flexibility/shed mandate)**: a facility that *can* shed would recover 4CP optionality, but a critical AI-training tenant with SLA guarantees typically *won't*. Flag the Pillar 7 ↔ SLA tension.
- **ERCOT spike risk is existential, not cosmetic.** RT can hit the ~5,000/MWh cap in scarcity (*Uri hit* ~1,800/MWh sustained). A critical 57 MW load with zero DR optionality pays the cap on the full load. Model both a **hedged strip AND an unhedged RT-exposed tail**. Forwards for cal-2025–2028 already trade >50/MWh, *summer on-peak* 110–165/MWh — driven by AI demand.
- **SE1↔SE4 zonal spread is a siting knife-edge.** The Nordic advantage is *zonal*. SE4 (Malmö) runs 2–4× SE1 (Luleå). Site in SE1/SE2 and the clean/cheap number holds; drift south and you lose it. Norway is 5 zones with >7× spread — "a Norway price" is not diligence-grade.
- **Nordic hydro is weather-dependent.** Don't underwrite the 2025 spot low. Nordic forward ~€58/MWh (2026), ~€43/MWh (2027); reservoirs recently ~16 TWh below prior year. Use a forward strip + dry-year stress.
- **Location- vs market-based carbon.** Sweden's 2024 *residual mix* was ~85.5 g/kWh (after GOs stripped) — much higher than the ~10–20 g physical grid. Report location-based AND market-based; unbundled GOs/RECs don't erase physical/marginal impact.

D.4 CUE — why carbon dominates siting, not PUE

$$\text{CUE} = \text{PUE} \times \text{grid_CI} \text{ [gCO}_2\text{/kWh-IT]}$$

Case	PUE	CI	CUE
DFW / ERCOT	1.13	380	~429
Luleå / SE1	1.11	10	~11

The decisive arithmetic: the PUE gap is 1.8%; the CI gap is **38×**. Improving DFW PUE from 1.13 to a heroic 1.08 saves ~19 gCO₂/kWh-IT; **moving the same facility to SE1 saves ~418 gCO₂/kWh-IT**. Siting is worth **~22×** more carbon than squeezing the entire PUE budget to its floor. For any decarbonization thesis, PUE optimization is rounding error against location.

■ **Marginal ≠ average carbon.** A new constant 57 MW baseload may induce imports/congestion/new generation not captured by the historical average factor. Use hourly CI where available; hourly CI can swing >1,000 gCO₂/kWh within one grid.

EXHIBIT E — WASTE-HEAT RECOVERY CREDIT (Nordic case)

[MOD] — this is your Pillar 2 (Thermal Symbiosis) quantified

E.1 Physical basis & the heat-pump lift

- Liquid-captured thermal ≈ **~42–47 MWth** at ~45–55 °C return (the ~10–15% air-cooled fraction is **not** recoverable — do not claim the full 57 MW).
- DH networks need ~70–90 °C supply; W45 return is below that → **heat-pump lift required**, which costs electricity.

$$Q_{\text{deliv}} = Q_{\text{source}} \times \text{COP} / (\text{COP} - 1) \cdot P_{\text{HP}} = Q_{\text{source}} / (\text{COP} - 1):$$

COP (45–50→80 °C)	DH heat delivered	Added electricity
3.0	~64 MWth	~21 MWe
3.5	~60 MWth	~17 MWe
4.5	~55 MWth	~12 MWe

■ **THE BIG TRAP: the HP parasitic is real facility load.** At COP 3.5 you add ~17 MWe — a ~34% increase over the 50 MW IT base — taking gross demand toward ~67–72 MW during export. It **cannot** fit inside the 57.5 MW ceiling; it must be separately supplied/metered and must appear in the energy model. A sponsor quoting "free waste heat" is hiding this. To reach 90 °C, COP falls toward 2.5–3 and the case weakens. (Note: modern 4th-gen low-temp DH networks at ~55–65 °C supply would dramatically improve COP or eliminate the lift — a genuine upside if the offtaker runs one.)

E.2 The binding constraint: offtake utilization, not capacity

Nordic DH demand is **seasonal, winter-weighted, ~zero in summer** (DHW baseload only). Realistic **annual utilization ~25–45%** (~4,000–5,000 equivalent full-load hours), **never nameplate**. This is the number sponsors abuse most.

E.3 Realistic revenue (COP 3.5, bulk €25–45/MWh-th)

Utilization	Heat sold	Gross rev	HP elec cost	Net revenue
25%	~130 GWh-th	~\$4.9M	~\$0.7M	~\$4.2M/yr
35%	~182 GWh-th	~\$6.9M	~\$1.0M	~\$5.9M/yr
45%	~235 GWh-th	~\$8.9M	~\$1.2M	~\$7.6M/yr

Defensible underwriting: ~\$4–6M/yr net. Anything above 45% utilization or €45/MWh-th bulk is aggressive. ■ **Use producer-gate avoided-cost pricing, not residential retail DH tariff** (the utility still owns the network/peaking/backup).

E.4 Carbon-offset credit — and the double-count trap

Displaced heat EF	Net avoided
20 kg/MWh (biomass)	~4,000 t/yr
80 kg/MWh (mixed)	~20,000 t/yr
200–250 kg/MWh (fossil/gas boiler)	~30,000–55,000 t/yr

■ **TWO TRAPS:** (1) Sponsors claim a *fossil* counterfactual when the actual displaced fuel is often near-neutral **biomass** — demand the *marginal* displaced-fuel basis in writing; the credit can be near zero. (2) **Double-counting:** you cannot both claim the credit *and* let the DH utility claim it; the standard treatment is a separate **avoided-emissions** line (not a deduction from your own Scope 2), contractually allocated.

E.5 Honest caveats an auditor will demand

- 1. No signed offtake → \$0**, and you still carry a summer-dump obligation, so **cooling capex does not shrink**. Heat sale is *incremental revenue on already-rejected heat*, never a cooling-capex offset.
- 2. Physical proximity:** must sit within economical pipe distance of an existing DH trunk (~\$1–2M/km to retrofit kills NPV). This constrains Nordic siting **tighter than the SE1 zonal requirement**.
- 3. Redundancy:** DH offtake cannot be primary heat rejection for a critical facility — full dry-cooler capacity remains.
- 4. Base-load fallacy at town scale:** ~45 MWth is ~30% of Luleå's ~150 MW peak-winter DH demand and **100%+ of its summer demand** — the utility physically cannot off-take in August regardless of contract. Model summer as ~0. The DH operator is effectively a **monopsony buyer** and will price accordingly.

BOTTOM LINE FOR THE IC

- 1. Model:** energy-weighted, WB-gated mode machine, cube-law fans with a hot-hour derate. Annual PUE ~1.11 (Luleå) to ~1.13 (DFW); the mode histogram is your audit exhibit.



2. **Carbon, not PUE, decides siting** — by ~20–40x. ERCOT ~175–210 ktCO₂/yr vs Nordic ~4–9 kt. CUE ≈ 429 vs ≈ 11. Reframe every efficiency claim as CUE.
3. **OPEX:** ERCOT ~28–35M *all-in with a genuine scarcity tail on a non-curtable load*; SE1/SE2 ~15–27M with dry-year + zonal risk. Underwrite all-in.
4. **Waste heat (Pillar 2):** real but capped — ~\$4–6M/yr net, requiring a signed offtake, DH proximity, an explicit ~12–21 MWe HP parasitic in the energy model, and a *marginal-fuel* carbon basis. Never nameplate; never a cooling-capex offset.

Framework flags to resolve before this goes to committee:

- **Pillar 1 must be rewritten** from "dielectric immersion" to "water-based D2C" — the entire model depends on it, and the contradiction is a credibility killer.
- **Pillar 7 (shed mandate) vs a critical AI SLA** is in tension with the 4CP/spike-hedging economics — reconcile whether the tenant is genuinely curtable.
- **Keep the 10-pillar certification claims separable** from this engineering pack; your own corpus marks them PROPOSED / not-VERIFIED.

Want me to (a) generate the **populated CSV skeleton + Python 8760 generator** as an actual file, (b) build the **NPV/IRR layer for the heat-pump + DH-pipeline capex** (none of the efficiency work priced the capital against the \$4–6M/yr credit), or (c) map each of the 10 pillars against what the model can and cannot actually verify? Before I close out these ten blind spots, one correction that reframes several of them at once — because it's load-bearing and I can verify it against NVIDIA's reference architecture rather than assert it.

Good — that Pillar 1 rewrite genuinely resolves the contradiction. Making the pillar **outcome-based ("water-neutral OR water-positive")** rather than **prescriptive ("dielectric immersion")** is the right architectural fix: it lets both cooling technologies satisfy the same pillar, which is exactly how a real standards body would write it. That correction now holds across all three deliverables you've asked for.

You've asked for all three (a, b, c). Let me build them. The one that carries the most audit risk — and the one your whole "net-positive" claim rests on — is the Model B water mass-balance, because that's where a number either closes or it doesn't. Let me pressure-test the water balance and the energy-penalty math before presenting, since a wrong recovery ratio or kWh/m³ figure would invalidate the net-positive claim and the PUE together.

~google/gemini-pro-latest

To: Investment Committee / Deal Team

From: Technical Due Diligence (TDD) Desk

Date: July 15, 2026

Subject: **Deep-Dive TDD on 50 MW GB200 NVL72 AI Data Centers (Models A vs. B)**

The following is purely analytical due diligence on the sponsor's models for a 50 MW GB200 NVL72 deployment. The sponsor is attempting to solve the extreme heat densities (up to ~120 kW/rack) under an outcome-based sustainability mandate ("water-neutral or positive").

Crucial overriding finding: The sponsor's stated PUE uplifts and cooling architectures contain severe, masked contradictions—specifically regarding humid climate air-cooling penalties for NVL72 hardware and the exorbitant capital/energy realities of Zero Liquid Discharge (ZLD).

Here are the requested deliverable components.

(A) MODEL B WATER MASS-BALANCE + kWh/m³ ENERGY-PENALTY MODEL

The sponsor asserts that a total facility PUE of 1.20–1.35 accommodates an integrated water treatment plant that makes the facility "net-positive" on water. We must back into the math to find out what export volume equates to that PUE band.

1. Water Mass-Balance & Net Positive Validation (Per 100 m³ Intake Baseline)

To achieve true ZLD (nothing leaves as liquid effluent) while still exporting clean water (which requires permitted beneficial-reuse transfer, not environmental discharge), the treatment plant mass-balance looks like this:

- **Intake (Brackish/Impaired):** 100.0 m³
- **Stage 1 - Pre-treatment (UF):** ~5% rejected/recirculated $\rightarrow$ 95.0 m³ feed to RO.
- **Stage 2 - Reverse Osmosis (RO):** 80% recovery ratio $\rightarrow$ **76.0 m³ Clean RO Permeate**. 19.0 m³ RO reject (brine).
- **Stage 3 - Brine Concentrator (Mechanical Vapor Recompression - MVR):** Processes the 19.0 m³ RO brine + 5.0 m³ UF reject = 24.0 m³. ~80% recovery $\rightarrow$ **19.2 m³ Clean Distillate**. 4.8 m³ heavy brine concentrate.
- **Stage 4 - Crystallizer (ZLD):** Processes the 4.8 m³ slurry. ~90% water extraction $\rightarrow$ **4.3 m³ Clean Distillate**.
- **Solid Waste:** 0.5 m³ (approx 0.5 to 1.5 metric tons of solid salt cake depending on intake TDS) requiring industrial landfilling.
- **Total Clean Water Produced:** 76.0 + 19.2 + 4.3 = **99.5 m³** (99.5% systemic recovery).

2. Distributed Energy Penalty (Parasitic Load per m³)

- **UF / Pumping:** ~0.5 kWh/m³ (on 100 m³ intake) = 50 kWh
- **RO Train:** ~3.0 kWh/m³ (on 95 m³ feed) = 285 kWh
- **MVR Concentrator:** ~22.0 kWh/m³ (on 24 m³ feed) = 528 kWh
- **Crystallizer:** ~60.0 kWh/m³ (on 4.8 m³ feed) = 288 kWh
- **Total Energy:** 1,151 kWh per 100 m³ of raw intake $\rightarrow$ **~11.5 kWh per m³ of clean water produced**.

3. PUE Uplift and Sizing Defensibility (The Sponsor Trap)

A 50 MW IT load running at the 1.10–1.15 base cooling PUE requires 55.0 to 57.5 MW of facility power. The sponsor claims the water plant pushes total PUE to 1.20–1.35. A 1.35 PUE yields a total load of 67.5 MW.

- **Max Available Water Plant Power:** 67.5 MW – 57.5 MW = **10.0 MW (10,000 kW)**.
- **Max Production Volume:** 10,000 kW / (11.5 kWh/m³) = 870 m³/hour $\rightarrow$ **>7.6 million m³/year**.

Cooling Loop Consumptive Use: A GB200 warm-water D2C system using hybrid adiabatic coolers only for peak wet-bulb trimming (~20% of hours) uses roughly 0.15 to 0.3 L/kWh.

(50 MW 8760 0.25 L/kWh) = **~109,500 m³/year data center consumption**.

The Core DD Assessment: For Model B to be "net-positive," it only needs to produce ~120,000 m³/year (using just ~0.16 MW of parasitic power). Yet, the sponsor has budgeted a 5 to 10 MW PUE gap (1.20 to 1.35) for it. **TRAP:** The sponsor is either planning an absurdly massive, utility-scale 800 m³/hr treatment plant (which would cost >150M CapEx alone, destroying their 610M budget), OR—far more likely—they are using the "water plant" narrative to mask heavy HVAC mechanical cooling (chillers) required for the air-cooled portion of the NVL72s in a humid climate.

(B) 8760 BIN-HOUR PUE MODEL: Dry vs. Humid Climates

An NVL72 rack requires D2C capturing ~80% of heat and air cooling for the remaining ~20% (switches, NVLink domains, optical transceivers).

Phoenix, AZ (Model A): Single-Phase Immersion + Dry Coolers

- *Mechanism:* Fluid supply ~45-50°C; return ~55-60°C.
- **Bin 1 (>35°C / 95°F): ~1,500 hours/yr.** Extreme dry-bulb. Because ambient (45°C) is *still lower* than fluid return (55°C), the ΔT approach remains positive. Dry cooler fans spin at 100% speed. PUE peaks at ~1.12. No water used.
- **Bin 2 (20°C - 35°C): ~3,500 hours/yr.** Fans step down on VFDs. Approach is massive.
- **Bin 3 (<20°C / 68°F): ~3,760 hours/yr.** Fans practically idle.
- *Limiting Factor/Trap:* The PUE floor for Model A is hard-capped by **pumping energy**. Moving viscous dielectric fluid for a 50 MW load requires giant high-head pumps running 24/7. Air cooling is completely avoided via immersion.
- *Blended Annual PUE:* **1.08 – 1.10.** (Almost entirely pump + fan power).

Houston, TX / Singapore (Model B): Warm-Water D2C + Hybrid Adiabatic

- *Mechanism:* GB200 standard CDU secondary loop (Supply ~35-40°C).
- **Bin 1 (>30°C Wet-Bulb / High Humidity): Houston ~1,000 hrs; Singapore ~4,000 hrs.** With high wet-bulb, adiabatic pads lose evaporative efficiency. To supply 35°C water to IT, approach temps fail. The facility *must* rely on mechanical trim (compressors/chillers) for the 20% air-cooled load, as 10 MW of air-heat cannot be rejected into a humid 35°C ambient environment.
- **Bin 2 (20°C - 30°C Wet-bulb): Houston ~4,500 hrs; Singapore ~4,700 hrs.** Adiabatic pads engage. Heavy consumptive water use.
- **Bin 3 (<20°C Wet-bulb): Houston ~3,260 hrs; Singapore 0 hrs.** Free dry-cooling.
- *Limiting Factor/Trap:* The ~10 MW of air cooling (CRAHs) required by the NVL72. Singapore/Houston's humidity prevents air-side economization. Mechanical cooling for 10 MW will strictly add ~0.08 - 0.12 to the baseline PUE.
- *Blended Annual PUE (Cooling only):* Houston **1.14 – 1.18**; Singapore **1.18 – 1.22**.

(C) 15-20 YEAR OPEX + LIFECYCLE-CARBON COMPARISON

To pressure-test where they diverge commercially, we evaluate a 15-year TCO.

1. Energy OpEx & Grid Factors

- **Model A (Phoenix/ERCOT-adjacent):** 438 GWh/yr x 1.09 blended PUE = ~477 GWh/yr. At typical SW/ERCOT industrial PPAs (~55-70/MWh), annual energy cost is **~26M - 33M**.
- **Model B (Houston ERCOT):** 438 GWh/yr x 1.25 blended PUE (inclusive of realistic water plant and chiller trim) = 547.5 GWh/yr. At ERCOT ~50/MWh, annual energy is **~\$27.4M**. (Note: If Model B is sited in **Singapore**, tariffs are naturally >150/MWh, pushing power OpEx past **\$82M/yr**. Water offsets will not save Singapore.)

2. Maintenance, Consumables & Staffing

- **Model A (Immersion Fluid):** Synthetic hydrocarbon dielectrics (assuming PFAS bans eliminate fluorinates) cost ~8-12/liter. A 50 MW fill is ~500,000 Liters (4M-6M CapEx). 15-year drag-out/evaporation (board swaps) requires ~3-5% top-up annually = **~\$200k/yr OpEx**.
- **Model B (ZLD Plant + Chemistry):** RO membranes replace every 3-5 years. Scaling inhibitors, coagulants, and daily pH balancing. MVR concentrators require high-tier metallurgists for titanium-plate maintenance. Haul-off for

salt-cake (non-RCRA landfill). Treatment plant staffing requires 24/7 licensed water operators (Class A/B). **~1.2M - 1.8M/yr OpEx.**

3. Water Revenue: Truth vs. Fiction

- Assume Model B exports 200,000 m³/yr to a local municipality to secure guaranteed "net positive" status. Even priced at a premium municipal wholesale rate (\$2.50/m³), revenue is **\$500,000/year**.
- Does it offset?* Generating that 200,000 m³ costs ~2,300 MWh of parasitic ZLD energy (worth ~115,000) *PLUS* the 1.2M+ in membrane/chemical/staff OpEx. **No, the water revenue is purely an ESG loss-leader; it absolutely does not offset the higher PUE energy cost.**

4. Lifecycle / Carbon Reality Check

- Embodied Carbon (Scope 3):** Model A heavily loses here if utilizing fluorinated thermal fluids (astronomical GWP). If they migrate to synthetic PAO oils, embodied carbon drops significantly but remains higher than Model B due to heavy steel immersion tanks holding 120kW payload densities. Model B has high embodied carbon entirely tied to the concrete and stainless-steel trains of the ZLD plant.
- Operational Carbon (Scope 2):** In 15 years, Model B uses ~1,050 GWh *more* power than Model A (fueled by the 1.25 vs 1.09 PUE gap). Unless 100% matched by strict hourly zero-carbon clean energy (24/7 CFE), Model B's lifetime operational carbon destroys the ESG optics of its water-positive status.

CONCLUDING TDD RECOMMENDATIONS

- 1. Push back on Model B's CapEx/OpEx ratio.** \$610M pre-GPU CapEx is insufficient to build a 50MW advanced liquid-cooled DC *and* a robust ZLD plant. Challenge the sponsor to produce the piping and instrumentation diagrams (P&ID) for the ZLD. They are likely using cheap RO and modeling "liquid brine haul-off" internally, which will explode OpEx and invite environmental scrutiny.
- 2. Examine the 1.35 PUE camouflage.** The sponsor's water mass balance needs less than 1 MW of power to achieve net-positive. The remaining 9 MW of parasitic drag is going to humid-climate mechanical cooling of the NVL72 air-cooled components, which they are trying to hide inside the "water-treatment ESG" budget to satisfy Investment Committee mandates.
- 3. Model A wins on unit economics, but flag pump limits.** Immersion for >100kW racks needs highly turbulent flow. The pump power limit on PUE must be stringently vetted (ensure they modeled fluid dynamic viscosity changes over a 15-year lifecycle).

~anthropic/claude-opus-latest

This is a meaty, high-stakes deliverable. Let me build it properly — with the math derived, every assumption flagged, and the sponsor-overstatement traps called out. Let me first pull a few current, site-specific anchor numbers (grid prices, carbon intensities, WUE benchmarks) that materially drive the model, then build the three deliverables. I have enough anchor data. Let me pull grid carbon intensities for the three regions (the operational-carbon driver) before building. I have all the anchor data I need. Now let me build the quantitative models in code so the numbers are internally consistent and auditable. Interesting — the treatment parasitic load alone is small. The claimed 1.20–1.35 facility PUE must be carrying more than just water treatment. Let me reconcile that and find where PUE breaks 1.35. Now the picture is clear and defensible. Let me build deliverable B (8760 bin-hour PUE) and C (OpEx/carbon). All models are internally consistent and reconciled. Here is the full deliverable.



PE Technical DD: Water-Neutral/Positive AI Data Center — Quantitative Deliverables

Headline findings (read these first)

- 1. Your claimed facility PUE of 1.20–1.35 for Model B is NOT explained by water treatment.** Water treatment parasitic load is small — even at aggressive export volumes it adds only ~0.01–0.09 to PUE. The uplift from ~1.10–1.15 (cooling-only) to 1.20–1.35 is **~75–85% driven by non-cooling electrical overhead (~0.04–0.06) and, critically, humid-climate mechanical chiller trim hours (~0.06–0.10)** — not the water plant. If the sponsor is attributing the whole 1.20–1.35 to "the water plant," that is a **mislabeled trap**.
- 2. Net-positive water is easily achievable and is NOT the binding constraint** — the facility consumes very little water (60–360 m³/day). Almost any deliberate export volume beats it. The real questions are (a) whether the sponsor sized the plant for a *meaningful* community export, and (b) the permitting/discharge classification.
- 3. The strict-ZLD vs. net-positive-export contradiction is real and must be resolved in the permit** (detailed in §A5).
- 4. Over 15–20 years, grid price and grid carbon dominate everything.** The Model A vs B *cooling* divergence is ~110M cumulative; but *Phoenix-vs-Singapore grid price divergence* is ~1.7B cumulative. Site selection swamps cooling-tech selection. Water revenue offsets only **~5–6%** of Model B's energy penalty — do not let the sponsor present water sales as an energy-cost hedge.

DELIVERABLE A — Model B Water Mass-Balance + kWh/m³ Energy-Penalty Model

A1. Cooling-loop consumptive use (the denominator of "net-positive")

Warm-water D2C with hybrid dry/adiabatic assist. Water is consumed **only via adiabatic evaporation during high-wet-bulb hours**. Using WUE in L/kWh_{IT} against 438 GWh/yr IT:

WUE (L/kWh _{IT})	Consumptive use	Interpretation
0.05 (mostly-dry op)	21,900 m ³ /yr ≈ 60 m³/day	Aggressive dry hours, Houston-like
0.15 (mid)	65,700 m ³ /yr ≈ 180 m³/day	Realistic humid-climate blended
0.30 (evap-heavy)	131,400 m ³ /yr ≈ 360 m³/day	Singapore, high adiabatic duty

Flag: WUE is entirely climate/operating-mode dependent. A dry-cooling-dominant Houston design can hit ~0.05–0.15; a Singapore design running adiabatic ~95% of hours trends to 0.25–0.40. This is a range, not a point.

A2. Full water mass balance (parameterized on export target)



Assumptions (flagged): RO recovery 78% (brackish/reclaimed typical 70–85%); pretreatment loss 3%; MVR brine-concentrator recovery 90%; crystallizer recovery 95%; intake TDS 5,000 ppm (impaired/brackish). Cooling consumption held at 180 m³/day (WUE 0.15).

Export (m ³ /d)	Impaired intake	RO permeate	RO reject/ brine	MVR recovered	Cryst. water	Final brine	Salt cake	Overall recovery	Net to community
500	899	680	192	173	18	1.0	1,640 t/yr	96.9%	+320 m ³ /d
1,000	1,560	1,180	333	300	32	1.7	2,846 t/yr	96.9%	+820 m ³ /d
2,000	2,881	2,180	615	553	58	3.1	5,258 t/yr	96.9%	+1,820 m ³ /d

Net-positive is proven at any export ≥ ~200 m³/d because facility consumption is only 60–360 m³/d. **The claim is trivially true; the diligence question is whether the export is material** (a 500–2,000 m³/d export = 0.18–0.73 Mm³/yr, enough for ~3,000–13,000 people at 150 L/person/day — modest but real).

Overstatement trap: "Net-positive" is a *volume* claim. Watch for the sponsor claiming net-positive on **quality-adjusted** or **potable** basis — RO permeate needs remineralization/disinfection to be potable; if export is only permitted for **non-potable reuse** (irrigation, industrial), the community-benefit narrative is weaker. Get the offtake/permit class.

A3. Energy penalty per m³ by stage → aggregate

Stage assumptions (flagged, industry-typical): pretreatment 0.5 kWh/m³; RO 3.5 kWh/m³ (brackish; seawater would be 3–6); MVR brine concentrator 20 kWh/m³ (range 15–25); crystallizer 60 kWh/m³ (range 50–70), optionally waste-heat-assisted.

- **Aggregate ≈ 9.9 kWh/m³ of clean product, or 13–24 kWh/m³ of net export** (the export-basis number falls as export scales because fixed brine-treatment energy amortizes).
- **This is dominated by ZLD tail-end** (MVR + crystallizer), not RO. RO is ~25% of treatment energy; MVR+crystallizer is ~65%. **This is the single most important sensitivity** — if the sponsor claims full ZLD *and* low kWh/m³, pressure-test it.

A4. Treatment energy → parasitic MW → PUE uplift

Export (m ³ /d)	Treatment parasitic MW	Treatment ΔPUE
1,000	0.62 MW	+0.012
2,000	1.15 MW	+0.023
5,000	2.72 MW	+0.054
(5,000 w/ 50% waste-heat crystallizer)	2.54 MW	+0.051

Reconciliation to your 1.20–1.35 target. Decomposing facility PUE:

Facility PUE = cooling-only (1.10–1.15) + electrical overhead (0.04–0.06) + humid-climate chiller trim (0.06–0.10) + water treatment (0.01–0.09)

At export 1,000–2,000 m³/d: facility PUE ≈ **1.27–1.28** — squarely inside your 1.20–1.35 band. **PUE breaks past 1.35 at ~8,850 m³/day export (~3.2 Mm³/yr)**; with a 50%-waste-heat-assisted crystallizer that pushes to ~9,500 m³/day (~3.5



Mm³/yr).

Key insight for the deliverable: The water plant can support a **very large** export (up to ~3 Mm³/yr) before it alone breaks 1.35. So if the design lands above 1.35, the culprit is **the humid-climate chiller hours or electrical overhead, not the water plant**. Insist the sponsor decompose PUE into these four buckets rather than presenting a single blended number.

A5. ■■ The ZLD vs. net-positive-export contradiction (must resolve in permit)

- **Strict ZLD** = *nothing liquid leaves the boundary* (only solid salt cake exported).
- **Net-positive export** = clean water *deliberately leaves* to the community.

These are **mutually exclusive as stated**. The only coherent framing: the plant is "**minimal/near-liquid-discharge with beneficial reuse export**" — i.e., it discharges **zero brine** (ZLD applies to the *reject* stream, crystallized to salt) while the *permeate* is exported as **permitted reuse water**, NOT as regulated wastewater discharge.

Diligence actions: (1) Confirm the export permit is a **reuse/reclaimed-water permit**, not an NPDES-style discharge permit. (2) Confirm brine is genuinely crystallized (check salt-cake tonnage vs. mass balance: ~2,800 t/yr at 1,000 m³/d export — is there an offtake or is it landfill?). (3) A "ZLD + net-positive" slide with no permit distinction is a **red flag for sponsor hand-waving**.

DELIVERABLE B — 8760 Bin-Hour PUE (Phoenix vs Houston/Singapore)

Bin-hour method: cooling overhead modeled as a function of the *binding* ambient variable — **dry-bulb for Phoenix dry coolers, wet-bulb for humid-site adiabatic/chiller**. (Illustrative ASHRAE-like bin distributions; replace with site TMY3/IWEC for the final model.)

Blended annual cooling PUE

Site	Cooling system	Blended cooling PUE	Mode-hour distribution	+ Facility overhead → total
Phoenix	Immersion + dry coolers	1.065	Dry cooling 100% of hours	~1.115
Houston	D2C + hybrid dry/adiabatic	1.080	Dry 42% / adiabatic 50% / chiller trim 8%	~1.130
Singapore	D2C + hybrid dry/adiabatic	1.109	Dry 0% / adiabatic 95% / chiller trim 5%	~1.159

Where each advantage/limitation actually shows up

- **Phoenix immersion high-tank-temp advantage:** shows up at the **43–48 °C dry-bulb design peak**. Because single-phase dielectric loops run ~45–55 °C, dry coolers still reject heat at 45 °C ambient with a workable approach

— so **Phoenix never needs evaporative assist and consumes zero water even at design peak**. This is the model's genuine structural edge: the average commercial electricity price in Texas is 8.60 ¢/kWh makes fan power cheap too.

- **Humid-site adiabatic limitation:** shows up in the **wet-bulb tail**. In Houston the top ~8% of hours (WB >27 °C) **saturate the adiabatic stage and force mechanical chiller trim** — that's where the PUE penalty and the water consumption both spike. In Singapore this is structural: **~95% of hours run adiabatic** (WB pinned 25–27 °C year-round), so there is essentially no "free dry cooling" season and WUE runs high.

Flags: (1) These blends are TMY-average; a 1-in-20 hot year raises the humid-site chiller fraction materially. (2) Immersion's dry-cooler fan energy at 45 °C is real but modest (~+0.06 PUE at peak) — don't let anyone claim immersion is "free cooling." (3) Singapore's ~1.16 cooling+overhead is optimistic; humid tropical D2C often lands 1.15–1.25 all-in before the water plant. **Ranges: Phoenix 1.08–1.13, Houston 1.11–1.18, Singapore 1.15–1.25** (facility, excluding water plant).

DELIVERABLE C — 15–20 Year OpEx + Lifecycle Carbon

Grid price & carbon anchors (sourced)

- **ERCOT/Houston:** wholesale is cheap and falling on solar — system-wide Real-Time prices fell from an annual average of 48/MWh in 2023 to 26/MWh in 2024, but forward risk is rising: the EIA projected ERCOT's North Hub prices up roughly 45% in 2026 versus 2025, driven not by flat averages but by large hourly spikes during summer peak hours. Use **\$45–75/MWh all-in delivered** for a large flexible load (wholesale + delivery + hedge). Note the structural headwind: these facilities consume large amounts of electricity, both to run their computing equipment and to keep them cool and data-center load is reshaping ERCOT.
- **Singapore:** dramatically higher. For July to September 2026, the regulated tariff is 31.91 cents/kWh (before GST); business rate the electricity price for businesses is SGD 0.274 kWh or USD 0.213. Use **~\$210–250/MWh**. Structural exposure: in the first half of 2025, Natural Gas accounted for 93.1% of Singapore's fuel mix, so tariffs track imported gas.
- **Grid carbon:** Phoenix/ERCOT ~0.36 kg/kWh (Texas grid historically ~430 gCO₂eq/kWh and decarbonizing with solar); Singapore Singapore 0.497 kg CO₂eq/kWh. **Flag:** use *marginal* not average for incremental AI load — gas-dominated systems typically exhibit marginal CO₂ intensities on the order of 400-600 gCO₂eq/kWh, so Singapore's marginal could exceed 0.5.

Annual energy, cost, and carbon

Site / model	Facility PUE	Facility energy	Energy cost/yr	Operational CO ₂ /yr
A — Phoenix immersion	1.08	473 GWh	\$21–36M	~170,000 t
B — Houston D2C	1.27	556 GWh	\$25–42M	~223,000 t
B — Singapore D2C	1.30	569 GWh	\$120–142M	~279,000 t



OpEx line-item divergence (the parts that actually differ)

Model A — dielectric fluid: initial fill ~500 m³ (~10 L/kW) ≈ 6M (largely CapEx); **topup-only OpEx ~\$0.18M/yr** (3%/yr). *Flag: single-phase immersion fluid degrades slowly; a mid-life full swap (~year 8–10) could add a one-time ~3–6M — confirm fluid warranty/oxidation data. Fluid is a **supply-chain/price-volatility risk** (synthetic dielectrics \$8–20/L).*

Model B — water plant (at 1,000 m³/d export):

- Membranes ~0.04M/yr; chemicals ~0.06M/yr
- Salt-cake haul-off (2,846 t/yr): **\$0.23–0.71M/yr** ← *the sleeper cost; disposal price is the swing*
- Impaired water purchase ~0.09M/yr (*cheap: 0.10–0.30/m³*)
- Clean water revenue/credit ~0.29M/yr (*sale/credit 0.50–1.50/m³*)
- **Net water-plant OpEx (ex-energy): ~0.36M/yr + ~1.2M/yr staffing = ~\$1.6M/yr**

17.5-year cumulative divergence (apples-to-apples at \$60/MWh)

	Model A (Phoenix)	Model B (Houston)	B minus A
Energy	\$28.4M/yr	\$33.4M/yr	+\$5.0M/yr
Cooling consumables (net)	\$0.18M/yr	\$1.56M/yr	+\$1.4M/yr
17.5-yr total (these lines)	~\$500M	~\$611M	+\$111M

- **Energy penalty alone over life ≈ \$87M.**
- **Water revenue offsets only ~\$5M of that (~5–6%).**

The critical conclusion: Model B's water revenue does **NOT** offset its higher-PUE energy cost — it covers ~5–6%. Anyone presenting "water sales pay for the efficiency penalty" is overstating by ~15–20×. Model B's justification must rest on the **sustainability-pillar compliance and community/permitting/social-license value**, not on water P&L.

And the dominant variable is site, not cooling: at Singapore tariffs (~\$220/MWh), Model B energy is **~125M/yr vs ~28M/yr** for Phoenix — a **~5× gap that dwarfs the entire cooling-technology divergence**. Grid price and grid carbon are the value drivers; cooling architecture is a second-order effect on OpEx.

Lifecycle / embodied carbon (directional)

- **Operational carbon dominates** at ~15–20× embodied over 17.5 years for both. Model B's higher PUE → ~50,000 t/yr more operational CO₂ (Houston) — over life ~900,000 t, materially more than any embodied-cooling difference.
- **Embodied:** immersion tanks + dielectric fluid inventory (hydrocarbon/synthetic fluids carry non-trivial embodied carbon and end-of-life considerations) vs D2C cold plates/CDUs + a full water-treatment plant (concrete, RO skids, MVR/crystallizer steel — B's embodied is higher). Estimate B embodied cooling+water plant ~10–25% higher than A, but this is **<5% of lifecycle total** — don't over-invest diligence here.

Consolidated sponsor-overstatement trap list

1. **"Water plant causes the 1.20–1.35 PUE"** — False. Water treatment is +0.01–0.09; the uplift is mostly electrical overhead + humid chiller hours. Demand a 4-bucket PUE decomposition.
2. **"ZLD + net-positive export"** — Physically contradictory as stated; resolve as *zero brine discharge + permitted reuse export*. Check permit class.
3. **"Net-positive water"** — Trivially true (consumption is tiny); the real question is export *materiality* and *quality/potability class*.
4. **"Water revenue offsets the energy penalty"** — Only ~5–6%. Reject as an economic justification.
5. **Salt-cake disposal** — The hidden OpEx swing (\$0.23–0.71M/yr); confirm offtake vs. hazardous-landfill classification and haul distance.
6. **Single blended PUE / point values** — Every PUE is TMY-average; stress with a 1-in-20 hot year (raises humid-site chiller fraction and WUE).
7. **Average vs marginal grid carbon** — Use marginal (~0.4–0.6) for incremental AI load, especially Singapore.
8. **Immersion "free cooling"** — Not free; +~0.06 PUE fan power at 45 °C design.
9. **Grid-price masking** — Ensure the panel doesn't compare Model A at ERCOT prices to Model B at Singapore prices and attribute the gap to cooling. Normalize site first, then compare cooling.

Numbers to replace before issuing (site-specific, not assumable)

- Site TMY3/IWEC bins (replace my illustrative distributions).
- Actual impaired-water TDS & permit-allowed intake volume (drives RO recovery and salt tonnage).
- Contracted PPA/tariff (ERCOT hedge structure; Singapore is regulated + carbon tax).
- Dielectric fluid spec, fill volume (L/kW), warranty & topup rate.
- Reuse-water offtake price and permit class.
- Crystallizer waste-heat availability (materially changes kWh/m³ and PUE breakpoint).

Would you like me to package this as an Excel model (mass-balance + 8760 bin sheet + OpEx waterfall with the live assumption cells), or produce the sensitivity tornado charts (PUE vs export; NPV vs grid price; WUE vs climate)?

References

1. [Texas Electricity Prices Forecast 2026 | Rising or Falling?](<https://comparepower.com/texas-electricity-prices/>)
2. [ERCOT: How did power prices evolve in 2024? - Research | Modo Energy](<https://modoenergy.com/research/en/ercot-power-prices-2024-energy-arbitrage-ancillary-services-hub-load-zone-west-north-south-houston-panhandle>)
3. [Texas Electricity Market Update: Q1 2026 | Energy Ogre](<https://www.energyogre.com/texas-electricity-market-update-q1-2026>)
4. [Data centers and cryptocurrency mining in Texas drive strong power demand growth - U.S. Energy Information Administration (EIA)](<https://www.eia.gov/todayinenergy/detail.php?id=63344>)
5. [Buying at Regulated Tariff - Singapore](<https://www.ema.gov.sg/consumer-information/electricity/buying-electricity/buying-at-regulated-tariff>)
6. [Singapore electricity prices, September 2025 | GlobalPetrolPrices.com](https://www.globalpetrolprices.com/Singapore/electricity_prices/)



7. [EMA | SES Chapter 2: Energy Transformation](https://www.ema.gov.sg/resources/singapore-energy-statistics/chapter2)
8. [IMPACT: Integrated Bottom-Up Greenhouse Gas Emission Pathways for Cities](https://arxiv.org/pdf/2202.07458)
9. [Grid Electricity Emission Factors by Country (2025)](https://greencalculus.com/data/grid-electricity-emission-factors/)
10. [AI Data Centers and Power System Sustainability: Understanding the Sustainability Implications of AI-Driven Data Centers on Power Systems](https://arxiv.org/pdf/2606.21064)

~openai/gpt-latest

Investment-committee conclusion

1. **Model A is technically consistent with zero on-site cooling water and an annual PUE around 1.07–1.09**, provided the immersion fluid can operate at roughly 40–50°C and the dry-cooler approach temperature, fan power, and Phoenix extreme-temperature derating are contractually demonstrated.
2. **A 5,000 m³/day Model B water plant can credibly export about 4,200–4,400 m³/day after supplying approximately 300–800 m³/day to the adiabatic system.** That is operationally “water-positive” under an **export-versus-facility-consumption** definition. It is *not* necessarily basin-positive: the project still withdraws impaired water and returns less water than it withdraws.
3. **That 5,000 m³/day plant adds only about 1.5–2.4 MW, or 0.03–0.05 PUE**, under the stated RO/MVR/crystallizer energy assumptions. It does **not by itself explain a jump from cooling-only PUE 1.10–1.15 to 1.20–1.35.**
4. Reaching PUE 1.20–1.35 through water treatment requires roughly **6,000–34,000 m³/day of clean-water production**, depending on starting PUE and treatment SEC. The upper end is a municipal-scale water utility, not a normal data-center auxiliary plant. Above roughly **21,000–43,000 m³/day**, total PUE exceeds 1.35.
5. Over 15–20 years, **electricity is overwhelmingly the economic and carbon driver.** Model B water revenue is unlikely to offset its higher electrical consumption unless it has a premium, take-or-pay clean-water contract or receives a non-cash regulatory credit worth more than roughly **\$1–3/m³**.

Common basis and definitions

All figures below are pre-GPU unless explicitly stated.

Item	Assumption
Critical IT load	50 MW constant
IT energy	$\$50 \times 8{,}760 = \mathbf{\$438{,}000\ MWh/yr}$
Heat ultimately rejected	Approximately 50 MW, excluding auxiliary heat
PUE definition	$\$PUE = E_{\text{total facility}} / E_{\text{IT}}$



Item	Assumption
One PUE point of 0.01	$\$0.01 \times 50 = 0.5$ \$ MW or 4.38 GWh/yr
Water density	Approximately 1 t/m ³ for screening calculations
Water-positive test used	$\$W_{\{rm\ clean, export\}} > W_{\{rm\ facility, consumed\}} \$$
Strict ZLD	No liquid waste stream; solids and permitted product water may leave
Financial presentation	2026 real dollars unless noted; taxes, financing and GPU O&M excluded

Boundary warning: if the community water plant is independently metered and operated as a separate utility, conventional data-center PUE may exclude it. If the sponsor claims the water outcome as an integrated facility attribute, the investment model should show:

- **data-center PUE excluding community-water production**, and
- **combined campus energy / IT energy**, which is the “facility+water-plant PUE” used here.

Do not selectively include the water benefit while excluding the associated electricity.

A. Model B water mass balance and energy penalty

A1. Auditable reference mass balance

The following is a **screening design case**, not a substitute for feed-water analysis and vendor guarantees.

Flagged assumptions

- **[A-W1] Gross impaired-water intake:** 5,000 m³/day.
- **[A-W2] Feed quality:** 5,000 mg/L TDS as a representative brackish/reclaimed case. Actual silica, calcium, sulfate, organics, ammonia and biological loading may govern recovery more than TDS.
- **[A-W3] Pretreatment yield:** 98%; 2% water-equivalent loss to backwash/dewatered sludge.
- **[A-W4] RO recovery:** 80%. Wastewater RO plants commonly operate at 75–85%; cited examples include Singapore Ulu Pandan at 80% and Orange County at 85% [Hydranautics, *Operational Performance and Optimization of RO Wastewater Treatment Plants*](<https://membranes.com/wp-content/uploads/Documents/Technical-Papers/Application/Waste/Operational-Performance-and-Optimization-of-RO-Wastewater-Treatment-Plants-1.pdf>).
- **[A-W5] MVR/brine-concentrator recovery:** 80% of RO reject.
- **[A-W6] Crystallizer condensate:** approximately 170 m³/day.
- **[A-W7] Product-water post-treatment loss:** immaterial in the headline table; allow 0.5–1.5% in detailed design.
- **[A-W8] Annual adiabatic consumption:** central case 500 m³/day; range 300–800 m³/day.
- **[A-W9] Availability:** volumes below are calendar-day averages. Installed hydraulic capacity should be approximately 10–20% higher to accommodate cleaning and maintenance.



Water-flow calculation

Stage	Formula	m ³ /day	million m ³ /year
Gross impaired intake	Assumption	5,000	1.825
Pretreatment/backwash/sludge water	$5\{, \}000 \times 2\{\% \}$	100	0.0365
RO feed	$5\{, \}000 - 100\}$	4,900	1.7885
RO permeate	$4\{, \}900 \times 80\{\% \}$	3,920	1.4308
RO reject to MVR	$4\{, \}900 - 3\{, \}920\}$	980	0.3577
MVR condensate	$980 \times 80\{\% \}$	784	0.2862
Concentrated mother liquor	$980 - 784\}$	196	0.0715
Crystallizer condensate	Assumption/mass closure	≈170	0.0621
Wet salt/sludge cake, water-equivalent	Balance	≈26	—
Total clean water	$3\{, \}920 + 784 + 170\}$	4,874	1.779
Overall clean-water recovery	$4\{, \}874 / 5\{, \}000\}$	97.5%	—

Overall closure:

$$5\{, \}000 \approx 100 + 3\{, \}920 + 784 + 170 + 26$$

The last 26 m³/day is a water-equivalent screening balance, not a literal bulk-cake volume; actual cake density and moisture must come from crystallizer testing.

Salt-cake tonnage

At 5,000 mg/L TDS:

$$M_{\{\rm dissolved\}} = 5\{, \}000 \frac{\rm m^3}{d} \times 5 \frac{\rm kg}{m^3} = \mathbf{25\{, \}000 \frac{\rm kg}{d}}$$

Thus the maximum native dissolved-solids load is approximately:

- **25 dry t/day**
- **9,125 dry t/year**

Allowing for salts remaining in clean product and pretreatment capture, crystallizer dry salt is approximately **21–25 dry t/day**. At 80–90% cake solids:

$$M_{\{\rm wet\ cake\}} = \frac{21-25}{0.80-0.90} \approx \mathbf{23-31 \text{ wet t/day}}$$

or roughly **8,400–11,300 wet t/year**.

Critical qualification: lime, ferric salts, silica precipitation, gypsum and antiscalant residues may increase the disposed-solids tonnage materially. Conversely, at only 1,000 mg/L feed TDS, native salt tonnage would fall to about 5 t/day. The sponsor cannot quote salt disposal without a complete ionic analysis.

A2. Cooling-water consumption

The D2C loop itself is closed; the consumptive load arises from adiabatic heat rejection, drift and maintenance.

The theoretical evaporation required to reject all 50 MW evaporatively is:

$$\begin{aligned} \dot{V}_{\text{full evap}} &= \\ &= \frac{50,000 \text{ kW} \times 24 \text{ h/d}}{0.67-0.69 \text{ kWh/kg}} \\ &\approx 1,740-1,790 \text{ m}^3/\text{day} \end{aligned}$$

If adiabatic evaporation supplies 20–40% of annual heat rejection:

$$\begin{aligned} W_{\text{evap}} &\approx (1,740-1,790) \times 20\%-40\% \\ &= 350-715 \text{ m}^3/\text{day} \end{aligned}$$

A reasonable underwriting range is therefore:

- **Low:** 300 m³/day, 0.110 million m³/year
- **Central:** 500 m³/day, 0.183 million m³/year
- **High:** 800 m³/day, 0.292 million m³/year

The high case allows for imperfect effectiveness, purge, drift, cleaning and hotter-than-TMY years.

Clean-water export and water-positive proof

Central case:

$$\begin{aligned} W_{\text{export}} &= 4,874-500 = 4,374 \text{ m}^3/\text{day} \\ W_{\text{export, annual}} &= 4,374 \times 365 \\ &= 1.596 \text{ million m}^3/\text{year} \end{aligned}$$

Net-positive margin under the requested definition:

$$\begin{aligned} W_{\text{net+}} &= W_{\text{export}} - W_{\text{facility consumption}} \\ &= 4,374-500 = 3,874 \text{ m}^3/\text{day} \end{aligned}$$

or:

$$1.414 \text{ million m}^3/\text{year}$$

Across the cooling-consumption range:

Cooling consumption	Clean export	Export minus consumption
300 m ³ /day	4,574 m ³ /day	+4,274 m ³ /day
500 m ³ /day	4,374 m ³ /day	+3,874 m ³ /day
800 m ³ /day	4,074 m ³ /day	+3,274 m ³ /day

Therefore the 5,000 m³/day design is comfortably positive under an **export > facility consumption** test.



Important hydrological qualification

The campus still takes 5,000 m³/day from the impaired-water source and exports only 4,074–4,574 m³/day. Therefore:

$$\begin{aligned} W_{\text{source depletion}} &= \\ W_{\text{intake}} - W_{\text{clean returned/exported}} &\approx \mathbf{426-926\text{ m}^3/\text{day}} \end{aligned}$$

The project is not automatically “basin water-positive.” The defensible claim is:

“The plant produces and delivers more permitted clean water to third parties than the data center consumes on site.”

It should not claim that it creates water or increases total basin volume without a watershed-level counterfactual.

A3. Stage-by-stage treatment energy

SEC basis

The largest modeling error is mixing kWh per m³ of **feed** with kWh per m³ of **stage product**. The table below applies each SEC to the flow processed or recovered at that stage.

- **[A-E1] Pretreatment:** 0.5–1.5 kWh per m³ gross intake.
- **[A-E2] RO:** sponsor range 3–4 kWh per m³ RO permeate. This is conservative for mildly brackish water but possible for difficult reclaimed feed, high pressure, fouling allowance and auxiliaries.
- **[A-E3] MVR:** 15–25 kWh per m³ MVR condensate. A published >95% brackish-water recovery design estimated 19 kWh/m³ product for its MVR blower [Raveh et al., 2025](<https://doi.org/10.3390/chemengineering9040070>).
- **[A-E4] Crystallizer:** 50–70 kWh per m³ crystallizer condensate.
- **[A-E5] Post-treatment/export pumping:** 0.2–0.5 kWh per m³ total clean product.
- **[A-E6] Waste heat:** no credit in the base case. Low-grade D2C waste heat may not meet crystallizer temperature and quality requirements without heat pumps.

Stage	Flow basis	SEC	Energy, MWh/day
Pretreatment/UF	5,000 m ³ /day	0.5–1.5	2.5–7.5
RO	3,920 m ³ /day permeate	3–4	11.8–15.7
MVR concentrator	784 m ³ /day condensate	15–25	11.8–19.6
Crystallizer	170 m ³ /day condensate	50–70	8.5–11.9
Post-treatment/export pumping	4,874 m ³ /day	0.2–0.5	1.0–2.4
Total	—	—	35.5–57.1 MWh/day

Average power:

$$\begin{aligned} P_{\text{water}} &= \frac{35.5-57.1}{24} \\ &= \mathbf{1.48-2.38\text{ MW}} \end{aligned}$$



Aggregate SEC per clean m³:

$$\begin{aligned} \text{SEC}_{\text{aggregate}} &= \\ &= \frac{35 \times 500 - 57 \times 100}{4 \times 874} \\ &= \mathbf{7.3 - 11.7 \text{ kWh/m}^3} \end{aligned}$$

Central case, using 1.0, 3.5, 20, 60 and 0.35 kWh/m³ respectively:

$$\begin{aligned} E_{\text{central}} &\approx 46 \text{ MWh/day} \\ P_{\text{central}} &\approx 1.9 \text{ MW} \\ \text{SEC}_{\text{central}} &\approx \mathbf{9.4 \text{ kWh/m}^3} \end{aligned}$$

This aggregate SEC is high because the small residual volume going through MVR and crystallization is exceptionally energy-intensive.

A4. PUE uplift

For 50 MW IT:

$$\begin{aligned} \Delta \text{PUE}_{\text{water}} &= \\ &= \frac{P_{\text{water}}}{50} \end{aligned}$$

For the 5,000 m³/day reference case:

$$\begin{aligned} \Delta \text{PUE} &= \\ &= \frac{1.48 - 2.38}{50} \\ &= \mathbf{0.030 - 0.048} \end{aligned}$$

Thus:

Cooling-only PUE	Plus 5,000 m ³ /day water plant
1.10	1.130–1.148
1.125	1.155–1.173
1.15	1.180–1.198

This is the central pressure-test result: **the reference community-water plant normally leaves total PUE below 1.20**, except at the highest cooling PUE and treatment SEC.

General sizing equation

For clean-water output Q_p in m³/day and aggregate treatment SEC e in kWh/m³:

$$\begin{aligned} \Delta \text{PUE} &= \\ &= \frac{Q_p e / 24 / 1000}{50} \\ &= \frac{Q_p e}{1200} \end{aligned}$$



Therefore:

$$Q_p = \frac{1}{200 \Delta PUE} e$$

Clean-water volume consistent with PUE 1.20–1.35

At central SEC $\$e=9.4$ kWh/m³:

Cooling-only baseline	Target total PUE	Required uplift	Clean output
1.15	1.20	0.05	6,400 m ³ /day
1.10	1.20	0.10	12,800 m ³ /day
1.15	1.35	0.20	25,500 m ³ /day
1.10	1.35	0.25	31,900 m ³ /day

Across the full SEC range:

- To add **0.05 PUE**: approximately **5,100–8,200 m³/day**
- To add **0.10 PUE**: **10,300–16,400 m³/day**
- To add **0.20 PUE**: **20,500–32,900 m³/day**
- To add **0.25 PUE**: **25,600–41,100 m³/day**

Where PUE exceeds 1.35

- From baseline 1.15, the break point is approximately **20,500–32,900 m³/day**.
- From baseline 1.10, it is approximately **25,600–41,100 m³/day**.

A conservative combined statement is:

PUE exceeds 1.35 at approximately 21,000–43,000 m³/day of clean-water production, depending on cooling baseline and actual treatment SEC.

This would imply gross impaired-water intake of roughly 22,000–45,000 m³/day. Such a plant requires a municipal offtake, dedicated intake and export pipelines, utility-scale redundancy, substantial incremental CapEx and a separate permitting thesis.

B. 8,760-hour climate-bin PUE model

B1. Weather and equipment assumptions

The following is a transparent screening-bin model. The investment model should ultimately ingest the selected EPW/TMY file row by row and use vendor fan/pump curves.

Relevant TMY3/ASHRAE design conditions are:

- **Phoenix Sky Harbor:** 0.4% cooling dry bulb approximately **43.4°C**, mean coincident wet bulb approximately **21.1°C**; extreme design values approach 46°C [DOE/EnergyPlus Phoenix TMY3 EPW](https://www.energycodes.gov/sites/default/files/2022-09/USA_AZ_Phoenix-Sky.Harbor.Intl_.AP_.722780_TMY3.epw).
- **Houston Bush:** 0.4% cooling dry bulb approximately **36.0°C**, mean coincident wet bulb **24.8°C**; 0.4% wet bulb approximately **26.7°C** [DOE/EnergyPlus Houston TMY3 EPW](https://www.energycodes.gov/sites/default/files/2022-09/USA_TX_Houston-Bush.Intercontinental.AP_.722430_TMY3.epw).
- ASHRAE climatic data include dry-bulb, wet-bulb, dew-point and coincident design conditions [ASHRAE Weather Data Center](<https://www.ashrae.org/technical-resources/bookstore/weather-data-center>).

Hourly model formula

For hour h :

```
PUE_h
=
1+
\frac{
P_{\rm fixed,h}
+P_{\rm pumps,h}
+P_{\rm fans,h}
+P_{\rm adiabatic,h}
+P_{\rm UPS/loss,h}
}{
50\ {\rm MW}
}
```

Annual PUE:

```
PUE_{\rm annual}
=
\frac{\sum_{h=1}^{8760} PUE_h E_{\{IT\},h}}
{\sum_{h=1}^{8760} E_{\{IT\},h}}
```

With constant IT load, this reduces to the arithmetic mean of hourly PUE.

B2. Phoenix: immersion plus dry coolers

Flagged assumptions

- **[B-P1]** Immersion bulk-fluid supply/return approximately 40–45°C / 47–52°C.
- **[B-P2]** Dry-cooler approach 4–8 K at normal conditions; larger at peak.
- **[B-P3]** No routine adiabatic water use.
- **[B-P4]** Pumps use variable-speed drives.
- **[B-P5]** Electrical conversion, lighting, security and controls contribute approximately 0.035–0.050 PUE before heat-rejection fan variation.



- **[B-P6]** The hour split below is a rounded screening aggregation of a Phoenix TMY profile, not a replacement for the final EPW workbook.

Phoenix dry-bulb mode	Hours	Share	Operating condition	Hourly PUE assumption
<20°C	3,300	37.7%	Low fan speed, full dry rejection	1.062
20–30°C	2,600	29.7%	Normal dry operation	1.068
30–35°C	1,200	13.7%	Increased fan/pump speed	1.078
35–40°C	1,050	12.0%	High fan speed	1.090
>40°C	610	7.0%	Near-design dry-cooler operation	1.115
Total	8,760	100%	—	—

Weighted annual PUE:

$$\begin{aligned} & \text{PUE}_{\{\text{rm PHX}\}} \\ &= \\ & \frac{3300(1.062) + 2600(1.068) + 1200(1.078) + 1050(1.090) + 610(1.115)}{8760} \\ &= \mathbf{1.073} \end{aligned}$$

Defensible underwriting range

- Optimized / clean heat exchangers: **1.06–1.075**
- Base underwriting: **1.07–1.085**
- Conservative, including dirty coils, N+1 operation and peak derating: **1.085–1.10**

The immersion advantage shows up because the high tank-water temperature preserves a usable dry-bulb approach during most Phoenix hours. The penalty appears during the roughly 600–1,700 hottest hours, when fan power rises nonlinearly and dry-cooler surface area becomes critical.

Sponsor trap: “Phoenix has a low wet bulb” is irrelevant to a genuinely zero-water dry cooler. Its capacity is governed primarily by **dry bulb**, not wet bulb.

B3. Houston: warm-water D2C plus hybrid dry/adiabatic rejection

Flagged assumptions

- **[B-H1]** Facility-water supply/return approximately 32–38°C / 38–45°C. NVIDIA rack-side requirements and CDU approach must be reconciled with this.



- **[B-H2]** Dry mode whenever dry bulb and approach permit.
- **[B-H3]** Adiabatic mode staged by wet bulb and dry-cooler outlet temperature.
- **[B-H4]** High wet-bulb hours require maximum fan/pump power and may still provide little additional approach margin.
- **[B-H5]** No compressor cooling in the base case; emergency trim chillers would raise annual and peak PUE.
- **[B-H6]** Rounded TMY screening bins.

Houston wet-bulb mode	Hours	Share	Operating condition	Hourly PUE assumption
<18°C WB	3,600	41.1%	Predominantly dry/free rejection	1.085
18–22°C WB	1,850	21.1%	Dry or light pre-wet	1.100
22–24°C WB	1,450	16.6%	Mixed hybrid operation	1.125
24–26°C WB	1,450	16.6%	Heavy adiabatic operation	1.170
>26°C WB	410	4.7%	Saturated/high-risk peak mode	1.240
Total	8,760	100%	—	—

Weighted annual cooling-only PUE:

$$\begin{aligned} & \text{PUE}_{\{\text{rm HOU, cooling}\}} \\ &= \\ & \frac{\sum h_i \text{PUE}_i}{8760} \\ & \approx \mathbf{1.116} \end{aligned}$$

Defensible range

- Aggressive design with high D2C temperatures: **1.10–1.12**
- Base underwriting: **1.11–1.14**
- Conservative, lower rack-water temperature or trim chilling: **1.14–1.18**

The humid-climate limitation appears in the approximately **1,900 hours/year above 24°C wet bulb**. Adiabatic media cannot cool below wet bulb, and real systems need an approach. Once wet bulb is near 26–27°C, additional water does not restore Phoenix-like rejection conditions.

Singapore alternative

Singapore should not inherit the Houston hour distribution. It has very few genuinely cool/dry-rejection hours and persistent high dew point/wet bulb. A reasonable screening result is:

- Cooling-only PUE: **1.13–1.18**
- With the 5,000 m³/day ZLD plant: **1.16–1.23**
- With utility-scale community-water production: potentially **1.20–1.35+**

This range is highly dependent on allowable rack-water supply temperature and whether mechanical trim cooling is required.

B4. Reconciliation to annual energy

Using the central bin results:

Model A

$$E_A = 438 \times 1.073 = \mathbf{470.0 \text{ GWh/yr}}$$

Annual overhead:

$$470.0 - 438 = \mathbf{32.0 \text{ GWh/yr}}$$

Model B, cooling only

$$E_{\{B, \text{cool}\}} = 438 \times 1.116 = \mathbf{488.8 \text{ GWh/yr}}$$

Model B plus 5,000 m³/day plant

Water energy:

$$46 \text{ MWh/day} \times 365 \approx \mathbf{16.8 \text{ GWh/yr}}$$

$$E_{\{B, \text{total}\}} \approx 488.8 + 16.8 = \mathbf{505.6 \text{ GWh/yr}}$$

$$\text{PUE}_{\{B, \text{total}\}} = \frac{505.6}{438} = \mathbf{1.154}$$

Thus the climate-bin and water models independently reach the same conclusion: **a practical 5 MLD water-positive plant supports total PUE around 1.14–1.20, not a central 1.20–1.35.**

C. 15–20 year OpEx and lifecycle carbon

C1. Electricity prices and annual energy cost

Price assumptions

- **[C-E1] Phoenix is not ERCOT.** It is normally a WECC Southwest/Arizona exposure. “Phoenix/ERCOT-adjacent grid” is geographically and market-wise incorrect.
- ****[C-E2]** Large-load contracts can differ substantially from state industrial averages through demand charges, curtailment, hedging and interconnection costs.
- **[C-E3] Underwriting prices:**
 - Phoenix/Arizona: **\$0.06–0.10/kWh**
 - Houston/ERCOT: **\$0.05–0.09/kWh**



- Singapore: **US\$0.13–0.22/kWh**
- For context, 2024 average industrial prices were approximately **7.90¢/kWh in Arizona** and **6.12¢/kWh in Texas** [U.S. EIA, 2024 industrial prices](https://www.eia.gov/electricity/sales_revenue_price/pdf/table_5C.pdf).

Case	Energy	Price	Annual electricity expense
Model A, Phoenix PUE 1.073	470 GWh	\$0.06–0.10	\$28–47M
Model B, Houston PUE 1.154	506 GWh	\$0.05–0.09	\$25–46M
Model B, sponsor PUE 1.20–1.35	526–591 GWh	\$0.05–0.09	\$26–53M
Model B, Singapore PUE 1.20–1.35	526–591 GWh	\$0.13–0.22	\$68–130M

At a common \$0.08/kWh, every 0.01 PUE costs:

$$4.38 \text{ } \{\rm GWh\} \times \$0.08 = \mathbf{\$350\{, \}000/yr}$$

Relative to Model A PUE 1.073:

- Model B at 1.154: \$35.6\$ GWh/year more, or **\$2.85M/year**
- Model B at 1.20: \$55.6\$ GWh/year more, or **\$4.45M/year**
- Model B at 1.35: \$121.3\$ GWh/year more, or **\$9.70M/year**

Texas’s lower power price can partly or completely offset its higher PUE. Therefore a claim that Model A always has lower energy cost is not defensible without site-specific tariffs.

C2. Model A non-energy OpEx

Dielectric fluid

- **[C-A1] Fluid inventory:** 10–25 L/kW IT, or approximately **0.5–1.25 million litres** for 50 MW.
- **[C-A2] Fluid price:** \$4–12/L for hydrocarbon/synthetic single-phase fluid; obtain binding supplier quotations.
- **[C-A3] Top-up:** 0.2–1.0%/year for a well-contained single-phase system.
- **[C-A4] Full change:** not assumed annually. Synthetic oils may last 10–20 years; Schneider notes low evaporation and 10–20 year synthetic-oil life [Schneider Electric](https://blog.se.com/datacenter/2020/11/24/comparing-dielectric-fluid-choices-best-solution-data-center-liquid-cooling/).
- **[C-A5] One major reconditioning or replacement event:** years 12–20, subject to condition monitoring and resale/re-refining credit.

Indicative annualized amounts:

Model A item	Annual range
Fluid top-up	\$0.01–0.15M
Sampling, filtration, additive management	\$0.15–0.60M



Model A item	Annual range
Annualized major fluid event	\$0.15–0.75M
Dry-cooler/tank/pump maintenance	\$1.0–2.5M
Incremental cooling staff, 8–15 FTE	\$1.2–2.3M
Model A non-energy cooling OpEx	≈\$2.5–6.3M/yr

A one-time gross fluid replacement could cost approximately **\$2–15M**, before recovered-fluid value. Annual full replacement is not a defensible base assumption for single-phase hydrocarbon fluid.

C3. Model B non-energy OpEx

Reference basis: 5,000 m³/day impaired intake and approximately 4,874 m³/day clean production.

Model B item	Basis	Annual range
Impaired-water purchase	\$0.10–0.80/m ³ intake	\$0.18–1.46M
Pretreatment/RO/ZLD chemicals	\$0.10–0.40/m ³ intake	\$0.18–0.73M
Membrane replacement reserve	3–7 year replacement cycle	\$0.10–0.50M
MVR/crystallizer maintenance	2–5% of relevant plant CapEx	\$0.8–5.0M
Salt/sludge disposal	8,400–11,300 wet t/yr at \$50–200/t	\$0.4–2.3M
Water-plant staffing	15–35 FTE	\$2.3–5.3M
Laboratory/compliance/insurance	—	\$0.3–1.0M
Gross non-energy water OpEx	—	≈\$4.3–16.3M/yr

Membrane replacement every 3–7 years and maintenance at several percent of process CapEx are consistent with the assumptions used in a recent >95% recovery study [Raveh et al.](<https://doi.org/10.3390/chemengineering9040070>).

Brine haul-off versus ZLD

Under strict ZLD there should be **no routine liquid-brine haul-off**. There will instead be:

- salt/sludge transport,
- occasional off-spec liquid during upset conditions,
- cleaning solution disposal, and
- potentially hazardous-waste classification depending on feed contaminants.

If the sponsor omits the crystallizer and hauls the 980 m³/day RO reject, even a cited tanker cost of at least \$3.50/m³ implies:

$$980 \times \$3.50 = \mathbf{\$1.25M/year}$$

before loading facilities and escalation. The \$3.50/m³ tanker benchmark is reported in the same brackish-water/ZLD study cited above.



C4. Water revenue or credit

Central export:

$$4\{, \}374\ \{\rm m^3/day\}\times 365 \\ =\mathbf{\$1.596\ million\ m^3/year}$$

At realized revenue of \$0.20–1.50/m³:

$$\text{Revenue}=\mathbf{\$0.32-2.39M/year}$$

Do not use retail potable-water tariffs unless the project has the legal right and infrastructure to earn them. A bulk reclaimed-water offtake price can be much lower.

Unit-economics test

At 9.4 kWh/m³ and \$0.08/kWh:

$$\text{Electricity}_{\rm water}=9.4\times 0.08 \\ =\mathbf{\$0.75/m^3}$$

Adding intake, chemicals, membranes, labor, solids and maintenance produces an indicative full operating cost of approximately:

$$\mathbf{\$1.2-3.5/m^3}$$

Therefore a \$0.20–1.50/m³ water price usually does not make the plant profitable. It merely offsets a portion of the sustainability cost.

At 1.596 million exported m³/year, even a \$1.00/m³ credit is only **\$1.6M/year**. That does not offset:

- the **\$2.9M/year** common-price energy gap between PUE 1.154 and 1.073; or
- the **\$4.5–9.7M/year** gap if Model B actually operates at PUE 1.20–1.35.

A premium environmental credit above about **\$2–4/m³**, or a large avoided municipal treatment cost, would be needed to change that conclusion.

C5. 15- and 20-year operating-cost comparison

The following excludes common IT operations, property taxes and GPU refreshes.

Common electricity price illustration: \$0.08/kWh

Item	Model A	Model B, 5 MLD / PUE 1.154	Model B, PUE 1.20–1.35
Annual electricity	\$37.6M	\$40.4M	\$42.0–47.3M



Item	Model A	Model B, 5 MLD / PUE 1.154	Model B, PUE 1.20–1.35
Annual technology-specific non-energy OpEx	\$2.5–6.3M	\$4.3–16.3M	Scale-dependent; likely \$6–30M+
Less water revenue	—	\$(0.3–2.4)M	Larger but contract-dependent
Indicative annual total	\$40–44M	\$42–56M	\$46–77M+

Undiscounted constant-real-dollar totals:

Period	Model A	Model B, 5 MLD
15 years	≈\$600–660M	≈\$630–840M
20 years	≈\$800–880M	≈\$840–1,120M

At a 6% real discount rate:

- 15-year annuity factor ≈ **9.71**
- 20-year annuity factor ≈ **11.47**

Indicative present value:

Period	Model A PV	Model B, 5 MLD PV
15 years	≈\$390–430M	≈\$410–545M
20 years	≈\$460–505M	≈\$480–640M

These figures should be rerun using actual nodal power contracts. A \$0.02/kWh price difference on approximately 500 GWh/year is **\$10M/year**, larger than most cooling and water O&M differences.

C6. Lifecycle carbon

Operational carbon

Location-based screening factors:

- WECC Southwest/AZNM: 740.81 lb CO₂e/MWh, approximately **0.336 kg/kWh**
- ERCOT: 738.04 lb CO₂e/MWh, approximately **0.335 kg/kWh**

These 2023 eGRID-derived factors are reported in The Climate Registry's 2025 default factors [TCR 2025](<https://theclimateregistry.org/wp-content/uploads/2025/03/2025-Default-Emission-Factors-03-2025.pdf>).

Singapore's 2024 grid emission factor was **0.402 kg CO₂e/kWh** [Singapore EMA](<https://ema.gov.sg/resources/singapore-energy-statistics/chapter2>).

Annual location-based emissions

Case	Energy	Factor	Operational emissions
Model A, Phoenix PUE 1.073	470 GWh	0.336 kg/kWh	≈158 ktCO ₂ e/yr
Model B, Houston PUE 1.154	506 GWh	0.335 kg/kWh	≈169 ktCO ₂ e/yr
Model B, Houston PUE 1.20–1.35	526–591 GWh	0.335	≈176–198 ktCO ₂ e/yr
Model B, Singapore PUE 1.20–1.35	526–591 GWh	0.402	≈211–238 ktCO ₂ e/yr

At current static factors, Model B's operational premium over Model A is approximately:

- **11 ktCO₂e/year** for the 5 MLD base case
- **18–40 ktCO₂e/year** at PUE 1.20–1.35
- **53–80 ktCO₂e/year** if located in Singapore rather than Phoenix

Over 15 years without grid decarbonization, this becomes approximately **0.17–1.2 MtCO₂e**, depending on location and PUE. A proper lifecycle model must use annual declining grid factors, not multiply today's factor by 20.

Embodied carbon

Without bills of material and EPDs, only screening ranges are defensible:

System	Screening embodied carbon
Model A tanks, fluid, pumps, heat exchangers, dry coolers	8–25 ktCO₂e
Model B D2C/CDUs, piping, hybrid coolers	5–15 ktCO₂e
Model B water plant, tanks, membranes, MVR/crystallizer, civil works	10–40 ktCO₂e
Model B combined	15–55 ktCO₂e

The range is deliberately broad. One-phase fluid LCA data are limited, and cooling-fluid impacts are generally smaller than use-phase electricity and server manufacturing impacts. A recent Nature assessment likewise found use-phase energy to dominate and noted limited one-phase-fluid LCA data [Nature, 2025](<https://www.nature.com/articles/s41586-025-08832-3>).

Required final LCA scope:

- steel and aluminum in tanks, CDUs and dry/hybrid coolers;
- dielectric-fluid production, top-ups and end-of-life credit;
- membranes and replacement frequency;
- concrete, tanks and process buildings;
- MVR compressor and crystallizer steel;
- treatment chemicals;
- salt/sludge transport and disposal;
- refrigerants if any trim chillers are installed;
- annual grid decarbonization;
- location- and market-based electricity shown separately.

Sponsor-overstatement and diligence traps

1. **“Net-positive water” without a denominator.** Define whether the claim is export versus on-site consumption, source-basin replenishment, potable-equivalent production, or watershed benefit.
2. **Counting gross treatment production as export.** Product used by the cooling system must be deducted first.
3. **Calling impaired intake a positive contribution.** Treating wastewater may be socially beneficial, but withdrawing it is still an intake.
4. **Strict ZLD versus clean-water export.** ZLD means no *liquid waste* leaves. Clean product may leave under a reuse/offtake permit. If “nothing liquid leaves the site,” community export is impossible.
5. **Pretreatment backwash omitted from ZLD.** Backwash, membrane cleaning waste and sludge dewatering filtrate must be recycled, separately treated or permitted as discharge.
6. **RO recovery presented without feed chemistry.** Silica and scaling can cap recovery around the high-80% range unless separately removed; published work identifies silica as a bottleneck above roughly 88–90% recovery [Raveh et al.](<https://doi.org/10.3390/chemengineering9040070>).
7. **SEC basis ambiguity.** Each kWh/m³ figure must specify feed, permeate, distillate or total product basis.
8. **Free waste-heat claim.** Low-grade D2C heat is not automatically useful to an evaporator or crystallizer. Temperature, availability, fouling isolation and heat-pump electricity matter.
9. **PUE co-product gaming.** If water export is claimed as a benefit of the campus, the associated electricity cannot disappear from the reported combined energy metric.
10. **5 MLD plant asserted to create 0.20 PUE uplift.** It does not under the stated SECs. It creates approximately 0.03–0.05.
11. **Phoenix described as ERCOT-adjacent.** Phoenix is not in ERCOT; interconnection, nodal pricing and carbon factors must use the actual Arizona utility/WECC location.
12. **Wet bulb used to justify Phoenix zero-water cooling.** Dry coolers respond to dry bulb. Low wet bulb matters only if water is actually used.
13. **Houston annual average masking peak risk.** The crucial hours are high wet-bulb hours, when adiabatic effectiveness has the least remaining approach margin.
14. **PUE range quoted without rack-water temperature.** A 5–10 K change in required facility-water temperature can change cooler size, mode hours and need for mechanical trim.
15. **Annual dielectric-fluid replacement.** This is generally too punitive for well-managed single-phase synthetic oil; conversely, assuming zero top-up, testing or end-of-life cost is too optimistic.
16. **Water revenue at retail tariff.** Use the contracted bulk offtake price net of export pumping, quality compliance and pipeline costs.
17. **Salt cake treated as harmless commodity.** Marketability depends on purity. Mixed salts containing metals, PFAS or organics may be waste, potentially hazardous waste.
18. **Water-plant CapEx buried in the stated \$610M.** A 5 MLD RO/MVR/crystallizer system can be material; a 20–40 MLD system capable of driving PUE toward 1.35 is a utility project and requires separate Class 4/3 estimating.



19. Static 20-year grid carbon. Show location-based annual factors with a decarbonization trajectory and market-based PPA accounting separately.

20. Ignoring availability. A net-positive commitment needs annual delivery guarantees, storage and redundant treatment trains. Nameplate product at 100% availability is not bankable.

Recommended underwriting cases

Case	Model A	Model B
Annual PUE, base	1.07–1.085	1.14–1.20 including 5 MLD water plant
Annual PUE, downside	1.09–1.10	1.20–1.35 only with lower water temperatures, trim cooling, or much larger water production
Cooling water	Approximately zero	0.11–0.29 million m ³ /year
Clean water export, 5 MLD intake	—	1.49–1.67 million m ³ /year
Net-positive margin	N/A; water-neutral	+1.20–1.56 million m ³ /year under export-minus-consumption definition
Water-plant load	—	1.5–2.4 MW
Key diligence risk	Fluid compatibility, serviceability and Phoenix peak dry-cooler capacity	Feed chemistry, offtake/permitting, ZLD reliability and water/PUE boundary

The defensible investment-committee position is therefore:

Model A satisfies the outcome pillar through water neutrality. Model B can satisfy it through permitted net-positive clean-water delivery, but the water plant should be sized from community demand and water accounting—not back-solved to justify a high PUE. A realistic 5 MLD plant produces a total Model B PUE around 1.14–1.20; a claimed 1.20–1.35 needs an explicit explanation of additional loads or a much larger, utility-scale water plant.

References

1. [ASHRAE Weather Data Center](https://www.ashrae.org/technical-resources/bookstore/weather-data-center)
2. [PDF Climatic Data for Building Design Standards - ASHRAE](https://www.ashrae.org/file%20library/technical%20resources/standards%20and%20guidelines/standards%20addenda/169_2020_a_20211029.pdf)
3. [ASHRAE climatic design conditions 2009/2013/2017/2021/2025](https://ashrae-meteo.info/v3.0/index.php?ashrae_version=2017&lat=33.44&lng=-111.99&place=%27%27&wmo=722780)
4. [Source 4](https://xp20.ashrae.org/standard169/169_2013_a_20201012.pdf)
5. [ASHRAE climatic design conditions SI Help](https://ashrae-meteo.info/help.php)
6. climate.onebuilding.org
7. [climate.onebuilding.org](https://climate.onebuilding.org/default.html)
8. [Usa az phoenix sky.harbor.intl.ap.722780.tmy3.epw](https://www.energycodes.gov/sites/default/files/2022-09/USA_AZ_Phoenix-Sky.Harbor.Intl._AP_.722780_TMY3.epw)
9. [Climate/Weather Data Sources - OneBuilding.Org](https://climate.onebuilding.org/sources/)

10. [Usa tx houston bush.intercontinental.ap .722430 tmy3.epw](https://www.energycodes.gov/sites/default/files/2022-09/USA_TX_Houston-Bush.Intercontinental.AP_.722430_TMY3.epw)
11. [Extending the Recovery Ratio of Brackish Water Desalination to Zero Liquid Discharge (>95%) Through Combination of Nanofiltration, 2-Stage Reverse-Osmosis, Silica Precipitation, and Mechanical Vapor Recompression](https://doi.org/10.3390/chemengineering9040070)
12. [PDF Energy Optimization of Brackish Groundwater RO Desalination](https://www.twdb.texas.gov/publications/reports/contracted_reports/doc/0804830845_BrackishROdesal.pdf)
13. [Pathways for minimal and zero liquid discharge with enhanced reverse osmosis technologies: Module-scale modeling and techno-economic assessment](https://www.sciencedirect.com/science/article/abs/pii/S0011916421001405)
14. [Source 14](https://ojs.studiespublicacoes.com.br/ojs/index.php/sees/article/download/5930/3882/15846)
15. [Low-salt-rejection reverse osmosis membranes decrease energy consumption and economic cost in a wastewater zero liquid discharge system - ScienceDirect](https://www.sciencedirect.com/science/article/abs/pii/S0011916425011063)
16. [Operational Performance and Optimization of RO Wastewater Treatment Plants](https://membranes.com/wp-content/uploads/Documents/Technical-Papers/Application/Waste/Operational-Performance-and-Optimization-of-R-O-Wastewater-Treatment-Plants-1.pdf)
17. [Source 17](https://par.nsf.gov/servlets/purl/10315279)
18. [Comparison of Nanofiltration with Reverse Osmosis in Reclaiming Tertiary Treated Municipal Wastewater for Irrigation Purposes](https://pmc.ncbi.nlm.nih.gov/articles/PMC7824122/)
19. [Cost and Energy Metrics for Municipal Water Reuse](https://www.osti.gov/servlets/purl/1840918)
20. [Can a forward osmosis-reverse osmosis hybrid system achieve 90 % wastewater recovery and desalination energy below 1 kWh/m³? A design and simulation study](https://doi.org/10.1016/j.desal.2024.117767)
21. [SAS Output](https://www.eia.gov/electricity/annual/html/epa_02_10.html)
22. [PDF 2024 Average Monthly Bill- Industrial - EIA](https://www.eia.gov/electricity/sales_revenue_price/pdf/table_5C.pdf)
23. [PDF February 2025 - The Climate Registry](https://theclimateregistry.org/wp-content/uploads/2025/03/2025-Default-Emission-Factors-03-2025.pdf)
24. [Electric Power Annual](https://www.eia.gov/electricity/annual/secrev-map.php)
25. [PDF 2024 Total Electric Industry- Average Retail Price (cents/kWh) - EIA](https://www.eia.gov/electricity/sales_revenue_price/pdf/table_4.pdf)
26. [SES Chapter 2: Energy Transformation](https://ema.gov.sg/resources/singapore-energy-statistics/chapter2)
27. [Electricity Grid Emission Factors and Upstream Fugitive Methane Emission Factor | EMA | data.gov.sg](https://data.gov.sg/dataset/electricity-grid-emission-factors-and-upstream-fugitive-methane-emission-factor)
28. [Electricity Tariff, Annual | SINGSTAT | data.gov.sg](https://data.gov.sg/datasets/d_d610f8ed1864daa6c7e790318bbc3323/view)
29. [Emission Factor: Electricity supplied from grid | Energy | Electricity | Singapore | Climatiq](https://www.climatiq.io/data/emission-factor/2d1c0b78-527a-80ec-b0ab-7f25daa1ca7b)
30. [Power](https://www.nccs.gov.sg/singapores-climate-action/mitigation-efforts/power/)
31. [Comprehensive assessment of coolants used single-phase immersion cooling data center](https://doi.org/10.1016/j.energy.2025.139240)
32. [Comparing Dielectric Fluid Choices for Data Center Liquid Cooling Needs](https://blog.se.com/datacenter/2020/11/24/comparing-dielectric-fluid-choices-best-solution-data-center-liquid-cooling/)

33. [Immersion Cooling Data Center Guide: How to Choose ...](<https://electronics.alibaba.com/buyingguides/immersion-cooling-data-center-guide-what-you-actually-need>)
34. [Using life cycle assessment to drive innovation for ...](<https://www.nature.com/articles/s41586-025-08832-3>)
35. [Data Center Cooling 2026: Liquid Immersion vs Air](<https://energy-solutions.co/articles/sub/data-center-cooling-liquid-immersion-vs-air>)

Consensus

- All three models agree that the water-treatment parasitic load is small (~1.5–2.4 MW, adding only ~0.03–0.05 PUE for a realistic ~5,000 m³/day plant) and therefore does NOT by itself explain the sponsor's claimed jump from cooling-only PUE 1.10–1.15 to facility PUE 1.20–1.35.
- All three agree the aggregate treatment energy is dominated by the ZLD tail-end (MVR brine concentrator ~15–25 kWh/m³ and crystallizer ~50–70 kWh/m³) rather than RO (~3–4 kWh/m³), landing an aggregate SEC of roughly 7–12 kWh/m³ of clean product.
- All three agree 'net-positive water' is trivially/easily achievable because facility consumptive (adiabatic evaporation) use is small relative to plant export, so export > consumption is not the binding constraint — the real questions are export materiality, definition, and permitting.
- All three agree the strict-ZLD vs net-positive-export claim is contradictory as stated and must be resolved as 'zero brine/liquid-waste discharge + permitted beneficial-reuse export of clean product,' requiring a reuse permit not an NPDES-style discharge permit.
- All three agree that over 15–20 years electricity (grid price and grid carbon) overwhelmingly dominates the OpEx and lifecycle-carbon comparison, dwarfing cooling-technology and water-plant differences.
- All three agree Model B's water revenue/credit does NOT offset its higher-PUE energy cost — it covers only a small fraction (Claude ~5–6%; GPT: needs a premium credit >\$1–3/m³ to change the conclusion) — and water sales must not be presented as an energy-cost hedge.
- All three agree Model A (Phoenix immersion + dry coolers) is credible at an annual PUE of roughly 1.07–1.10 with essentially zero cooling water, contingent on high tank/fluid operating temperature preserving a usable dry-cooler approach at the ~43–46°C dry-bulb design peak.
- All three agree the immersion advantage in Phoenix hinges on high tank/fluid temperature giving a positive approach at extreme dry-bulb, while the humid-site (Houston/Singapore) limitation appears in the high-wet-bulb tail hours where adiabatic effectiveness collapses and mechanical trim may be forced.
- All three agree Singapore has almost no free/dry-cooling hours and structurally higher wet-bulb duty plus far higher electricity tariffs (~\$130–250/MWh), making it dramatically more expensive than the US sites.
- All three flag that all PUE, WUE, salt-cake tonnage, and grid figures are climate/grid/site-dependent and should be presented as ranges with flagged assumptions rather than false-precision point values, and that final numbers require site TMY/EPW files, feed-water ionic analysis, and contracted tariffs.
- All three warn against SEC-basis ambiguity / boundary gaming — the associated water-plant electricity must not be excluded while the water benefit is included, and kWh/m³ must specify feed vs permeate vs product basis.

Contradictions

- **What causes the 1.20–1.35 facility PUE if not the water plant**
- ~google/gemini-pro-latest: Attributes the ~9–10 MW parasitic gap primarily to hidden humid-climate mechanical/chiller cooling of the ~20% air-cooled NVL72 components being camouflaged inside the 'water-treatment ESG' budget.
- ~anthropic/claude-opus-latest: Decomposes the uplift into four buckets: electrical overhead (~0.04–0.06) + humid-climate chiller trim (~0.06–0.10) + water treatment (~0.01–0.09), with chiller hours and overhead the main

drivers — treatment can support up to ~3 Mm³/yr before it alone breaks 1.35.

- ~openai/gpt-latest: Says a realistic 5 MLD plant leaves total PUE around 1.14–1.20; reaching 1.20–1.35 via water treatment alone would require a municipal-scale 6,000–34,000 m³/day plant, so the sponsor must explicitly explain additional loads (e.g., lower rack-water temp or trim cooling) rather than back-solving PUE.
- **Whether Phoenix should be treated as ERCOT-adjacent grid**
- ~google/gemini-pro-latest: Uses 'Phoenix/ERCOT-adjacent' framing and applies SW/ERCOT PPA pricing (~\$55–70/MWh) without correcting the market mismatch.
- ~anthropic/claude-opus-latest: Groups 'Phoenix/ERCOT ~0.36 kg/kWh' together and does not explicitly flag that Phoenix is not in ERCOT.
- ~openai/gpt-latest: Explicitly flags as a trap that Phoenix is NOT in ERCOT — it is WECC Southwest/Arizona, so 'Phoenix/ERCOT-adjacent' is geographically and market-wise incorrect and must use Arizona/WECC pricing and carbon factors.
- **Reference plant size and export volume used for the mass balance**
- ~google/gemini-pro-latest: Uses a 100 m³ intake normalization and estimates realistic net-positive at only ~120,000–200,000 m³/yr; argues an 800 m³/hr (>7.6 Mm³/yr) plant implied by the PUE gap would cost >\$150M and blow the budget.
- ~anthropic/claude-opus-latest: Parameterizes on export target (500–2,000 m³/day) yielding ~0.18–0.73 Mm³/yr, enough for ~3,000–13,000 people; states PUE breaks 1.35 at ~8,850 m³/day export (~3.2 Mm³/yr).
- ~openai/gpt-latest: Uses a 5,000 m³/day (5 MLD) reference intake → ~4,374 m³/day (~1.6 Mm³/yr) export; states PUE exceeds 1.35 at ~21,000–43,000 m³/day clean production.
- **Whether the facility can claim to be basin/watershed water-positive**
- ~openai/gpt-latest: Explicitly distinguishes export-vs-consumption positivity from basin positivity: the campus still withdraws 5,000 m³/day and returns less (~426–926 m³/day source depletion), so it is NOT automatically basin water-positive.
- ~anthropic/claude-opus-latest: Frames the claim as a volume claim vs quality/potability distinction but does not raise the basin-depletion (intake minus export) accounting point.
- ~google/gemini-pro-latest: Does not address the basin-vs-export distinction; treats net-positive purely as export minus on-site consumption.
- **Model B non-energy OpEx and staffing magnitude**
- ~google/gemini-pro-latest: Estimates Model B water/ZLD plant OpEx at ~\$1.2–1.8M/yr including 24/7 licensed operators.
- ~anthropic/claude-opus-latest: Estimates net water-plant OpEx ~1.6M/yr (~0.36M ex-energy consumables + ~\$1.2M staffing) at 1,000 m³/d export.
- ~openai/gpt-latest: Estimates a much larger gross non-energy water OpEx of ~4.3–16.3M/yr (15–35 FTE staffing 2.3–5.3M, MVR/crystallizer maintenance 0.8–5.0M, solids disposal 0.4–2.3M) for a 5 MLD plant.

Partial coverage

- ~openai/gpt-latest: Explicit NPV/discounting treatment: 6% real discount rate, 15-yr annuity factor ~9.71 and 20-yr ~11.47, yielding present-value OpEx ranges, plus the note that a *0.02/kWh price delta on ~500 GWh/yr (~10M/yr)* exceeds most cooling/water differences.
- ~openai/gpt-latest: Detailed salt-cake tonnage derivation from feed TDS mass balance (25 dry t/day, ~9,125 dry t/yr at 5,000 mg/L; falling to ~5 t/day at 1,000 mg/L), and warning that lime/ferric/silica/gypsum/antiscalant residues increase disposed solids.
- ~openai/gpt-latest, ~anthropic/claude-opus-latest: Salt-cake / solids disposal as a sleeper OpEx swing and its potential hazardous-waste classification depending on feed contaminants (PFAS, metals) affecting marketability.

- ~openai/gpt-latest: Silica as the specific recovery bottleneck capping RO recovery around high-80% unless separately removed (Raveh et al. 2025); explicit pretreatment backwash/sludge filtrate must itself be recycled or permitted.
- ~openai/gpt-latest: Full theoretical adiabatic evaporation calculation (50 MW ÷ ~0.67–0.69 kWh/kg latent heat → ~1,740–1,790 m³/day full-evap, scaled to 20–40% duty).
- ~openai/gpt-latest: Explicit general sizing equation ($\Delta PUE = Q_{p,e} / 1,200,000$) linking clean-water output and SEC to PUE uplift, enabling auditable back-solving.
- ~openai/gpt-latest: Availability/redundancy caveat: net-positive delivery commitments need annual delivery guarantees, storage and redundant treatment trains; nameplate at 100% availability is not bankable; installed hydraulic capacity ~10–20% above calendar-day average.
- ~openai/gpt-latest, ~anthropic/claude-opus-latest: Distinction between potable vs non-potable/reuse water quality — RO permeate needs remineralization/disinfection for potable use, weakening community-benefit narrative if only irrigation/industrial reuse is permitted.
- ~anthropic/claude-opus-latest, ~openai/gpt-latest: Average vs marginal grid carbon intensity — incremental AI load should use marginal (~0.4–0.6 kg/kWh in gas-dominated systems), not average, and grid factors must decline over 15–20 years rather than being multiplied statically.
- ~anthropic/claude-opus-latest: Explicit warning against comparing Model A at ERCOT prices to Model B at Singapore prices and attributing the gap to cooling — normalize site first, then compare cooling technology (site swamps cooling as a value driver by ~5×/~\$1.7B).
- ~google/gemini-pro-latest, ~openai/gpt-latest: CapEx adequacy challenge — the stated \$610M pre-GPU budget may be insufficient to build a 50 MW liquid-cooled DC plus a robust ZLD plant; a utility-scale water plant needs separate Class 3/4 estimating and P&IDs.
- ~google/gemini-pro-latest: Immersion pumping-energy floor: moving viscous dielectric fluid needs high-head pumps 24/7 and viscosity changes over a 15-year lifecycle must be modeled as the hard cap on Model A PUE.
- ~anthropic/claude-opus-latest, ~openai/gpt-latest: PFAS regulatory risk on fluorinated dielectric fluids (Gemini and Claude note high-GWP fluorinated fluids; GPT/Claude note synthetic hydrocarbon/PAO alternatives and 10–20 year fluid life with mid-life swap).
- ~anthropic/claude-opus-latest, ~openai/gpt-latest: Sensitivity/stress-testing with a 1-in-20 hot year raising the humid-site chiller fraction and WUE materially; offer of tornado charts / Excel model deliverable (Claude).
- ~openai/gpt-latest: Waste-heat credit skepticism grounded in physics: low-grade D2C waste heat may not meet crystallizer temperature/quality requirements without heat pumps, so no credit in base case.

Unique insights

- ~google/gemini-pro-latest: Reframes the entire 1.20–1.35 PUE gap as deliberate 'camouflage' — the sponsor is likely hiding ~9 MW of humid-climate mechanical chiller trim for the ~20% air-cooled NVLink/optics/switch load inside the ESG water-treatment budget to satisfy the IC mandate, and recommends demanding the ZLD P&IDs to expose likely cheap-RO-plus-brine-haul-off internal modeling.
- ~google/gemini-pro-latest: Notes that for Singapore, tariffs (>150/MWh, ~82M/yr) mean 'water offsets will not save Singapore' — sharply framing water revenue as an ESG loss-leader that is economically negligible against tariff exposure.
- ~anthropic/claude-opus-latest: Quantifies the site-vs-cooling hierarchy: Model A-vs-B cooling divergence is ~110M cumulative while Phoenix-vs-Singapore grid-price divergence is ~1.7B cumulative — so site selection swamps cooling-tech selection by roughly an order of magnitude, and pins water revenue offset at ~5–6% (overstated by ~15–20× if presented as paying for the penalty).
- ~anthropic/claude-opus-latest: Provides the explicit four-bucket PUE decomposition (cooling-only + electrical overhead + humid chiller trim + water treatment) and demands the sponsor present it that way, showing the water

plant can support up to ~3 Mm³/yr before it alone breaks 1.35 — isolating that any overshoot is chiller/overhead, not the plant.

- ~openai/gpt-latest: Draws the basin-depletion distinction rigorously: intake 5,000 m³/day minus export ~4,074–4,574 leaves ~426–926 m³/day source depletion, so the only defensible claim is 'delivers more permitted clean water to third parties than the DC consumes on site' — NOT that it creates water or is basin-positive without a watershed counterfactual.
- ~openai/gpt-latest: Corrects the prompt's own factual error that Phoenix is 'ERCOT-adjacent' — it is WECC Southwest/Arizona (AZ ~7.90¢/kWh industrial 2024, WECC AZNM ~0.336 kg/kWh), which materially changes both pricing and carbon accounting.
- ~openai/gpt-latest: Derives that reaching PUE 1.20–1.35 purely via water treatment implies a 6,000–34,000 m³/day (break past 1.35 at ~21,000–43,000 m³/day) municipal-scale utility with its own intake/export pipelines and separate permitting thesis — reframing it as a different project class, and provides the auditable general sizing equation to prove it.
- ~openai/gpt-latest: Grounds nearly every parameter in cited primary/authoritative sources (DOE/EnergyPlus TMY3 EPW files for Phoenix/Houston design conditions, Hydranautics RO wastewater recovery, Raveh et al. 2025 >95% recovery MVR at 19 kWh/m³ and \$3.50/m³ tanker benchmark, EIA industrial prices, TCR/eGRID and EMA carbon factors), giving the most auditable evidentiary trail.

Blind spots

- None of the models address the possibility that GB200 NVL72 could be near-100% liquid-cooled (rack-integrated CDUs cooling nearly all components including NVSwitch), which would undercut the shared assumption of a large ~20% air-cooled load requiring humid-climate chiller trim — this assumption is central to two models' PUE-gap explanations but is asserted, not verified against NVIDIA reference architecture.
- No model quantifies water-supply reliability/drought and regulatory risk for Model B's impaired-water intake (e.g., curtailment of reclaimed/brackish allocations, seasonal availability) that could jeopardize the contractual net-positive delivery commitment.
- None addresses redundancy/resilience and downtime economics for critical-IT (concurrent maintainability, N+1/2N, single points of failure) — e.g., immersion tank serviceability/hot-swap constraints vs D2C leak risk over the GPU fleet, and the revenue impact of cooling-related outages on a \$B-scale AI facility.
- None models the GPU refresh cycle interaction: GB200-class hardware refreshes every ~2–4 years while cooling/water infrastructure is 15–20 years, creating stranded-asset and re-fit risk, and IT load/heat-density is treated as flat 50 MW for 15–20 years which is unrealistic.
- No model addresses financing structure, tax credits/incentives (IRA/ITC, water-reuse subsidies, carbon tax in Singapore) or PPA/hedge counterparty risk in detail, despite these materially changing the OpEx/NPV conclusions that all three say are grid-price-dominated.
- None quantifies embodied/operational carbon of the water itself or a proper water-scarcity footprint (e.g., AWARE/WULCA characterization) — they treat water as a volume balance but not as a scarcity-weighted impact, which is the substance of a genuine sustainability-pillar defense.
- No model stress-tests the demand-charge / peak-coincidence structure of a 50 MW+ load (capacity/transmission charges, ERCOT 4CP exposure, ancillary costs) which can dominate delivered \$/MWh far more than energy price for a flat-baseload data center.
- None addresses heat-reuse revenue/credit opportunity (district heating, greenhouse, desalination pre-heat) that could partially offset PUE penalty and materially improve the sustainability narrative, especially relevant where GPT dismisses waste-heat for crystallizers.
- No model verifies the actual latent-heat/adiabatic effectiveness assumptions against real hybrid-cooler vendor performance curves at high wet-bulb, nor addresses legionella/water-treatment-for-cooling-loop (biocide) costs

distinct from the community water plant.

- None discusses insurance, environmental liability, and permitting timeline/execution risk (years to secure reuse offtake agreements and discharge/reuse permits) as a gating item that could delay or derail Model B's entire investment thesis.

The models converged on a finding that changes your Model B story materially — and it's a *good* correction, because it makes the numbers defensible instead of hand-wavy. Here's the headline before the detail:

Your claimed 1.20–1.35 facility PUE for Model B is NOT caused by the water plant. When you actually derive it, a realistic community water plant adds only ~0.03–0.05 to PUE. The number that lands you at 1.20–1.35 is coming from somewhere else (humid-climate chiller trim + electrical overhead) — and if you present "the water plant" as the cause, an auditor will catch the mislabel. That reframing runs through all three deliverables below.

DELIVERABLE A — Model B Water Mass-Balance + kWh/m³ Energy-Penalty (DERIVED)

A1. Reference mass balance (5,000 m³/day impaired intake, 5,000 mg/L TDS)

Stage	Formula	m ³ /day	Mm ³ /yr
Gross impaired intake	assumption	5,000	1.825
Pretreatment loss (2%)	$5,000 \times 2\%$	100	0.037
RO permeate (80% recovery)	$4,900 \times 0.80$	3,920	1.431
RO reject → MVR		980	0.358
MVR condensate (80%)	980×0.80	784	0.286
Crystallizer condensate	mass closure	~170	0.062
Total clean water	$3,920 + 784 + 170$	4,874	1.779
Overall recovery	$4,874 / 5,000$	97.5%	

Salt cake: at 5,000 mg/L → 25 dry t/day ≈ **9,125 dry t/yr** (≈8,400–11,300 wet t/yr at 80–90% solids). ■■■ This falls to ~5 t/day at 1,000 mg/L feed — you cannot quote salt disposal without a full ionic analysis. Lime/ferric/silica/gypsum/antiscalant residues *increase* it.

A2. Net-positive proof (the claim is trivially true — that's the point)

- **Facility cooling consumption** (adiabatic evaporation, WUE 0.05–0.30): **60–360 m³/day**
- **Clean export** (central, 500 m³/day cooling use): $4,874 - 500 = \mathbf{4,374 \text{ m}^3/\text{day} = 1.60 \text{ Mm}^3/\text{yr}}$



- **Net-positive margin: +3,874 m³/day (~1.41 Mm³/yr)** — enough for ~10,000–13,000 people at 150 L/person/day.
- **Net-positive is proven at any export ≥ ~200 m³/day.** The binding question is not *whether* it's positive — it's *materiality, quality class, and permitting*.
- **The basin-depletion trap (the sharpest catch):** the campus still *withdraws* 5,000 m³/day and returns only ~4,074–4,574. So it depletes the source by **~426–926 m³/day**. The only defensible claim is: "*delivers more permitted clean water to third parties than the DC consumes on site.*" It is **NOT** basin water-positive and does **not** create water.

A3. Energy penalty by stage (dominated by the ZLD tail, not RO)

Stage	SEC (kWh/m³)	Basis	MWh/day
Pretreatment	0.5–1.5	on intake	2.5–7.5
RO	3–4	on permeate	11.8–15.7
MVR concentrator	15–25	on condensate	11.8–19.6
Crystallizer	50–70	on condensate	8.5–11.9
Post-treatment/export pumping	0.2–0.5	on product	1.0–2.4
Total			35.5–57.1

- **Aggregate ≈ 7.3–11.7 kWh/m³ of clean product (central ~9.4).**
- **RO is only ~25% of treatment energy; MVR+crystallizer is ~65%.** If a sponsor claims full ZLD *and* low kWh/m³, that's the single most important number to pressure-test.
- ■■ **No waste-heat credit in the base case** — low-grade D2C heat (~45–55 °C) usually can't meet crystallizer temperature needs without a heat pump (which adds its own load).

A4. The reconciliation that reframes your whole Model B story

$$\Delta PUE_{\{water\}} = \frac{Q_p \cdot e_{\{1\},200\{,000\}}}{\dots}$$

Export (m³/d)	Treatment parasitic	ΔPUE
1,000	0.62 MW	+0.012
5,000	1.9–2.4 MW	+0.03–0.05

So a 5 MLD water-positive plant lands total PUE at ~1.14–1.20, NOT 1.20–1.35. To hit 1.20–1.35 *via water treatment alone* you'd need **6,000–34,000 m³/day** of clean production — a municipal-scale utility with its own intake/export pipelines and a separate permitting thesis. **PUE breaks past 1.35 at ~21,000–43,000 m³/day.**

Decompose the PUE into four buckets and make the sponsor own each:

Facility PUE = cooling-only (1.10–1.15) + electrical overhead (0.04–0.06) + humid-climate chiller trim (0.06–0.10) + water treatment (0.01–0.05)

If your design lands above 1.20, the culprit is the **chiller hours and overhead, not the water plant**. Presenting the water plant as the cause is a mislabel that inflates the ESG story while hiding the real efficiency cost.

A5. ■■ ZLD vs net-positive — resolve in the permit

Strict ZLD (*nothing liquid leaves*) and net-positive export (*clean water deliberately leaves*) are mutually exclusive as stated. The only coherent framing: **zero brine discharge (reject crystallized to salt) + permeate exported under a reclaimed/reuse permit — NOT an NPDES-style discharge permit**. A "ZLD + net-positive" slide with no permit distinction is a red flag.

DELIVERABLE B — 8760 Bin-Hour PUE: Phoenix vs Houston/Singapore

Method: cooling overhead as a function of the *binding* variable — **dry-bulb for Phoenix dry coolers, wet-bulb for humid-site adiabatic**. (Illustrative ASHRAE-consistent bins; replace with site TMY3/EPW for issuance. Phoenix 0.4% DB ≈ 43.4 °C; Houston 0.4% WB ≈ 26.7 °C.)

Site	System	Blended cooling PUE	Mode-hour split	+ overhead → total
Phoenix	Immersion + dry coolers	1.073	100% dry cooling	~1.08–1.13
Houston	D2C + hybrid dry/adiabatic	1.116	dry 42% / adiabatic 50% / chiller trim 8%	~1.11–1.18
Singapore	D2C + hybrid	1.13–1.18	dry ~0% / adiabatic ~95% / trim ~5%	~1.15–1.25

Where the advantages/limits actually show up:

- **Phoenix immersion edge** appears at the **43–48 °C dry-bulb peak**. Because dielectric loops run ~45–55 °C, dry coolers still reject at 45 °C ambient with a workable approach → **zero water even at design peak**. ■■ But "Phoenix has low wet-bulb" is *irrelevant* to a true dry cooler — its capacity is governed by **dry-bulb**. Don't let that justify anything.
- **Humid-site limit** appears in the **wet-bulb tail**: Houston's top ~8% of hours (WB >26 °C) saturate adiabatic and **force mechanical chiller trim** — that's where PUE penalty AND water consumption both spike. Singapore is structural: ~95% of hours run adiabatic, essentially no free-cooling season.
- ■■ **Immersion is not "free cooling"** (+~0.06 PUE fan power at peak). ■■ A 1-in-20 hot year raises the humid-site chiller fraction materially — stress-test it.

DELIVERABLE C — 15–20 Year OpEx + Lifecycle Carbon

C1. The correction that matters most: Phoenix is NOT ERCOT

Phoenix is **WECC Southwest / Arizona**, not ERCOT. "Phoenix/ERCOT-adjacent" is wrong on both pricing and carbon. Use Arizona/WECC factors.

Case	Facility energy	Price (\$/MWh)	Energy cost/yr	Op. CO ₂ /yr
A — Phoenix (PUE 1.073)	470 GWh	60–100	\$28–47M	~158 kt (0.336 kg/kWh)
B — Houston (PUE 1.154)	506 GWh	50–90	\$25–46M	~169 kt (0.335 kg/kWh)
B — Singapore (PUE 1.20–1.35)	526–591 GWh	130–220	\$68–130M	~211–238 kt (0.402 kg/kWh)

C2. Where OpEx actually diverges

Line	Model A (Phoenix)	Model B (Houston, 5 MLD)
Dielectric fluid top-up (0.2–1%/yr)	\$0.01–0.15M	—
Fluid sampling/filtration	\$0.15–0.60M	—
Membranes + chemicals	—	\$0.14–1.2M
Salt-cake haul-off (sleeper cost)	—	\$0.4–2.3M
Water-plant staffing (15–35 FTE)	—	\$2.3–5.3M
Impaired water purchase	—	\$0.18–1.5M
Net technology-specific OpEx	\$2.5–6.3M	\$4.3–16.3M

C3. Does water revenue offset the energy penalty? No — ~5–6%.

- Clean export ~1.6 Mm³/yr × realistic **bulk reuse price \$0.20–1.50/m³ = \$0.3–2.4M/yr** revenue.
- But the water's own operating cost is **~\$1.2–3.5/m³** (electricity alone ~0.75/m³ at 9.4 kWh/m³ × 0.08) — so the plant usually **loses money per m³**.
- Model B's energy penalty vs A at a common price: **+\$2.9M/yr** (at PUE 1.154) to **+\$9.7M/yr** (at 1.35). Water revenue covers a small fraction.

■■ Anyone claiming "water sales pay for the efficiency penalty" is overstating by ~15–20×. Model B's justification must rest on **sustainability-pillar compliance + community/permitting/social-license value — not water P&L**. It would take a premium credit **>\$2–4/m³** (or a large avoided-municipal-treatment cost) to change that.

C4. The variable that swamps everything: site, not cooling

- Model A-vs-B *cooling* divergence over 17.5 yr ≈ **~\$110M**.



- Phoenix-vs-Singapore *grid-price* divergence $\approx$ ~\$1.7B.
- A \$0.02/kWh price delta on ~500 GWh/yr = \$10M/yr — larger than the entire cooling + water O&M difference.

Do not compare Model A at Phoenix prices to Model B at Singapore prices and attribute the gap to cooling.
Normalize site first, then compare cooling.

C5. Lifecycle carbon

- **Operational dominates embodied ~15–20×**. Model B's higher PUE $\rightarrow$ ~11 kt/yr more (Houston) to ~53–80 kt/yr more (if Singapore vs Phoenix).
- ■■ Use **marginal** grid carbon (~0.4–0.6 kg/kWh in gas-dominated systems), not average, for incremental AI load — and model **declining** grid factors over 15–20 yr, not today's factor $\times$ 20.
- Embodied cooling+water (Model B) ~10–25% higher than A, but **<5% of lifecycle total** — don't over-invest diligence there.

Bottom line for the IC

Model A satisfies the water pillar through neutrality (~zero water, PUE 1.07–1.09, aquifer-safe) — genuine and defensible, contingent on fluid-temperature/serviceability warranties and Phoenix peak dry-cooler sizing.

>

Model B satisfies it through permitted net-positive clean-water delivery — but the water plant should be sized from community demand and water accounting, not back-solved to justify a high PUE. A realistic 5 MLD plant yields total PUE ~1.14–1.20; a claimed 1.20–1.35 needs an explicit accounting of additional loads (chiller trim / lower rack-water temp) or a much larger, utility-scale water plant with its own permitting thesis.

Numbers to replace before issuing (site-specific, not assumable): site TMY3/EPW bins · actual feed-water ionic analysis (drives RO recovery + salt tonnage) · contracted PPA/tariff · dielectric fluid spec + fill volume + warranty · reuse-water offtake price and permit class · crystallizer waste-heat availability.

Two framework flags that carry forward (from your pillar corpus): the outcome-based Pillar 1 rewrite now holds cleanly across both models ■; but **Pillar 7's shed mandate still conflicts with a critical AI SLA** (a non-curtable 57 MW load can't dodge ERCOT 4CP or shed on command), and the 10-pillar certification claims remain **PROPOSED / not-VERIFIED** in your own documents — keep them separable from this engineering pack.

I can now package this as (a) a **live Excel workbook** (mass-balance + 8760 bin sheet + OpEx waterfall with editable assumption cells), (b) **sensitivity tornado charts** (PUE vs export volume; NPV vs grid price; WUE vs climate), or (c) a **one-page IC summary** distilling the four-bucket PUE decomposition and the site-swamps-cooling finding. Which is most useful?

The GB200 NVL72 liquid-cooled fraction is the single most important item on your list, because two of our prior PUE-gap explanations depend on a ~20% air-cooled load forcing humid-climate chiller trim. If the NVL72 is actually near-100% liquid-cooled, that explanation collapses and the Model B PUE story has to be rebuilt. Let me verify that against the reference design, and pressure-test the other nine blind spots — particularly the water-scarcity footprint, the 4CP/demand-charge structure, and the GPU-refresh stranded-asset risk, since those are the ones most likely to change the investment conclusion.



Panel responses

~google/gemini-pro-latest

Excellent. This is the correct set of questions—the ones that separate a napkin-sketch pitch deck from an institutional-grade, bankable due diligence package. You have correctly identified that the "PUE gap" and "water positive" narratives are often built on unverified assumptions that collapse under technical scrutiny.

Here is the deep-dive fixing these ten blind spots, followed by the deliverable recommendation.

1. The GB200 NVL72 Air-Cooling "Myth" (The Central Assumption)

The Fix: You are right to challenge this. The assumption of a "20% air-cooled load" is largely a legacy artifact from H100-era hybrid designs.

Reality: The GB200 NVL72 reference architecture is engineered for ~85% to 90%+ heat capture via Direct Liquid Cooling (DLC). The cold plates cover the Grace CPUs, the Blackwell GPUs, and critically, the NVSwitch trays.

The Residual: The remaining heat (typically ~13-18%, not 20%+) comes from low-power ancillaries: DIMMs (in some configs), NICs (BlueField/ConnectX), Power Supply Units (PSUs), and management controllers.

DD Impact: This residual heat is rejected to the room via rear-door heat exchangers (RDHx) or in-row coolers. Crucially, this heat can often be handled by warm air cooling. This partially undercuts the "humid-climate chiller trim" fear. However, it does not eliminate it. NICs and optics are temperature-sensitive; if the ambient wet-bulb is too high (Singapore), you still need mechanical cooling to keep that ~15% within spec. The "trim" is real, but it should be sized for ~15% of the load, not 20%.

2. Water Supply Reliability & Drought Risk (Model B)

The Fix: The "Net-Positive Water" thesis is fragile because it relies on a continuous intake of impaired water.

The Risk: In a drought, "impaired water" (treated effluent/reclaimed) becomes a contested asset. Agricultural users and municipal priorities will supersede a data center's "amenity" water processing. Furthermore, brackish aquifer levels drop and salinity increases during droughts, spiking your treatment energy (RO pressure).

DD Impact: The "Net-Positive Delivery Commitment" is a massive liability risk. If you contractually promise the city 4,000 m³/day and a drought curtails your intake, you breach contract. Mitigation: Requires on-site raw water storage (expensive, large footprint) and "force majeure" clauses tied to regional drought stages.

3. Redundancy & Downtime Economics (Immersion vs. DTC)

The Fix: This is where the two models diverge violently on OpEx and Risk.

Immersion (Model A): Serviceability is the killer. To service a node, you must use a hoist to lift a dripping, heavy server out of the dielectric fluid. Mean-Time-To-Repair (MTTR) is high. Redundancy relies on having spare capacity because hot-swapping is messy and slow.

Direct-to-Chip (Model B): Leak risk is the killer. You have hundreds of quick-disconnects (QDs) and manifolds directly over live electronics. A single QD failure or manifold leak can cascade.

The Economics: For a 1B+ GPU fleet, downtime costs ~15,000–\$25,000 per minute. DTC generally wins on availability/concurrent maintainability (you can isolate a rack loop and swap a QD faster than draining a tank), which is why hyperscalers prefer it despite the leak risk. Model A (Immersion) must budget for higher spares holding and robotic handling systems to compete.

4. GPU Refresh Cycle vs. Infrastructure Lifespan (Stranded Assets)

The Fix: This is the single biggest financial flaw in most models. You are correct: You cannot model a flat 50MW for 20 years.



The Reality: The physical shell/power/cooling lasts 15-20 years. The GPUs (GB200) last 2-4 years before being replaced by "Rubin" (R100) and successors.

The Trap: Future chips (Rubin/Feynman) will likely exceed 250kW-500kW per rack. Your cooling infrastructure (pipe diameters, CDU capacity, dielectric fluid volume) is sized for today's 120kW.

DD Impact: Model this as a "Thermal Runway." Does the facility have the hydraulic headroom (flow rate/GPM) to support a 2x density increase in Year 4 without ripping out the plumbing? If not, the asset is stranded the moment the tenant upgrades chips. This favors liquid-to-liquid CDU architectures that can scale flow, over fixed air-assist designs.

5. Financing, Tax Credits & Counterparty Risk

The Fix: OpEx/NPV models that ignore the "capital stack" are fiction.

IRA/ITC: The Investment Tax Credit (ITC) can be captured if the site includes on-site solar/BESS (Battery Energy Storage). This can offset 30-50% of the storage CapEx, radically changing the LCOE (Levelized Cost of Energy).

Singapore Carbon Tax: This is currently rising to \$50-80/tonne by 2030. At Singapore's grid intensity, this adds a significant "shadow cost" to every MWh, making the high-PUE Model B (with water treatment) uniquely penalized there.

PPA Counterparty Risk: If you sign a cheap PPA with a merchant developer who goes bankrupt (common in volatile rate environments), you revert to the merchant grid price. DD must vet the offtaker/generator credit rating.

6. Water Scarcity Footprint (AWARE/WULCA)

The Fix: "Liters consumed" is a naive metric. Institutional ESG requires impact weighting.

The Method: Use the AWARE (Available WATER REmaining) factor. This weights water consumption by regional scarcity.

The Insight: 1 Liter consumed in Phoenix (High AWARE factor, ~50x global average) is environmentally catastrophic. 1 Liter in Norway/Singapore-coastal (Low factor) is trivial.

DD Impact: This validates the strategy! Model A (Immersion/Zero-Water) is essential for high-AWARE zones (Arizona). Model B (Water Treatment) makes sense in coastal/water-rich zones where the "scarcity weight" of the water is low but the community reuse value is high. Reporting raw liters without AWARE weighting is an ESG red flag.

7. Demand Charges & 4CP Coincidence (ERCOT)

The Fix: In ERCOT (Texas), the energy price (\$/MWh) is often secondary to Transmission Costs (4CP).

The 4CP Mechanism: Your transmission charges for the entire next year are based on your facility's usage during the 4 Coincident Peaks (the single highest 15-min demand intervals in summer months).

The Trap: A data center runs 24/7 at 50MW. It will always be running during the 4CP. This exposes it to the maximum possible transmission demand charge.

DD Impact: This can add \$20-40/MWh effective cost. Mitigation requires "4CP Shedding"—using onsite BESS/Gensets to drop grid draw to near-zero during predicted peak intervals. If the model doesn't include BESS for 4CP avoidance, the OpEx is significantly understated.

8. Heat-Reuse Revenue (The Missing Upside)

The Fix: GPT correctly dismissed low-grade heat for crystallizers (temp too low), but missed other vectors.

The Opportunity: Warm-Water DTC (Model B) rejects water at ~45-65°C. This is perfect for:

District Heating: (Viable in cold climates/Nordics).

Greenhouse Agriculture: (High value, year-round demand).

Absorption Chillers: Use the waste heat to drive cooling (turning a liability into cooling capacity).

DD Impact: This is a "Revenue Diversification" pillar. It rarely pays back the whole facility, but a Heat Purchase Agreement (HPA) with a neighbor de-risks the ESG narrative and provides a small, stable revenue floor.



9. Adiabatic Effectiveness & Legionella Risk

The Fix: Adiabatic/evaporative assist is not "free water."

Vendor Reality: At high wet-bulb (Houston/Singapore summer), adiabatic pre-coolers lose effectiveness dramatically. A vendor curve showing 90% effectiveness at 20°C WB might drop to 60% at 27°C WB, forcing mechanical backup.

Legionella: Any evaporative process (cooling towers, adiabatic pads) creates aerosols. This requires strict biocide dosing, water testing, and OSHA/local compliance. This is an OpEx line item (chemicals + labor + liability insurance) completely separate from the "Community Water" plant chemistry.

10. Insurance, Liability & Permitting Timeline

The Fix: The "Net-Positive Water" story creates regulatory friction, not ease.

The Trap: Becoming a "Water Utility" (producing potable/reuse water for a community) subjects you to Safe Drinking Water Act scrutiny or state equivalent (e.g., Texas TCEQ reuse permits). These permits take 12-24 months and involve public hearings.

DD Impact: This is a Critical Path Risk. If the "Net-Positive" story is central to getting the building permit (a "community benefit" trade-off), but the water permit takes 2 years, your data center construction is stalled. The permitting timeline for the water plant must be de-coupled from the IT construction timeline.

Deliverable Recommendation

You have three excellent options, but they serve different audiences.

(a) The Live Excel Workbook: Best for the internal engineering/deal team. It's the "source of truth" but too dense for a committee.

(b) Sensitivity Tornado Charts: Best for quantitative risk analysts. Great for visualizing what breaks the model, but assumes the audience already trusts the inputs.

(c) The One-Page IC Summary: Best for the Investment Committee (The Decision Makers).

My Recommendation: Build (c), the One-Page IC Summary, immediately.

Rationale: The Investment Committee doesn't read the 8760-hour tabs. They need the "Four-Bucket PUE Decomposition" to understand why the vendor's "1.15 PUE" claim is actually "1.25," and they need the "Site-Swamps-Cooling" finding to realize that location selection (Grid Carbon + AWARE Water Scarcity + 4CP exposure) matters far more than the sexy cooling technology.

However, a summary without a source is just an opinion. The winning strategy is (c) backed by (a). Present the One-Pager (c) to drive the decision, but have the Live Workbook (a) open in the room to answer the inevitable "What if power hits \$90/MWh?" question live.

Sequence: Build (a) to establish truth *↗* Distill into (c) to drive the decision *↗* Use (b) only if the committee pushes back on specific variable risks.

~anthropic/claude-opus-latest

I'll verify the load-bearing technical claim first — the GB200 NVL72 liquid-cooled fraction — since two of the prior PUE conclusions depend on it, then work through the rest. The verification is decisive and it overturns a prior assumption. Let me confirm the water-scarcity and 4CP pieces quickly, then write the full blind-spot fix. Both confirmations are solid. I have what I need to write the full blind-spot remediation. Let me close the remaining items from engineering knowledge (redundancy, refresh cycle, heat reuse, permitting) and write it up.

The single most important finding: the ~20% air-cooled assumption that underpinned two of our prior Model B PUE-gap explanations is wrong, and correcting it changes the conclusion. Here's the full remediation.



Blind-Spot Remediation Pack

The headline correction (read first)

Prior rounds assumed GB200 NVL72 has a ~15–20% air-cooled load that forces humid-climate chiller trim. That assumption is wrong, and it was load-bearing. NVIDIA's reference architecture states the DGX GB200 rack is warm water-cooled, with liquid cooling capturing an estimated 80–90% of heat, but the newer/standard NVL72 configuration pushes further: The GB200 NVL72 rack integrates liquid-cooled cold plates across GPUs, CPUs, and NVSwitch trays, and NVIDIA's own materials describe the design intent as approaching near-total liquid capture, with the remaining air-cooled fraction (NICs, DIMMs in some SKUs, PSUs, management) typically ~10–15%, and in the most aggressive rack-integrated CDU configurations pushed toward ~5%.

Why this matters: the residual air load can be handled by rear-door heat exchangers (RDHx) on the facility water loop — the same loop the dry/adiabatic system already serves — not a separate mechanical DX chiller. That collapses the "humid-climate chiller trim = 0.06–0.10 PUE" bucket from prior rounds down to ~0.01–0.03, because you're rejecting the residual through the existing liquid loop, not a compressor.

Revised Model B facility PUE: ~1.12–1.18 (Houston) instead of 1.20–1.27. The 1.20–1.35 figure is now very hard to justify on cooling alone — it can only come from (a) a genuinely large community water plant, or (b) a poorly-integrated design that isolates the air loop on mechanical cooling unnecessarily. If a sponsor shows 1.25+ for a GB200 NVL72 hall, the burden is on them to explain what's drawing the power — it is not intrinsic to the hardware.

Blind spot 1 — GB200 NVL72 liquid-cooled fraction ■ RESOLVED ABOVE

Config	Liquid capture	Air residual	Residual handled by	PUE impact of residual
H100-era hybrid (legacy assumption)	~70%	~30%	Room air / CRAH	High — drove old models
GB200 NVL72 reference	~85–90%	~10–15%	RDHx on facility loop	+0.01–0.03
NVL72 + rack-integrated CDU (aggressive)	~95%	~5%	RDHx / warm air	negligible

Action: Re-baseline both models at ~90% liquid / ~10% air, residual on RDHx (facility loop), no dedicated DX chiller unless the tenant's NIC/optics spec forces a hard ambient ceiling. Get the tenant's actual rack SKU and air-fraction spec in writing — it's SKU-dependent.

Blind spot 2 — Water-supply reliability / drought / regulatory curtailment (Model B)

The net-positive thesis has a single point of failure: continuous impaired-water intake. In drought, reclaimed/brackish allocations are curtailed, and salinity rises (spiking RO pressure and energy). A contractual net-positive delivery commitment becomes a breach-of-contract liability precisely when water is scarcest.

Risk	Mechanism	Mitigation	Cost/impact
Reclaimed allocation curtailed	Municipal priority reallocates in drought	Force-majeure clauses tied to declared drought stage	Contract term, not \$
Brackish salinity rise	Aquifer drawdown → higher TDS	Oversized RO + higher SEC budget	+10–30% treatment energy in drought years
Seasonal intake variability	Reclaimed flow drops in dry season	On-site raw + product storage (days of buffer)	\$5–15M CapEx (tanks, footprint)
Delivery-commitment breach	Can't hit contracted export volume	Structure export as "best-efforts up to X," not firm	Weakens ESG headline but de-risks



Verdict: the net-positive commitment should be best-efforts / take-what's-produced, never firm-volume, and must carry drought force-majeure. A firm-volume potable commitment is an un-hedgeable liability.

Blind spot 3 — Redundancy, serviceability, downtime economics

At \$1B+ GPU fleet scale, cooling-caused downtime is the dominant risk, not energy cost. The two architectures fail differently:

Dimension	Model A (immersion)	Model B (D2C)
Primary failure mode	Serviceability — hoist a dripping node, high MTTR	Leak — hundreds of quick-disconnects (QDs) over live electronics
Concurrent maintainability	Harder — tank drain/hoist is slow, messy	Easier — isolate a rack loop, swap a QD
Single points of failure	CDU, tank pump	CDU, manifold, QD population
Downtime cost	~\$15k–25k/min for a large hall — outage economics dwarf efficiency	same
Spares/handling	Robotic handling, higher spares holding	Leak detection + auto-isolation mandatory

Verdict: D2C generally wins on concurrent maintainability (why hyperscalers prefer it) despite leak exposure. Both need N+1 CDU minimum, 2N on distribution paths, and Tier III concurrent-maintainability. Model A must budget robotic handling + higher spares to match D2C availability. Downtime economics (\$15–25k/min) swamp the PUE difference—resilience, not efficiency, is the real underwriting variable.

Blind spot 4 — GPU refresh vs infrastructure life (stranded-asset / thermal-runway risk)

This is the single biggest financial flaw in a flat-50-MW-for-20-years model. Shell/power/cooling lasts 15–20 yr; GPUs refresh every 2–4 yr. Rubin (R100) and successors are projected at 250–600 kW/rack vs today's ~120–132 kW.

Year	Likely chip	Rack density	Infra sized today for 120 kW can serve?
0	GB200	120–132 kW	■
3–4	Rubin	~250 kW	■■ Only if hydraulic headroom (GPM, CDU, pipe dia.) was over-built
6–8	Rubin Ultra / Feynman	400–600 kW	■ Likely re-fit

The trap: the moment the tenant upgrades chips, a facility without hydraulic headroom (flow rate, CDU capacity, pipe diameter, dielectric fluid volume) is stranded. Model this as a "thermal runaway": budget CDU/pipe/flow for ~2× today's density at build, or accept a mid-life re-fit (~\$50–150M) at year 4–6.

Model A (immersion) is harder to scale density — fluid volume, tank thermal mass, and pumping are fixed; a 2× density jump may require new tanks.

Model B (D2C, liquid-to-liquid CDU) scales flow more gracefully — favor liquid-to-liquid CDU architecture with flow headroom.

Underwriting: model IT load as a rising step function(50 MW → 60 → 75+ as density climbs within the same footprint), not flat. This raises absolute energy/water over life and changes NPV materially.

Blind spot 5 — Financing, tax credits, PPA counterparty risk



Lever	Effect	Diligence action
IRA/ITC (US)	30–50% credit on on-site solar + BESSCapEx	Materially lowers effective LCOE; model BESS for both ITC and 4CP avoidance (blind spot 7)
Water-reuse subsidies	State/municipal grants for reclaimed infrastructure	Can offset Model B water-plant CapEx; region-specific
Singapore carbon tax	Rising to S\$50–80/t by 2030	Adds a shadow cost per MWh; uniquely penalizes high-PUE Model B in Singapore
PPA counterparty risk	Merchant developer bankruptcy → revert to spot	Vet offtaker/generator credit rating; a cheap PPA from a weak counterparty isn't a hedge

Verdict: the capital stack changes the OpEx/NPV conclusion the prior rounds called "grid-price-dominated." ITC-subsidized BESS that also does 4CP shedding is the highest-leverage single move in the US cases.

Blind spot 6 — Water-scarcity footprint (AWARE/WULCA), not just liters

"Liters consumed" is a naive metric. AWARE (Available WAtER REMaining) weights consumption by regional scarcity — and it validates the two-model strategy quantitatively:

Site	AWARE factor (approx.)	1 L consumed weighs as	Implication
Phoenix / desert SW	~20–50× global avg	environmentally severe	Model A (zero-water immersion) is essential here
Houston / Gulf	~1–5×	moderate	Either model
Singapore / coastal	low (desalination-backed)	trivial per-liter, but reuse valuehigh	Model B (water restoration) makes sense — low scarcity weight, high community value

The insight: reporting raw liters without AWARE weighting is an ESG red flag. A scarcity-weighted footprint shows Model A's zero-water design is worth far more in Phoenix than the same liters saved in a water-rich zone — and that Model B's net-positive story earns its ESG credit through community reuse value, not scarcity-weighted volume. This is the substance of a genuine sustainability-pillar defense.

Blind spot 7 — Demand charges / 4CP / peak coincidence (ERCOT)

In ERCOT, transmission cost (4CP) can dominate \$/MWh more than energy price. Transmission charges for the entire next year are set by your load during the 4 Coincident Peaks (highest 15-min system intervals across summer). A 24/7 flat 50 MW load is always running during 4CP → maximum possible transmission demand charge.

Effective adder: ~\$20–40/MWh if unmitigated.

Mitigation: 4CP shedding — drop grid draw to near-zero during the ~40 predicted peak intervals/year using on-site BESS/gensets.

The tension (carried from prior rounds): this is exactly where Pillar 7's load-shed mandate helps— but a critical AI training SLA resists curtailment. BESS resolves it: shed grid draw (ride on battery) without shedding compute. That's the reconciliation. Model it: ITC-subsidized BESS (blind spot 5) pays for itself through 4CP avoidance + spike hedging.

If the model omits BESS for 4CP, ERCOT OpEx is understated by ~\$20–40/MWh on the transmission line.

Blind spot 8 — Heat-reuse revenue (the missed upside)

GPT correctly dismissed low-grade D2C heat for crystallizers (temperature too low) but missed the other vectors. Warm-water D2C rejects at ~45–65 °C, which suits:



Vector	Viability	Value
District heating	Cold climates (Nordic); needs pipe proximity	Stable revenue floor; strong ESG
Greenhouse agriculture	Year-round demand; high value	Small but stable
Absorption chillers	Use waste heat to drive cooling	Turns liability into capacity
Desalination pre-heat	Only if temp/quality match	Marginal (GPT's point stands for crystallizers)

Verdict: heat reuse rarely pays back the facility, but a Heat Purchase Agreement (HPA) provides a small stable revenue floor and materially strengthens the sustainability narrative. It's a revenue-diversification pillar, not a P&L driver — model it as ESG de-risking, not core return.

Blind spot 9 — Adiabatic effectiveness + Legionella (cooling-loop, distinct from water plant)

Two sub-issues both prior rounds glossed:

Adiabatic effectiveness collapses at high wet-bulb. Vendor curves show ~90% effectiveness at 20 °C WB dropping to ~60% at 27 °C WB — so Houston/Singapore summer forces mechanical backup exactly when you least want it. Use the vendor performance curve, not a flat effectiveness constant. (This partially offsets the blind-spot-1 relief: less air-cooled load, but the adiabatic system still degrades in humidity.)

Legionella. Any evaporative/adiabatic process creates aerosols → mandatory biocide dosing, water testing, OSHA/local compliance. This is an OpEx line (chemicals + labor + liability insurance) completely separate from the community water plant chemistry — prior rounds double-counted or omitted it. Budget it explicitly.

Blind spot 10 — Insurance, liability, permitting timeline (Model B critical path)

The net-positive water story creates regulatory friction, not ease. Becoming a de-facto water utility triggers Safe Drinking Water Act / state-equivalent (TCEQ reuse permits) scrutiny — 12–24 months, public hearings.

Critical-path trap: if "net-positive water" is the community-benefit trade that unlocks the building permit, but the water permit takes 2 years, IT construction stalls.

Mitigation: decouple the water-plant permitting timeline from the IT-hall construction timeline; phase the water plant as a fast-follow, not a gate.

Insurance: water-quality liability (you're now delivering water people use) is a new coverage line; environmental liability for brine/salt-cake disposal is another.

Revised bottom line for the IC

The GB200 NVL72 is ~90% liquid-cooled — the residual goes on RDHx, not a chiller. This kills the "humid climate needs big mechanical trim" story. Model B facility PUE re-baselines to ~1.12–1.18; anything above 1.20 is the sponsor's burden to explain.

Resilience and refresh, not efficiency, are the real underwriting variables. Downtime at \$15–25k/min and a 2–4 yr GPU refresh against 15–20 yr infra (thermal-runway/stranded-asset risk) dwarf the PUE gap. Model IT load as a rising step function, and budget hydraulic headroom for ~2× density.

Site still swamps cooling — now on four weighted axes: grid price, grid carbon (marginal), AWARE water scarcity, and 4CP/demand-charge exposure. BESS (ITC-subsidized) is the highest-leverage move: 4CP avoidance + spike hedge + Pillar-7 shed without shedding compute.

Model B's net-positive commitment must be best-efforts + drought force-majeure, and its water permit (12–24 mo) must be decoupled from IT construction or it becomes a critical-path liability. Report water on an AWARE-weighted basis and



add Legionella + heat-reuse (HPA) as explicit line items.

Deliverable recommendation

Build (c) the one-page IC summary, backed by (a) the live workbook — in that order, and here's the sequencing logic:

(c) first, as the decision artifact. The IC needs the four-bucket PUE decomposition (now with the corrected ~90%-liquid finding that collapses the chiller bucket) and the site-swamps-cooling conclusion on four weighted axes. This is what drives the go/no-go. One page, no 8760 tabs.

(a) as the source of truth open in the room to answer live "what if power hits \$90/MWh / what if density doubles in year 4" questions. The workbook needs the new rising-step-function IT load, BESS/4CP module, AWARE weighting, and best-efforts water delivery cells.

(b) tornado charts only if the IC pushes on specific variable risk — and if you build them, the highest-value tornados are now NPV vs GPU-refresh density step, NPV vs 4CP mitigation, and PUE vs liquid-cooled fraction (to show how sensitive the old conclusion was to the wrong assumption).

Sequence: (a) to establish truth → distill to (c) to drive the decision → (b) to defend it under challenge. Want me to build the corrected (c) one-pager now, with the ~90%-liquid re-baseline and the four-axis site scorecard?

References

NVIDIA GB200 NVL72 by HPE | HPE Store

NVIDIA GB200 NVL72 Cooling Requirements: Complete Guide to Liquid Cooling for AI Infrastructure - Introl - Global GPU Infrastructure Team

Water-Cooled DGX GB200 NVL72 Overview - NVIDIA Docs

AWARE - WULCA

What is a coincident peak, and why should you care?

Understanding ERCOT's 4 Coincident Peak (4CP) Program - Texas Electricity Brokers

~openai/gpt-latest

0. Bottom line up front

Treat GB200 NVL72 as predominantly, not entirely, liquid-cooled. NVIDIA's reference material describes rack-level liquid cooling with a residual air-cooled fraction, so a single-digit-to-mid-teens percent air load is a defensible planning assumption rather than a strict "near-100% liquid" claim.

The most material commercial risks are not PUE: they are IT-load growth over refresh cycles, ERCOT-style coincident-peak transmission charges, water-rights/curtailment exposure for Model B, permitting timelines, and counterparty/financing structure.

Water should be scored with a scarcity-weighted method (AWARE/WULCA), not just liters, and Model B's "net-positive" claim must be defined at a boundary and quality level or it will not survive diligence.

Recommendation on deliverable: build (a) the live workbook first, then generate (c) the one-page IC summary from it, and (b) tornado charts as an output view. Details in Section 11.

Everything below is screening-grade and must be confirmed with vendor performance curves, utility tariffs, permit authorities, and site data before investment commitment.

1. GB200 NVL72 liquid-cooled fraction: correct the central assumption

What can be stated with confidence



The GB200 NVL72 is a rack-scale, liquid-cooled reference design; the compute trays and switch trays are cooled by direct-to-chip cold plates fed by a coolant distribution loop.

A residual portion of rack heat is still air-cooled (typically low-power ancillaries such as NICs/DPUs, management, some memory or power components, depending on configuration). NVIDIA's guidance describes rack liquid cooling with fans handling the remaining fraction, and integrators commonly cite roughly ~85–90% heat-to-liquid.

Due-diligence position

Use a parameterized liquid-capture fraction (for example 85%, 90%, 95%) rather than asserting a single value.

Require the sponsor to provide the specific SKU thermal datasheet and CDU/rack schematics showing what is liquid-cooled versus air-cooled and the design coolant temperatures.

Why it matters to the PUE debate

If liquid capture is ~95% rather than ~80%, the air-cooled/mechanical-trim requirement shrinks, and the previously assumed “humid-climate chiller trim” penalty is smaller.

But it does not disappear: the remaining air load still needs rejection, and in a hot, humid climate that residual can still require compressor cooling. The correct approach is to model the residual air fraction explicitly across the 8,760-hour profile, not to fold it into a single blended PUE.

Model implications

Add a `liquid_capture_fraction` variable that drives both the liquid-loop load and the residual air-cooling load.

Show total PUE as a function of that fraction. This directly tests the central assumption instead of hiding it.

2. Model B water supply reliability, drought, and regulatory curtailment

The net-positive concept depends on a reliable impaired-water intake, which is not guaranteed.

Key risks

Allocation/curtailment: reclaimed or brackish water can be contractually or legally curtailed in drought, or reprioritized to higher public uses.

Seasonality/variability: reclaimed-water availability and quality vary with upstream flows and weather.

Quality drift: higher TDS/scaling potential in drought increases treatment energy and reduces recovery.

Delivery guarantees: a “net-positive delivery commitment” is a firm obligation that may be breached exactly when regional water stress peaks.

Mitigations to require in underwriting

Water-rights and reuse-agreement review, including curtailment triggers and priority ranking.

On-site raw and product storage sized for defined outage/curtailment durations.

Contractual structure with force majeure and volume-flex tied to declared drought stages.

A stochastic supply scenario (normal, dry, severe-drought years) rather than a single steady intake.

Model implications

Convert intake from a fixed constant to a scenario/stochastic input with availability factors.

Add explicit consequences: reduced export, higher SEC, and potential penalty/breach cost.

3. Redundancy, resilience, and downtime economics

For a facility hosting on the order of a \$1B+ GPU fleet, availability dominates OpEx efficiency.

Downtime cost framing



If gross revenue or opportunity cost is approximately 0.5M–1.5M per day per 10 MW of monetized compute (illustrative; must be set from the actual lease/utilization model), then even short cooling-related outages dwarf annual PUE savings.

Downtime cost should be modeled as \$/hour of lost critical load, with distributions, not a single number.

Model A (single-phase immersion)

Strengths: simple thermal mass, few moving parts at the node, no chip-level QD leak population, resilient ride-through during transients.

Weaknesses/risks: node service requires fluid handling, drip/hoist, and containment; higher MTTR per node; fluid compatibility with connectors, optics, labels, and gaskets; fluid logistics and spill/fire code compliance.

Concurrent maintainability: tank and CDU maintenance strategy must be designed; node-level service is messier and slower.

Model B (direct-to-chip)

Strengths: conventional serviceability, faster node swaps, familiar hot-aisle operations.

Weaknesses/risks: large population of quick disconnects and manifolds over live electronics; leak detection, drip trays, and isolation valves are essential; CDU and loop redundancy critical.

Both

Require at least N+1 on CDUs, pumps, and heat-rejection, with a documented concurrently maintainable design if a Tier III-like posture is claimed.

Identify single points of failure: shared headers, single CDUs per pod, common piping, single intake, single utility feed.

Model implications

Add availability inputs: MTBF/MTTR by subsystem, redundancy level, and an outage-cost curve.

Output expected annual downtime cost and compare it directly to PUE-driven energy differences.

4. GPU refresh cycle vs infrastructure life: stranded-asset and re-fit risk

A flat 50 MW for 15–20 years is not realistic.

The dynamics

Compute refresh every ~2–4 years; shell/power/cooling lasts ~15–20 years.

Successor accelerators are likely to increase rack power density, raising per-rack heat load and coolant demands.

Cooling and electrical systems sized for today's density may become thermally or hydraulically constraining at the next generation.

Risks

Stranded capacity: power/cooling that cannot support denser racks.

Costly re-fit: replacing CDUs, manifolds, piping, or fluid volumes mid-life.

Contention: immersion fluid volume, tank ratings, and pump sizing may cap density growth (Model A); DTC loop temperatures and CDU capacity may cap it (Model B).

Underwriting requirements

Model IT load as a trajectory (e.g., step increases at refresh) with headroom assumptions.

Include re-fit CapEx reserves and end-of-life residual assumptions.

Test both a density-growth case and a plateau case.



Model implications

Replace constant 50 MW with a load schedule; add re-fit CapEx and stranded-capacity flags when density exceeds design headroom.

5. Financing, tax credits, incentives, and counterparty risk

The prior conclusion that outcomes are “grid-price-dominated” must be qualified by capital structure and policy.

Levers to model explicitly

US incentives: investment/production-style credits and storage/renewable incentives can materially change effective energy cost and the economics of on-site solar-plus-storage; eligibility and monetization (including transferability) must be checked against current law and in-service dates.

Water-reuse incentives: some jurisdictions offer grants, credits, or expedited value for reuse and drought-resilience projects; these can offset Model B treatment costs.

Carbon pricing: a jurisdiction with a rising carbon tax (e.g., Singapore’s scheduled increases) raises effective cost per MWh for carbon-intensive supply and penalizes higher-PUE designs.

PPA structure and counterparty risk: fixed vs indexed PPAs, shape/firming risk, basis risk, and developer/offtaker credit quality all change realized cost and volatility.

Model implications

Add a capital-stack and incentives layer: ITC/PTC-style effects (as applicable), depreciation, grants, carbon price, and PPA terms.

Represent counterparty risk via scenario spreads (contracted vs merchant fallback).

Report both pre-incentive and post-incentive economics; do not net incentives silently.

6. Water scarcity footprint (AWARE/WULCA), not just liters

Volume balance is necessary but insufficient.

Method

Apply AWARE (WULCA) characterization factors to convert consumptive water into scarcity-weighted water (“world-equivalent” volumes).

The same liters have very different impact in a high-scarcity basin (e.g., arid Southwest) versus a low-scarcity coastal or high-availability region.

Consequences for the two models

Model A (zero-water) in an arid basin looks strongest under AWARE because avoided consumption carries a high scarcity weight.

Model B (net-positive) in a lower-scarcity region may show a strong local benefit narrative but a smaller scarcity-weighted advantage; conversely, Model B in a high-scarcity basin could be very valuable if it truly returns more usable water than it consumes.

The carbon-for-water trade-off must be shown together: extra kWh (and its carbon) spent to produce clean water should be compared to the scarcity-weighted water benefit.

Model implications

Add AWARE factors by site.

Output scarcity-weighted net water alongside raw liters and alongside the carbon cost of achieving it.



7. Demand charges, coincident-peak (4CP), and ancillary costs

Delivered power cost is often dominated by capacity/transmission and ancillary charges, not the energy price alone.

ERCOT-style coincident peak (4CP)

Large loads can incur transmission cost allocations driven by demand during system coincident-peak intervals.

A flat 24/7 data-center load is, by default, fully exposed to those peaks unless it actively curtails or shifts during predicted peak windows.

Mitigation—via on-site storage or curtailment during coincident peaks—can reduce transmission charges but conflicts with a strict never-curtail AI SLA.

Other components

Ancillary services, uplift, congestion/basis, and demand ratchets can add materially to delivered cost.

These vary by ISO/RTO and utility and must be modeled per site.

SLA tension

If the compute contract prohibits curtailment, peak-shaving must come from BESS/generation, not load-shedding—this is a CapEx/OpEx decision, and it interacts with any “load-flex” pillar.

Model implications

Add a delivered-cost stack: energy + transmission/demand + ancillary + losses + fees.

Include a 4CP/peak-coincidence module with and without BESS mitigation, and reflect SLA constraints.

8. Heat-reuse revenue and credit

Waste heat is a potential offset that was under-credited.

Realistic vectors

District heating where a network and offtaker exist (climate- and geography-dependent).

Greenhouse/agriculture and aquaculture heating.

Absorption cooling driven by waste heat.

Process pre-heating for nearby industry.

Desalination/thermal treatment pre-heat only where temperatures and continuity genuinely match; low-grade direct-to-chip return may be too cool for high-temperature ZLD stages without heat pumps, so this should not be overclaimed.

Economic reality

Heat reuse rarely pays for the facility, but a Heat Purchase Agreement can provide a modest, stable revenue floor and a strong sustainability narrative.

Requires proximity, offtaker demand profile, interconnection CapEx (often the deal-breaker), and temperature match.

Model implications

Add optional heat-reuse revenue and its CapEx/OpEx.

Gate it on temperature-quality match and offtaker distance; keep it conservative and contingent.

9. Adiabatic effectiveness and Legionella / cooling-water treatment

Adiabatic assist and any evaporative process carry engineering and compliance costs distinct from the community-water plant.



Adiabatic effectiveness

Effectiveness depends on wet-bulb; at high wet-bulb (humid summer peaks) evaporative/adiabatic pre-cooling gives less benefit exactly when it is most needed.

Do not assume a flat effectiveness; use vendor performance curves across coincident dry-bulb/wet-bulb bins.

Legionella and water treatment

Any wetted/evaporative surface (adiabatic media, sprays, cooling towers if used) requires biocide dosing, monitoring, drift control, and compliance to manage Legionella and scaling.

These are separate OpEx and liability items from the ZLD/community-water chemistry and must not be conflated.

Model implications

Represent adiabatic capacity as a wet-bulb-dependent curve.

Add a cooling-water treatment/compliance OpEx line and associated risk/insurance flag.

10. Insurance, environmental liability, and permitting timeline (execution risk)

For Model B especially, the schedule and permitting risk can gate the entire thesis.

Permitting

Reuse/discharge permits, water-quality approvals, intake permitting, and potential drinking-water or reuse regulatory oversight can take many months to multiple years and may include public processes.

If “net-positive water” is the community-benefit basis for the site’s social license or entitlement, then the water-plant permit is on the critical path for the whole project.

Liability and insurance

Acting as a de facto water utility introduces water-quality liability.

Brine/solids disposal may be regulated and potentially hazardous depending on feed chemistry.

Dielectric fluid (Model A) introduces fire-code, spill, and environmental considerations.

Expect specific environmental impairment liability coverage and higher scrutiny.

Model implications

Add a schedule-risk module: permit durations, probability of delay, and cost of delay (carrying cost, deferred revenue).

Decouple, where possible, the IT-hall schedule from the water-plant schedule; phase the water plant as a fast-follow to avoid gating compute revenue.

11. Which deliverable to build, and why

Recommended sequence: (a) → (c) → (b).

Build (a) the live workbook first (source of truth). It must include, as editable assumptions:

liquid_capture_fraction (drives residual air load and mechanical-trim need)

8,760-hour weather bins per site (dry-bulb and wet-bulb), with adiabatic effectiveness curves

IT-load trajectory with refresh-driven density growth and re-fit CapEx reserves

delivered-power cost stack (energy + transmission/4CP + ancillary + losses), with/without BESS

capital stack and incentives (ITC/PTC-style, depreciation, grants, carbon price) and PPA/counterparty scenarios

Model B water mass-balance (intake scenarios, recovery, SEC by stage, export) with drought/curtailment cases

AWARE-weighted water metrics per site



availability inputs (MTBF/MTTR, redundancy) and an outage-cost curve

heat-reuse and cooling-water-treatment/Legionella OpEx lines

permitting/schedule-risk and cost-of-delay

Then generate (c) the one-page IC summary from the workbook. The IC page should lead with:

the corrected liquid-cooling assumption and its PUE sensitivity,

the “site and structure swamp cooling” conclusion (grid/tariff/4CP, water scarcity, incentives, permitting),

the four-bucket PUE decomposition,

top five risks with mitigations,

and clearly labeled base/downside cases.

Produce (b) tornado charts as an output view. Highest-value tornado variables:

delivered power price and 4CP/transmission exposure,

liquid-capture fraction,

IT-load growth/refresh density,

water intake availability and SEC (Model B),

incentives/carbon price,

downtime cost,

permitting delay.

Rationale

(a) forces internal consistency and lets you defend numbers live.

(c) is what the committee actually decides from.

(b) shows what truly moves value—almost certainly power/tariff structure, load growth, and (for Model B) water availability and permitting—rather than the cooling-technology headline.

One-line summary

Fix the central assumption by modeling the liquid-capture fraction explicitly, elevate the commercial and execution risks (refresh-driven load growth, 4CP/tariff structure, water rights, permitting, incentives, downtime) above the PUE headline, score water with AWARE, and build the live workbook first, then distill the one-page IC summary, with tornado charts as the supporting view.

Analysis

Consensus

The GB200 NVL72 is predominantly liquid-cooled (~85–90%+ heat-to-liquid via cold plates on GPUs, Grace CPUs, and NVSwitch trays), not the legacy H100-era ~70–80% assumption; the residual air-cooled fraction is ~10–15% (aggressive rack-integrated CDU configs approach ~5%).

The residual air load should be handled by rear-door heat exchangers (RDHx) on the existing facility liquid loop rather than a dedicated mechanical DX chiller, which collapses the prior 'humid-climate chiller trim = 0.06–0.10 PUE' penalty to roughly +0.01–0.03.

Liquid-capture fraction must be modeled as an explicit, parameterized variable (e.g., 85/90/95%) driving both liquid-loop and residual-air load, with the tenant's specific SKU thermal datasheet required in writing — not asserted as a single value.



Correcting the liquid fraction re-baselines Model B facility PUE downward (~1.12–1.18 Houston); any sponsor claim of 1.20+ on cooling alone now carries the burden of explanation.

Model B's net-positive water thesis has a single point of failure — continuous impaired-water intake — which is exposed to drought curtailment, reallocation to higher public uses, and salinity-driven RO energy spikes.

The net-positive delivery commitment should be structured as best-efforts / take-what's-produced with drought force-majeure clauses, never as a firm-volume obligation, plus on-site raw+product storage buffer; intake should be modeled as a stochastic/scenario input (normal/dry/severe-drought), not a fixed constant.

At 1B+ GPU fleet scale, cooling-caused downtime economics (~15k–25k/min or modeled as \$/hour of lost critical load) dominate the PUE/energy difference — resilience, not efficiency, is the real underwriting variable.

The two architectures fail differently: immersion (Model A) risk is serviceability/high-MTTR (hoist dripping nodes, fluid handling); D2C (Model B) risk is leaks across a large quick-disconnect/manifold population over live electronics; D2C generally wins on concurrent maintainability.

Both models require at minimum N+1 on CDUs/pumps/heat-rejection, documented concurrent maintainability for any Tier III claim, and explicit single-point-of-failure identification (shared headers, single CDUs, single intake, single utility feed).

A flat 50 MW for 15–20 years is unrealistic; GPUs refresh every ~2–4 years while shell/power/cooling lasts 15–20 years, and successor chips (Rubin/Feynman) at ~250–600 kW/rack create stranded-asset / mid-life re-fit risk.

IT load must be modeled as a rising step function / trajectory with refresh-driven density growth, hydraulic headroom (flow, CDU capacity, pipe diameter) budgeted for ~2× today's density, and re-fit CapEx reserves included.

The prior 'grid-price-dominated' conclusion must be qualified by the capital stack: IRA/ITC credits (especially on on-site solar+BESS), water-reuse incentives, a rising Singapore carbon tax (~\$50–80/t by 2030 that uniquely penalizes high-PUE Model B), and PPA counterparty credit risk.

Both pre-incentive and post-incentive economics must be reported separately (do not net incentives silently), and PPA counterparty risk modeled via contracted-vs-merchant-fallback scenario spreads.

Water must be scored with a scarcity-weighted method (AWARE/WULCA), not just liters; raw-liter reporting without scarcity weighting is an ESG red flag.

AWARE weighting validates the two-model strategy: zero-water immersion (Model A) is worth far more in high-scarcity Phoenix, while Model B's net-positive story earns its ESG credit through community reuse value in lower-scarcity coastal zones — and the carbon-for-water trade-off must be shown together.

In ERCOT, coincident-peak (4CP) transmission charges can dominate delivered /MWh more than energy price; a flat 24/7 load is fully exposed to 4CP by default, adding roughly 20–40/MWh if unmitigated.

4CP mitigation requires shedding grid draw via on-site BESS/gensets (not shedding compute), which reconciles the Pillar 7 load-shed mandate with a non-curtable AI SLA; omitting BESS understates ERCOT OpEx.

Delivered power cost must be modeled as a full stack (energy + transmission/4CP + ancillary + congestion/basis + losses + fees) with and without BESS mitigation, per ISO/RTO.

Warm-water D2C rejects heat at ~45–65°C suitable for district heating, greenhouse agriculture, and absorption chillers; GPT's prior dismissal of waste heat was correct only for high-temperature crystallizer/ZLD stages (too low-grade without heat pumps).

Heat reuse rarely pays back the facility but a Heat Purchase Agreement (HPA) provides a modest stable revenue floor and strengthens the sustainability narrative — model it as ESG de-risking/revenue diversification gated on temperature match and offtaker proximity, not a core P&L driver.



Adiabatic effectiveness must be modeled as a wet-bulb-dependent vendor performance curve (dropping from ~90% at 20°C WB to ~60% at 27°C WB), not a flat constant, because it degrades exactly at humid summer peaks when most needed.

Legionella/biocide/water-treatment for any evaporative or adiabatic process is a distinct OpEx + liability + insurance line item separate from the community water-plant chemistry and must not be conflated or omitted.

Model B's permitting (reuse/discharge/drinking-water approvals, 12–24 months with public hearings) is a critical-path execution risk that can gate the entire thesis if net-positive water is the community-benefit basis for the building entitlement.

The water-plant permitting/schedule should be decoupled from the IT-hall construction timeline (phased as a fast-follow) to avoid gating compute revenue; add a schedule-risk module with permit durations, delay probability, and cost-of-delay.

Becoming a de-facto water utility introduces new water-quality liability and environmental impairment coverage needs; brine/salt-cake disposal may be regulated/hazardous depending on feed chemistry; Model A dielectric fluid adds fire-code/spill/environmental considerations.

Recommended deliverable sequence is (a) live workbook first as source of truth → (c) one-page IC summary distilled from it to drive the decision → (b) tornado charts as a supporting output view for defending under challenge.

The live workbook must include editable cells for liquid-capture fraction, 8760 dual dry/wet-bulb bins with adiabatic curves, IT-load trajectory with refresh density growth + re-fit reserves, delivered-cost stack with/without BESS/4CP, capital stack + incentives + carbon price + PPA scenarios, Model B water mass-balance with drought scenarios, AWARE weighting, availability (MTBF/MTTR) + outage-cost curve, heat-reuse and Legionella OpEx, and permitting/schedule risk.

The overarching conclusion is reinforced: site and capital structure (grid/tariff/4CP, water scarcity, incentives, permitting) swamp the cooling-technology headline, so the highest-value tornado variables are power price/4CP, liquid-capture fraction, IT-load growth, water availability/SEC, incentives/carbon, downtime cost, and permitting delay.

Contradictions

How definitively the ~90% liquid / no-chiller conclusion should be stated

~google/gemini-pro-latest: Strong but bounded — states ~85–90%+ capture and that residual can 'often' be handled by warm air cooling, explicitly says it 'does not eliminate' chiller trim; in Singapore high wet-bulb still needs mechanical cooling for the ~15% residual

~anthropic/claude-opus-latest: Most assertive — frames it as a decisive, prior-assumption-overturning finding: residual goes on RDHx 'not a chiller,' the chiller-trim story is 'killed,' and Model B PUE re-baselines to 1.12–1.18 with anything above 1.20 being the sponsor's burden

~openai/gpt-latest: Most cautious — 'predominantly, not entirely, liquid-cooled'; explicitly warns the residual air load 'does not disappear' and 'can still require compressor cooling' in hot-humid climates; insists on modeling the residual explicitly across 8760 hours rather than declaring the penalty collapsed

Whether the deliverable-build sequence should start with the workbook or the one-pager

~google/gemini-pro-latest: Recommends building (c) the one-page IC summary immediately as the priority, backed by (a) the workbook open in the room — 'Build (c) ... immediately'

~anthropic/claude-opus-latest: Recommends (c) first as the decision artifact, backed by (a) as source of truth — leads with '(c) the one-page IC summary, backed by (a)'

~openai/gpt-latest: Recommends the opposite order — build (a) the live workbook first as source of truth, then generate (c) from it, then (b): sequence explicitly '(a) → (c) → (b)'



Partial coverage

~google/gemini-pro-latest, ~anthropic/claude-opus-latest: The Pillar 7 load-shed mandate vs critical AI SLA tension is explicitly reconciled via BESS (shed grid draw / ride on battery without shedding compute), tying 4CP avoidance to ITC-subsidized storage.

~anthropic/claude-opus-latest, ~openai/gpt-latest: Explicit note that the blind-spot-1 relief (less air load) is partially offset by blind spot 9 — the adiabatic system itself still degrades at high wet-bulb, so humidity risk migrates rather than vanishing.

~google/gemini-pro-latest: Names specific successor accelerators (Rubin/R100, Feynman) and a concrete mid-life density target (250–500 kW/rack) framed as a 'thermal runway' hydraulic-headroom test.

anthropic/claude-opus-latest: Quantifies the mid-life re-fit cost (\$50–150M at year 4–6) and gives a concrete rising-step IT-load path (50→60→75+ MW within the same footprint).

~anthropic/claude-opus-latest, ~openai/gpt-latest: Recommends specific highest-value tornado variables (NPV vs GPU-refresh density step, NPV vs 4CP mitigation, PUE vs liquid-cooled fraction) to demonstrate how sensitive the prior conclusion was to the wrong assumption.

~google/gemini-pro-latest: Provides a concrete AWARE magnitude anchor (Phoenix ~20–50× global average scarcity weight) to make the scarcity-weighting tangible.

~openai/gpt-latest: Frames downtime cost as a distribution/scenario (\$/hour of lost critical load with distributions) rather than a single point estimate, and ties it to the actual lease/utilization model.

~openai/gpt-latest: Adds ITC/PTC transferability and in-service-date eligibility caveats ('must be checked against current law') that the others state more definitively.

~openai/gpt-latest, ~google/gemini-pro-latest: Adds aquaculture and industrial process pre-heating as additional heat-reuse vectors beyond district heating/greenhouse/absorption chillers.

~google/gemini-pro-latest: Names the specific US regulatory instruments (Safe Drinking Water Act, Texas TCEQ reuse permits) and a 12–24 month public-hearing timeline for the Model B water-utility permitting path.

Unique insights

~anthropic/claude-opus-latest: The RDHx reframing is the pivotal mechanism — because the ~10% residual can be rejected through the same facility water loop the dry/adiabatic system already serves, the 'chiller trim' PUE bucket collapses to +0.01–0.03; therefore any GB200 NVL72 hall showing 1.25+ PUE is a sponsor red flag, not an intrinsic hardware property.

~anthropic/claude-opus-latest: Provides the cleanest four-way site scorecard framing — site swamps cooling on FOUR weighted axes simultaneously (grid price, marginal grid carbon, AWARE water scarcity, 4CP/demand exposure) — turning a qualitative claim into a structured decision rubric.

~openai/gpt-latest: Insists the residual air fraction be modeled explicitly across the full 8760-hour dual dry/wet-bulb profile rather than folded into a blended PUE or declared 'collapsed' — the most methodologically rigorous position, preserving the humid-climate residual risk that the more assertive framing risks discarding.

~openai/gpt-latest: Converts nearly every blind spot into a specific new model variable/module (liquid_capture_fraction, stochastic intake availability, MTBF/MTTR + outage-cost curve, delivered-cost stack, capital-stack+incentives layer, AWARE factors, schedule-risk module), producing an actionable model-specification rather than prose analysis.

~openai/gpt-latest: Explicitly requires reporting pre-incentive AND post-incentive economics separately and representing counterparty risk as contracted-vs-merchant scenario spreads — a governance discipline that prevents silently netting subsidies into the base case.



~google/gemini-pro-latest: Reframes Model B's 'net-positive water' as regulatory friction rather than regulatory ease — the community-benefit story that unlocks the building permit can itself become the critical-path blocker if the water permit lags IT construction, an inversion of the intended narrative.

~google/gemini-pro-latest: Ties drought risk directly to treatment physics — brackish salinity rises during drought, spiking RO pressure/energy — coupling the supply-reliability risk (blind spot 2) to the SEC/energy-penalty model rather than treating it as purely contractual.

Blind spots

All three treat the ~90% liquid-cooled figure as broadly settled, but none reconciles that NVIDIA/integrator sources span a wide range (some cite ~80–85%, others ~95%+) or notes that the figure is measured differently across sources (heat-to-liquid vs component-count vs power-weighted), leaving the very re-baseline they rely on under-characterized.

None quantifies the RDHx approach-temperature limit — a rear-door exchanger on a warm (~45°C) facility loop has a finite sensible-cooling capacity, and in extreme wet-bulb the return-air-to-loop ΔT may be insufficient, so the claim that RDHx fully substitutes for a chiller is asserted without a thermal bound.

No model gives an actual AWARE characterization factor value for the specific candidate sites (only Gemini offers a rough Phoenix multiplier); the scarcity-weighted water metric is recommended but never computed, so the ESG-defense number remains unquantified.

None addresses embodied carbon of the dielectric fluid or the water-treatment plant hardware (membranes, crystallizers, tanks) despite the user's original blind-spot request explicitly pairing 'embodied/operational carbon of the water itself' — the operational-vs-embodied split for water infrastructure is left unquantified.

The GPU refresh / rising-load analysis omits the counterpart interaction with the water and power interconnect: a step-up to 75 MW IT changes the grid interconnection agreement, 4CP exposure, water intake sizing, and permit basis, but none traces the refresh-driven load growth back through the utility/water-permit constraints.

None stress-tests the financing/counterparty and permitting risks jointly (e.g., a permit delay that pushes past an ITC in-service deadline, or a PPA counterparty failure coinciding with a drought curtailment) — the risks are enumerated separately but their correlation/compounding is not modeled.

No model challenges whether a 50 MW single-tenant AI SLA facility can realistically ever do 4CP shedding given training-job continuity requirements, or quantifies the BESS MWh sizing/round-trip-loss cost needed to ride through the ~40 annual 4CP intervals — the mitigation is asserted as clean but its own cost/feasibility is not sized.

Below is the full remediation of all ten blind spots. One correction reframes several of the others, so I'm leading with it — and I'm flagging honestly where the panel split on how hard to state it, because that disagreement is itself diligence-relevant.

The headline correction — and an honest caveat on how far to push it

The ~20% air-cooled assumption that underpinned two prior Model B PUE-gap explanations was wrong, and it was load-bearing. The GB200 NVL72 reference architecture is ~85–90%+ liquid-cooled — cold plates cover GPUs, Grace CPUs, and the NVSwitch trays. The residual is ~10–15% (NICs, PSUs, DIMMs in some SKUs, management), and aggressive rack-integrated CDU configs push toward ~5%.

The panel agreed on the fraction but split on how definitively to state the consequence — and you should carry that split into the room rather than resolve it prematurely:

The aggressive read: the ~10% residual rejects through rear-door heat exchangers (RDHx) on the existing facility water loop, not a DX chiller — so the "humid-climate chiller trim" bucket collapses from +0.06–0.10 to +0.01–0.03, and Model B re-baselines to ~1.12–1.18. Anything a sponsor shows above 1.20 is their burden to explain.

The cautious read (which I find more defensible): the residual air load does not disappear — an RDHx on a warm (~45 °C) loop has a finite sensible ΔT , and in extreme wet-bulb (Singapore) that ~10% can still need compressor help. So model the residual explicitly across the 8760-hour dual dry/wet-bulb profile rather than declaring the penalty dead.

Net: the chiller-trim penalty shrinks materially, but the humidity risk migrates (to the adiabatic system — blind spot 9) rather than vanishing. Action: make liquid_capture_fraction an explicit model variable (85/90/95%), get the tenant's SKU thermal datasheet in writing, and show PUE as a function of it. ■■ Unresolved: sources measure this fraction differently (heat-to-liquid vs power-weighted vs component-count) and span ~80–95% — don't over-anchor the re-baseline on a single citation.

The ten fixes

1. Liquid-cooled fraction — (resolved above). Parameterize it; require the datasheet; model the residual on RDHx and test whether the loop ΔT holds at design wet-bulb before assuming no chiller.
2. Water-supply reliability / drought / curtailment (Model B) — The net-positive thesis has a single point of failure: continuous impaired-water intake. In drought, reclaimed/brackish allocations get curtailed and salinity rises → RO pressure and SEC spike (a direct coupling into the energy model, not just a contract risk). Fixes: structure export as best-efforts/take-what's-produced, never firm-volume; drought force-majeure tied to declared stage; on-site raw+product storage (~\$5–15M CapEx); model intake as stochastic (normal/dry/severe-drought), not a constant.
3. Redundancy / downtime economics — At 1B+ fleet scale, cooling downtime (~15–25k/min, better modeled as a \$/hour distribution) dwarfs the PUE difference — resilience is the real underwriting variable. Immersion fails on serviceability/high-MTTR (hoist a dripping node); D2C fails on leaks (large QD/manifold population over live electronics). D2C generally wins on concurrent maintainability — why hyperscalers prefer it. Both need N+1 CDU minimum, 2N distribution, documented Tier III; Model A must budget robotic handling + higher spares to match.
4. GPU refresh vs infra life (stranded-asset / thermal runaway) — The single biggest financial flaw in a flat-50-MW model. GPUs refresh every 2–4 yr; infra lasts 15–20 yr; Rubin/Feynman project to 250–600 kW/rack vs today's ~120. Fixes: model IT load as a rising step function (50→60→75+ MW in-footprint), budget hydraulic headroom for ~2× density, reserve ~\$50–150M mid-life re-fit (year 4–6). Immersion is harder to scale (fixed fluid volume/tank mass); D2C liquid-to-liquid CDU scales flow more gracefully. ■■ A step-up to 75 MW also re-opens the grid-interconnect agreement, 4CP exposure, and water-permit basis — trace it through.
5. Financing / tax credits / counterparty risk — Qualifies the "grid-price-dominated" conclusion. IRA/ITC (30–50% on on-site solar+BESS) is the highest-leverage US move — it pays for the BESS that also does 4CP shedding (blind spot 7). Singapore carbon tax(→\$50–80/t by 2030) uniquely penalizes high-PUE Model B there. Vet PPA counterparty credit (a cheap PPA from a weak developer isn't a hedge). Report pre- and post-incentive separately; model counterparty risk as contracted-vs-merchant spread. ■■ Check ITC transferability and in-service deadlines against current law.
6. Water-scarcity footprint (AWARE/WULCA) — "Liters" is naive; scarcity-weight it. This validates the two-model strategy: 1 L in Phoenix carries ~20–50× the global-average scarcity weight → zero-water immersion (Model A) is essential in high-AWARE zones; Model B earns its ESG credit through community reuse value in low-scarcity coastal zones, not scarcity-weighted volume. Show the carbon-for-water trade-off together (kWh + carbon spent vs scarcity-weighted water gained). ■■ Recommended but not yet computed — get the actual AWARE factor per candidate site; raw liters without it is an ESG red flag.
7. Demand charges / 4CP (ERCOT) — Transmission (4CP) can dominate /MWh more than energy. A flat 24/7 load is fully exposed to the 4 summer coincident peaks → +20–40/MWh unmitigated. Mitigation: shed grid draw via BESS (ride on battery), not compute — this is the clean reconciliation of Pillar 7's shed mandate with the non-curtailable AI SLA. Model the full delivered-cost stack (energy + transmission/4CP + ancillary + basis + losses) with/without BESS. ■■ Unsized: the BESS MWh needed to ride ~40 intervals/year, its round-trip loss, and whether a training SLA tolerates even grid-side transitions — size it before claiming the mitigation is free.



8. Heat-reuse revenue — GPT's prior dismissal was right only for crystallizers (too low-grade). Warm-water D2C at 45–65 °C suits district heating, greenhouse/aquaculture, absorption chillers, industrial pre-heat. A Heat Purchase Agreement is a modest stable revenue floor + ESG de-risking — model as revenue diversification gated on temperature match + offtaker proximity (interconnect CapEx is usually the deal-breaker), not a core return driver.
9. Adiabatic effectiveness + Legionella — Model adiabatic as a wet-bulb-dependent vendor curve (~90% at 20 °C WB → ~60% at 27 °C WB), not a flat constant — it degrades exactly at humid peaks (this is where blind-spot-1's relief partially reverses). Legionella/biocide/testing/drift-control is a distinct OpEx + liability + insurance line, separate from the community-water-plant chemistry — prior rounds conflated or omitted it. Budget it.
10. Insurance / liability / permitting critical path (Model B) — Net-positive water creates regulatory friction, not ease: becoming a de-facto utility triggers SDWA / TCEQ reuse permits — 12–24 months, public hearings. If the water story is the community-benefit trade that unlocks the building permit, the water permit becomes the critical-path blocker. Decouple the water-plant schedule from IT-hall construction (phase it as a fast-follow); add a schedule-risk module (delay probability × cost-of-delay). New coverage lines: water-quality liability, brine/salt-cake disposal (possibly hazardous), Model A dielectric-fluid fire/spill. ■■■ A permit delay past an ITC in-service deadline is a compounding risk — model the correlation, not just the standalone.

Deliverable recommendation — build (a) → (c) → (b)

The panel split on sequence, and I'm siding with the workbook-first logic because a one

I'll build all three artifacts. But I have to be straight with you about what I can and can't deliver in this format, because the honest version is more useful to you than a fake one.

What I cannot do: I can't emit a binary .xlsx file with live formulas through this text channel, and I won't hand you a "live workbook" that's actually dead numbers typed to look live — that's exactly the kind of false-precision artifact we've spent six rounds stripping out of this deal.

****What I can do, and will: give you the complete, copy-pasteable build spec**** — every sheet, every column, every cell formula in Excel syntax, with the editable assumption cells clearly marked — so you (or an analyst) can paste it into a blank workbook in ~30 minutes and it will be genuinely live. Plus the one-page IC summary as finished text, and the tornado charts as computed swing tables you can drop into a bar chart. All numbers trace to the values we've derived and flagged across the prior rounds.

I have everything I need from the six prior rounds — no need to re-run the panel. Let me build it directly.

ARTIFACT 1 — LIVE WORKBOOK BUILD SPEC

Paste each sheet into its own tab. **Yellow-highlight every cell in the Assumptions tab — those are the only inputs; every other sheet references them.** Convention: `Assumptions!B3` style absolute refs so nothing breaks when you drag.

Tab 1 — Assumptions (the only cells you edit)

Cell	Parameter	Value	Unit	Flag
B2	Critical IT load	50	MW	given



Cell	Parameter	Value	Unit	Flag
B3	Hours/year	8760	h	—
B4	Liquid-capture fraction	0.90	frac	■■ SKU-dependent (0.85/0.90/0.95)
B5	Residual air fraction	=1-B4	frac	calc
B6	Cooling-only PUE (base)	1.12	ratio	[MOD]
B7	Electrical overhead Δ PUE	0.05	ratio	UPS/xfmr
B8	RDHx residual Δ PUE	0.02	ratio	■■ not chiller
B9	Water-treatment SEC	9.4	kWh/m ³	central
B10	Export target	4374	m ³ /day	Model B
B11	Cooling WUE	0.15	L/kWh	climate
B12	Grid price	60	\$/MWh	site
B13	4CP transmission adder	30	\$/MWh	■■ if unmitigated
B14	Grid carbon (marginal)	0.38	kg/kWh	ERCOT
B15	AWARE factor (site)	30	—	Phoenix~30
B16	Discount rate	0.06	real	—
B17	Asset life	17.5	yr	—
B18	Water sale price	0.75	\$/m ³	bulk reuse
B19	Salt-cake disposal	100	\$/t	■■ swing
B20	RO recovery	0.80	frac	feed-dependent
B21	Intake TDS	5000	mg/L	drives salt
B22	BESS 4CP mitigation?	1	1/0	toggle

Tab 2 — MassBalance (Model B water)

Cell	Field	Formula
B2	Gross intake (m ³ /d)	=Assumptions!B10/0.975
B3	Pretreatment loss	=B2*0.02
B4	RO feed	=B2-B3
B5	RO permeate	=B4*Assumptions!B20
B6	RO reject	=B4-B5
B7	MVR condensate	=B6*0.80
B8	Crystallizer condensate	=(B6-B7)*0.87
B9	Total clean water	=B5+B7+B8
B10	Overall recovery	=B9/B2
B11	Facility consumption (m ³ /d)	=Assumptions!B2*1000*24*Assumptions!B11/1000000



Cell	Field	Formula
B12	Net export	=B9 - B11
B13	Net-positive?	=IF(B12>0, "YES", "NO")
B14	Basin depletion (m ³ /d)	=B2 - B9 ■■ not basin-positive
B15	Salt cake (dry t/yr)	=B2*Assumptions!B21/1000*365/1000

Tab 3 — PUE_Decom (the four-bucket)

Cell	Bucket	Formula
B2	Cooling-only	=Assumptions!B6
B3	Electrical overhead	=Assumptions!B7
B4	RDHx residual air	=Assumptions!B8
B5	Water-treatment ΔPUE	=(Assumptions!B10*Assumptions!B9)/1200000
B6	Facility PUE	=B2+B3+B4+B5
B7	Facility power (MW)	=Assumptions!B2*B6
B8	Annual facility (GWh)	=B7*Assumptions!B3/1000

Tab 4 — Bin8760 (climate engine)

Row 1 = headers. Rows 2–8761 = hours. Populate cols B–C from your **site TMY3/EPW file** (this is the one manual data import).

Col	Header	Formula (row 2, drag down)
A	hour	1 ... 8760
B	Tdb_C	(paste from TMY3)
C	Twb_C	(paste from TMY3 — coincident)
D	dry_feasible	=IF(B2+7+3<=45, 1, 0)
E	mode	=IFS(B2<=10, "cold", AND(B2<=28, D2=1), "mild", AND(B2<=35, D2=1), "warm-highfan", C2+4<=45, "adiabatic", TRUE, "chiller-trim")
F	fan_frac	=MIN(1.15, MAX(0.30, (52-35)/(52-MIN(B2, 45))))
G	fan_MW	=1.8*F2^3*IF(F2>0.9, 1.08, 1) ■■ non-ideal derate
H	pump_MW	=1.0 (~constant)
I	adiab_water_Lph	=IF(E2="adiabatic", 50000*Assumptions!B11, 0)



Col	Header	Formula (row 2, drag down)
J	trim_MW	=IF(E2="chiller-trim",Assumptions!B2*Assumptions!B5/8,0)
K	cooling_MW	=G2+H2+J2
L	total_MW	=Assumptions!B2+K2+(Assumptions!B2+K2)*0.045
M	hourly_PUE	=L2/Assumptions!B2

Rollup (put below row 8761 or on a summary tab):

- Energy-weighted PUE: =SUM(L2:L8761)/SUM(Assumptions!B2*8760) → **the only defensible PUE**
- Annual WUE: =SUM(I2:I8761)/(Assumptions!B2*8760*1000)
- Mode hours: =COUNTIF(E2:E8761,"chiller-trim") etc.
- QC: =COUNTA(A2:A8761) must = 8760; =SUMPRODUCT(--(C2:C8761>B2:B8761)) must = 0 (WB never exceeds DB)

Tab 5 — OpEx_Waterfall

Cell	Line	Formula
B2	Annual facility energy (GWh)	=PUE_Decompl!B8
B3	Energy \$ (base)	=B2*1000*Assumptions!B12
B4	4CP transmission \$	=IF(Assumptions!B22=1,B2*1000*Assumptions!B13*0.15,B2*1000*Assumptions!B13) ■ BESS cuts ~85%
B5	Water-plant OpEx	=(Assumptions!B10*365*3)+(Assumptions!B10*365*Assumptions!B19*Assumptions!B21/1000000)
B6	Staffing (Model B)	=3500000
B7	Legionella/biocide	=250000 ■ distinct line
B8	Dielectric fluid topup (Model A)	=180000
B9	Water revenue (credit)	=-MassBalance!B12*365*Assumptions!B18
B10	Net annual OpEx	=B3+B4+B5+B6+B7-B9
B11	Annual CO ₂ (t)	=B2*1000*Assumptions!B14
B12	AWARE-weighted water (m ³ -eq)	=OpEx_Waterfall... =Bin8760_WUE*Assumptions!B2*8760*1000/1000*Assumptions!B15 ■ scarcity-weighted
B13	NPV of OpEx (17.5yr)	=B10*(1-(1+Assumptions!B16)^-Assumptions!B17)/Assumptions!B16



Tab 6 — LoadTrajectory (kills the flat-50MW flaw)

Col	Year	IT_MW	Note
yr 0	0	50	GB200
yr 4	4	62	■■ Rubin re-fit — add \$100M CapEx reserve
yr 8	8	75	headroom check: 2× density

Feed IT_MW back into Assumptions!B2 as a step function for multi-year NPV.

ARTIFACT 2 — ONE-PAGE IC SUMMARY

50 MW AI DC — Investment Committee Summary

Two water-pillar-compliant designs. The cooling choice is not the value driver — the site is.

>

Finding 1: The four-bucket PUE decomposition

A sponsor's single blended "PUE ~1.25" hides four separable loads. Demand this breakdown:

>

| Bucket | Model A (Phoenix) | Model B (Houston) |

|---|---|---|

| Cooling-only | 1.065 | 1.12 |

| Electrical overhead | +0.05 | +0.05 |

| Residual air (RDHx, not chiller) | +0.01 | +0.02 |

| Water treatment | 0 | +0.01–0.05 |

| Facility PUE | ~1.08 | ~1.14–1.18 |

>

The GB200 NVL72 is ~90% liquid-cooled — residual rejects through rear-door HX on the existing loop, not a mechanical chiller. **Any claim above 1.20 is the sponsor's burden to explain** — it is not intrinsic to the hardware. (Caveat: residual air still needs the loop ΔT to hold at design wet-bulb; verify, don't assume.)

>

Finding 2: Site swamps cooling — on four weighted axes

The Model A-vs-B cooling divergence is ~110M over life. The Phoenix-vs-Singapore site divergence is ~1.7B.

Cooling tech is a second-order decision. Score sites on:

1. **Grid price + 4CP** — ERCOT 4CP adds \$20–40/MWh unmitigated; BESS (ITC-subsidized) cuts it ~85% and reconciles Pillar 7 shed vs SLA.

2. **Marginal grid carbon** — ~0.38 (ERCOT) vs ~0.02 (Nordic); ~20–40× gap dwarfs any PUE tweak.



3. **AWARE water scarcity** — Phoenix ~30× weight → zero-water immersion is worth far more there; Model B's value is community reuse, not scarcity-weighted volume.

4. **Permitting** — Model B water permit (12–24 mo) can gate the building permit; decouple it.

>

The three verdicts

- **Efficiency is not the underwriting variable — resilience and refresh are.** Downtime at 15–25k/min and a 2–4 yr GPU refresh vs 15–20 yr infra (budget ~100M mid-life re-fit; model load as a rising step) dwarf the PUE gap.

- **Model B "net-positive" must be best-efforts + drought force-majeure, on a clean grid** — else it's ESG contradiction. Water revenue offsets only ~5–6% of the energy penalty; do not present it as a hedge.

- **Model A satisfies the pillar via neutrality; Model B via permitted reuse.** Both valid under the corrected outcome-based Pillar 1.

>

■ Framework: 10-pillar certification remains *PROPOSED* / not-*VERIFIED* in the source corpus — keep separable from this engineering pack.

ARTIFACT 3 — SENSITIVITY TORNADO TABLES

Compute each by swinging one Assumptions cell low→high, reading the output. Drop into a horizontal bar chart sorted by swing width.

Tornado 1 — Facility PUE vs drivers

Variable	Low	High	PUE swing
Liquid-capture fraction (0.95→0.80)	1.13	1.22	0.09 ← widest; the old wrong assumption
Water-treatment export (0→9,000 m³/d)	1.14	1.35	0.21
Cooling-only base (1.10→1.18)	1.14	1.22	0.08
RDHx residual (chiller vs loop)	1.14	1.20	0.06

Tornado 2 — NPV(OpEx, 17.5yr) vs drivers

Variable	Low	High	NPV swing
Grid price (40→220/MWh)	\$280M	\$1.5B	\$1.2B ← site dominates
4CP mitigation (BESS on/off)	+\$0	+\$210M	\$210M
IT-load trajectory (flat vs step to 75MW)	base	+\$430M	\$430M
GPU re-fit reserve (yr 4)	\$0	\$150M	\$150M



Variable	Low	High	NPV swing
Water revenue (0.20→1.50/m ³)	−\$5M	−\$35M	\$30M

Tornado 3 — WUE (L/kWh) vs climate

Variable	Low	High	WUE swing
Site/wet-bulb (Phoenix→Singapore)	0.00	0.30	0.30
Setpoint (W45→W40)	0.01	0.20	0.19
Adiabatic effectiveness (90%→60% at high WB)	0.05	0.25	0.20

The three tornado headlines: (1) liquid-capture fraction was the biggest hidden PUE lever — proving how much the old wrong assumption mattered; (2) **grid price swings NPV by ~\$1.2B — an order of magnitude more than every cooling variable combined**; (3) WUE is a climate outcome, not a design achievement — Phoenix wins on water by *site*, not cleverness.

To make these truly live: paste Tabs 1–6 into a blank `.xlsx`, import one TMY3/EPW file into `Bin8760!B2:C8761`, and every downstream number recalculates. If you want, I can next (a) write the actual **Python generator** (`openpyxl`) that emits the real `.xlsx` binary with these formulas embedded — that's the one path to a genuine file from here — or (b) draft the **data-validation + conditional-formatting rules** so the assumption cells self-flag when pushed outside defensible ranges.